

MECHANICAL SYMBOLS LIST		
AC-1 (TXF-1)	EQUIPMENT SYMBOL	CONTROLS AND SENSORS
	POINT OF NEW CONNECTION TO EXISTING	THERMOSTAT TEMPERATURE SENSOR
AIR DEVICES		
	CEILING DIFFUSER SUPPLY	AIR DUCT W/ 1.5" ACOUSTICAL LINING
	CEILING DIFFUSER RETURN	FLEXIBLE DUCT
DUCT ACCESSORIES		
	BACKDRAFT DAMPER	FLEXIBLE CONNECTION RECTANGULAR DUCT (WIDTH X DEPTH)
	VOLUME DAMPER W/ ACCESS DOOR	SUPPLY AIR RECTANGULAR DUCT CROSS SECTION
	MOTORIZED DAMPER W/ ACCESS DOOR	RETURN AIR RECTANGULAR DUCT CROSS SECTION

MECHANICAL ABBREVIATIONS	
AL	ACOUSTIC LINING
CDS	CEILING DIFFUSER SUPPLY
CDR	CEILING DIFFUSER RETURN
CFM	CUBIC FEET OF AIR PER MINUTE
COP	COEFFICIENT OF PERFORMANCE
EER	ENERGY EFFICIENCY RATIO
EN	ENERGY ANALYSIS
FC	FLEXIBLE CONNECTION
HSPF	HEATING SEASONAL PERFORMANCE FACTOR
EF	EXHAUST FAN
SEER	SEASONAL ENERGY EFFICIENCY RATIO
TEF	TOILET EXHAUST FAN
VD	VOLUME DAMPER
VFD	VARIABLE FREQUENCY DRIVE
FD	FIRE DAMPER
MD	MOTORIZED DAMPER
RTU	ROOF TOP UNIT
S.A.E	SAME AS EXISTING
V.I.F	VERIFY IN FIELD
K.E.F	KITCHEN EXHAUST FAN
AC	AIR CONDITIONING UNIT
CU	CONDENSING UNIT
VTR	VENT THROUGH ROOF

MECHANICAL DRAWING LIST	
M0.1	MECHANICAL GENERAL NOTES, SYMBOLS LIST & ABBREVIATIONS
M0.2	MECHANICAL SPECIFICATIONS (1 OF 2)
M0.3	MECHANICAL SPECIFICATIONS (2 OF 2)
M1.0	MECHANICAL FLOOR PLAN
M1.1	MECHANICAL ROOF PLAN
M5.0	MECHANICAL DETAILS (1 OF 3)
M5.1	MECHANICAL DETAILS (2 OF 3)
M5.2	MECHANICAL DETAILS (3 OF 3)
M6.0	MECHANICAL SCHEDULES
M7.0	HEAT LOAD CALCULATION REPORTS
H1.0	HOOD DETAILS (1 OF 4)
H1.1	HOOD DETAILS (2 OF 4)
H1.2	HOOD DETAILS (3 OF 4)
H1.3	HOOD DETAILS (4 OF 4)

BUILDING DEPARTMENT NOTES

ALL WORK SHALL COMPLY WITH APPLICABLE SECTIONS OF 2023 BUILDING CODE; BASE CODE IBC 2021, AND ALL RULES AND REGULATIONS OF THE DEPARTMENT OF BUILDINGS TO DATE.

1. ALL HEATING AND COOLING LOADS CALCULATED PER ASHRAE/ACCA 183.
2. VENTILATION FOR ALL AREA SHALL COMPLY WITH 2023 MECHANICAL CODE, CHAPTER 4.
3. AS PER C408.2.5 OF BUILDING CODE; BASE CODE FECC 2023, CONSTRUCTION DOCUMENT SHALL REQUIRE THAT, WITHIN 90 DAYS AFTER THE DATE OF SYSTEM ACCEPTANCE, RECORD DRAWINGS OF THE ACTUAL INSTALLATION BE PROVIDED TO THE BUILDING OWNER OR THE DESIGNATED REPRESENTATIVE OF THE BUILDING OWNER.
4. AS PER C408.3.2 OF BUILDING CODE; BASE CODE FECC 2023, CONSTRUCTION DOCUMENT SHALL REQUIRE THAT, WITHIN 90 DAYS AFTER THE DATE OF SYSTEM ACCEPTANCE, THE CONTRACTOR SHALL ENGAGE THE SERVICES OF A PROFESSIONAL ENGINEER TO PROVIDE THE REQUIRED SPECIAL INSPECTIONS AND TESTS.
5. TESTS WILL BE CONDUCTED UNDER DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, ARCHITECT OR OTHER PERSON HAVING NOT LESS THAN FIVE (5) YEARS EXPERIENCE SUPERVISING THE INSTALLATION OF SUCH MECHANICAL SYSTEMS. THE TESTS WILL SHOW COMPLIANCE WITH FLORIDA BUILDING CODE; BASE CODE FBC 2023, REQUIREMENTS AS OUTLINES IN SECTION.
6. THE LICENSED PROFESSIONAL ENGINEER, ARCHITECT OR OTHER PERSON HAVING NOT LESS THAN FIVE (5) YEARS EXPERIENCE SUPERVISING THE INSTALLATION OF SUCH MECHANICAL SYSTEMS AND CONDUCTING SUCH TESTS WILL FILE DOCUMENTATION AND REPORTS OF TESTS THAT THE SYSTEM COMPLIES WITH THE CONSTRUCTION DOCUMENTS AND APPLICABLE LAWS.
7. TESTS OF MECHANICAL SYSTEMS SHALL BE PERFORMED IN ACCORDANCE WITH THE FOLLOWING SECTIONS OF FLORIDA BUILDING CODE; BASE CODE FMC 2023 CHAPTER 4 AND CHAPTER 5:
 - A. MECHANICAL VENTILATION – SECTION 403.
8. THE FOLLOWING WORK ITEMS, COMPONENTS, MATERIALS, CAPACITIES, ETC. SHALL COMPLY WITH THE REFERENCED CODE OR STANDARD:
 - A. STANDARDS OF HEATING – BUILDING CODE; BASE CODE FMC 2023.
 - B. DUCT CONSTRUCTION AND INSTALLATION – SECTION 603 OF BUILDING CODE; BASE CODE FMC 2023.
 - C. AIR INTAKES, EXHAUSTS AND RELIEF – SECTION 401 OF BUILDING CODE; BASE CODE FMC 2023.
 - D. AIR FILTERS – SECTION 605 OF BUILDING CODE; BASE CODE FMC 2023.
 - E. MANUAL AND AUTOMATIC FIRE AND SMOKE CONTROLS FOR AIR DISTRIBUTION SYSTEMS – SECTION 513 OF BUILDING CODE; BASE CODE FMC 2023.
 - D. GAS FIRED EQUIPMENT – 2023 FUEL & GAS CODE
9. MINIMUM TEMPERATURE TO BE MAINTAINED IN OCCUPIED SPACES DURING HEATING SEASON: 68 DEG. FAHRENHEIT.
10. REFER TO ARCHITECTURAL DRAWINGS FOR REQUIRED FIRE-RATED WALL AND SMOKE WALL CONSTRUCTION AND LOCATION.
11. THESE PLANS ARE APPROVED ONLY FOR THE WORK INDICATED ON THE APPLICATION SPECIFICATION SHEET. ALL OTHER MATTERS SHOWN ARE NOT TO BE RELIED UPON OR TO BE CONSIDERED AS EITHER BEING APPROVED OR IN ACCORDANCE WITH APPLICABLE CODES.

SCOPE OF WORK

SCOPE OF WORK

1. THE WORK UNDER CONTRACT INCLUDES ALL LABOR, MATERIALS AND APPLIANCES NECESSARY FOR THE FURNISHING, INSTALLING AND TESTING, COMPLETE AND READY FOR SAFE OPERATION OF THE SYSTEMS AS DESCRIBED IN THE SPECIFICATIONS, FLOOR PLAN(S), DESIGN, DETAIL DRAWINGS, NOTES, RFI'S, ETC. FOR THIS PROJECT. WORK SHALL BE INSTALLED IN A NEAT, WORKMANLIKE MANNER.
2. THE CONTRACTOR SHALL GIVE NECESSARY NOTICE, FILE DRAWINGS AND SPECIFICATIONS WITH THE DEPARTMENT HAVING JURISDICTION, OBTAIN PERMITS OR LICENSES NECESSARY TO CARRY OUT THIS WORK AND PAY ALL FEES THEREFORE. THE CONTRACTOR SHALL ARRANGE FOR INSPECTION AND TESTS OF ANY OR ALL PARTS OF THE WORK IF SO REQUIRED BY AUTHORITIES AND PAY ALL CHARGES FOR SAME. THE CONTRACTOR SHALL PAY ALL COSTS FOR, AND FURNISH TO THE OWNER BEFORE FINAL BILLING, ALL CERTIFICATES NECESSARY AS EVIDENCE THAT THE WORK INSTALLED CONFORMS WITH ALL REGULATIONS WHERE THEY APPLY TO THIS WORK.
3. THE CONTRACTOR SHALL FURNISH A WRITTEN GUARANTEE TO REPLACE OR REPAIR PROMPTLY AND ASSUME RESPONSIBILITY FOR ALL EXPENSES INCURRED FOR ANY WORKMANSHIP AND EQUIPMENT IN WHICH DEFECTS DEVELOP WITHIN ONE YEAR FROM THE DATE OF FINAL CERTIFICATE FOR PAYMENT AND/OR FROM DATE OR ACTUAL USE OF EQUIPMENT OR OCCUPANCY OF SPACES, BY OWNER, INCLUDED UNDER THE VARIOUS PARTS OF THE WORK, WHICHEVER DATE IS EARLIER. THIS WORK SHALL BE DONE AS DIRECTED BY THE OWNER. THIS GUARANTEE SHALL ALSO PROVIDE THAT WHERE DEFECTS OCCUR, THE CONTRACTOR WILL ASSUME RESPONSIBILITY FOR ALL EXPENSES INCURRED IN REPAIRING AND REPLACING WORK OF OTHER TRADES AFFECTED BY DEFECTS, REPAIRS OR REPLACEMENTS IN EQUIPMENT SUPPLIED BY THE CONTRACTOR.
12. THE CONTRACTOR SHALL KEEP ALL EQUIPMENT AND MATERIALS, AND ALL PARTS OF THE BUILDING, EXTERIOR SPACES, AND ADJACENT STREETS, SIDEWALKS AND PAVEMENTS, FREE FROM MATERIAL AND DEBRIS RESULTING FROM THE EXECUTION OF THIS WORK. EXCESS MATERIALS WILL NOT BE PERMITTED TO ACCUMULATE EITHER ON THE INTERIOR OR THE EXTERIOR.
13. UNLESS OTHERWISE SPECIFICALLY SPECIFIED, INCLUDE ALL CUTTING AND PATCHING OF EXISTING FLOORS, WALLS, PARTITIONS AND OTHER MATERIALS IN THE EXISTING BUILDING. THE CONTRACTOR SHALL RESTORE THESE AREAS TO ORIGINAL CONDITION.
14. MATERIALS AND WORKMANSHIP, UNLESS OTHERWISE NOTED, SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
15. ALL EQUIPMENT SHALL BE PROVIDED WITH ONE YEAR WARRANTY PARTS AND LABOR AND FIVE YEARS ON COMPRESSORS. WARRANTY PERIOD BEGINS UPON PROJECT ACCEPTANCE.
16. ALL MATERIAL AND EQUIPMENT TO BE NEW UNLESS OTHERWISE NOTED AND SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
17. THE CONTRACTOR SHALL BE RESPONSIBLE FOR HIS WORK WITH ITS COMPLETION AND FINAL ACCEPTANCE AND SHALL REPLACE ANY OF THE SAME WHICH MAY BE DAMAGED, LOST, OR STOLEN WITHOUT ADDITIONAL COST TO THE OWNER.
18. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE FAILURE OF ANY DUCTWORK SYSTEM OR EQUIPMENT TO FUNCTION PROPERLY UPON COMPLETION OF HIS WORK UPON SAID SYSTEM OR EQUIPMENT.

GENERAL NOTES

1. CONTRACTOR SHALL SURVEY THE AREA OF THIS WORK BEFORE SUBMITTING A BID AND SHALL BE RESPONSIBLE FOR NOTIFYING THE ARCHITECT OF ANY CONDITIONS WHICH WOULD PREVENT THE INSTALLATION OF THE WORK AS SHOWN ON DRAWINGS.
2. ALL APPLICABLE CODES, LAWS AND REGULATIONS GOVERNING OR RELATING TO ANY PORTION OF THIS WORK ARE HEREBY INCORPORATED INTO AND MADE A PART OF THESE SPECIFICATIONS, AND THEIR PROVISIONS SHALL BE CARRIED OUT BY THE CONTRACTOR WHO SHALL INFORM THE OWNER, PRIOR TO SUBMITTING A PROPOSAL OF ANY WORK OR MATERIALS WHICH VIOLATE ANY OF THE ABOVE LAWS AND REGULATIONS. ANY WORK DONE BY THE CONTRACTOR CAUSING SUCH VIOLATION SHALL BE CORRECTED BY THE CONTRACTOR.
3. BEFORE PROCEEDING WITH ANY WORK IN OCCUPIED OR USED AREAS, THE CONTRACTOR SHALL APPLY TO OWNER FOR PERMISSION TO ENTER SUCH AREAS. THE CONTRACTOR IS OBLIGED TO PERFORM HIS WORK ONLY AT THE TIMES DESIGNATED BY OWNER. THERE WILL BE NO ADDITIONAL COMPENSATION FOR THE WORK PERFORMED AFTER HOURS OR ON OFF-DAYS WITHOUT PRIOR WRITTEN APPROVAL.
4. THE WORK IN THE BUILDING SHALL BE DONE WHEN AND AS DIRECTED, AND IN A MANNER SATISFACTORY TO THE OWNER. THE WORK SHALL BE PERFORMED SO AS TO CAUSE THE LEAST POSSIBLE INCONVENIENCE AND DISTURBANCE TO THE PRESENT OCCUPANTS.
5. THE CONTRACTOR'S PROPOSAL FOR ALL WORK SHALL BE PREDICATED ON THE PERFORMANCE OF THE WORK DURING REGULAR WORKING HOURS. WHEN SO DIRECTED, HOWEVER, THE CONTRACTOR SHALL INSTALL WORK IN OVERTIME AND THE ADDITIONAL COST TO BE CHARGED THEREFORE SHALL BE ONLY THE "PREMIUM" PORTION OF THE WAGES PAID.
6. CONTRACTOR SHALL ASCERTAIN THE APPROPRIATE METHOD FOR BRINGING THE UNITS INTO AND THROUGH THE BUILDING TO POSITION UNIT IN LOCATION SHOWN ON THE PLANS WHERE NECESSARY. EQUIPMENT SHALL BE SHIPPED FROM MANUFACTURER IN SECTIONS OF SIZE SUITABLE FOR MOVING THROUGH RESTRICTIVE SPACES. COORDINATE WITH BUILDING OWNER APPROPRIATE TIMES OF DAY SUCH EQUIPMENT MAY BE MOVED THROUGH ALL AREAS.
7. DISCONNECT, REMOVE AND/OR RELOCATE EXISTING MATERIAL, EQUIPMENT AND OTHER WORK AS NOTED OR REQUIRED FOR PROPER INSTALLATION OF NEW SYSTEM.
8. CONNECT NEW WORK TO EXISTING WORK IN NEAT AND APPROVED MANNER. RESTORE EXISTING WORK DISTURBED WHILE INSTALLING NEW WORK TO ACCEPTABLE CONDITION AS DETERMINED BY ARCHITECT.
9. PLAN INSTALLATION OF NEW WORK AND CONNECTIONS TO EXISTING WORK TO INSURE MINIMUM INTERFERENCE WITH REGULAR OPERATION OF EXISTING FACILITIES. ALL SYSTEM SHUTDOWNS AFFECTING OTHER AREAS SHALL BE COORDINATED. WITH BUILDING OWNER. INSTALL ISOLATION VALVES AT POINT OF CONNECTION TO THE EXISTING PIPING. PROVIDE TEMPORARY DUCT CAPS AND/OR CONNECTIONS TO MINIMIZE SHUTDOWN TIME.
10. SUPPORT ALL DUCTWORK AND PIPING FROM BUILDING STRUCTURE AND/OR FRAMING IN AN APPROVED MANNER. WHERE OVERHEAD CONSTRUCTION DOES NOT PERMIT FASTENING OR SUPPORTS FOR EQUIPMENT, FURNISH ADDITIONAL FRAMING. INSERTS SHALL BE STEEL, SLOTTED TYPE AND FACTORY PAINTED. SINGLE ROD SHALL BE SIMILAR TO GRINNELL FIG. 281. MULTI-ROD SHALL BE SIMILAR TO FEE & MASON SERIES 9000 WITH END CAPS AND CLOSURE STRIPS. MAXIMUM LOADING INCLUDING PIPES, DUCTWORK CONTENTS AND COVERING SHALL NOT EXCEED 75% OF RATED INSERT CAPACITY. WHEN SUPPORTING FROM BUILDING USE BEAM CLAMPS IN APPROVED MANNER.
11. PROVIDE ALL NECESSARY FLASHING AND COUNTER FLASHING TO MAINTAIN THE WATERPROOFING INTEGRITY OF THIS BUILDING AS REQUIRED BY THE INSTALLATION OR REMOVAL OF PIPES, DUCTS, LOUVERS, CONDUIT, AND EQUIPMENT. PROVIDE EQUIPMENT CURBS AND DUNNAGE STEEL AS REQUIRED.
12. SEAL OPENINGS AROUND DUCTS AND PIPING THROUGH PARTITIONS, WALLS AND FLOORS (NOT IN SHAFTS) WITH MINERAL WOOL OR OTHER NONCOMBUSTIBLE MATERIAL (FIBERGLASS INSULATION IS NOT ACCEPTABLE).
13. WHERE PENETRATIONS THROUGH FIRE RATED WALLS ARE NOT FIRE PROOFED THIS CONTRACTOR SHALL BE RESPONSIBLE TO SEAL SAME TO MAINTAIN THE RATED INTEGRITY.
14. INSTALL WORK SO AS TO BE READILY ACCESSIBLE FOR OPERATION, MAINTENANCE AND REPAIR. MINOR DEVIATIONS FROM DRAWINGS MAY BE MADE TO ACCOMPLISH THIS, BUT CHANGES WHICH INVOLVE EXTRA COST SHALL NOT BE MADE WITHOUT APPROVAL.
15. ACCESS DOORS ARE REQUIRED FOR ALL BUILDING SERVICE VALVES THAT RUN THROUGH THE SPACE, AND ACCESS DOOR SHALL HAVE THE EQUAL RATED CAPACITY (1HR, 2HR, ETC.) AS WALL. COORDINATE ALL LOCATIONS OF ACCESS DOORS WITH THE ARCHITECT.
16. REMOVABLE ACCESS TILE AND/OR ACCESS DOOR ARE REQUIRED IN HUNG CEILINGS, SHAFTS AND WALLS FOR ALL VOLUME AND FIRE DAMPERS, AUTOMATIC DAMPERS AND ALL OTHER MECHANICAL EQUIPMENT AND DEVICES. HAVE CONTRACTOR TO FURNISH ACCESS LOCATION REQUIREMENTS TO GENERAL CONTRACTOR. ACCESS TILE IDENTIFICATION: PROVIDE BUTTONS, TABS, AND MARKERS TO IDENTIFY LOCATION OF CONCEALED VALVES, DAMPERS AND EQUIPMENT.
17. THE CONTRACTOR SHALL KEEP ALL EQUIPMENT AND MATERIALS, AND ALL PARTS OF THE BUILDING, EXTERIOR SPACES, AND ADJACENT STREETS, SIDEWALKS AND PAVEMENTS, FREE FROM MATERIAL AND DEBRIS RESULTING FROM THE EXECUTION OF THIS WORK. EXCESS MATERIALS WILL NOT BE PERMITTED TO ACCUMULATE EITHER ON THE INTERIOR OR THE EXTERIOR.
18. UNLESS OTHERWISE SPECIFICALLY SPECIFIED, INCLUDE ALL CUTTING AND PATCHING OF EXISTING FLOORS, WALLS, PARTITIONS AND OTHER MATERIALS IN THE EXISTING BUILDING. THE CONTRACTOR SHALL RESTORE THESE AREAS TO ORIGINAL CONDITION.
19. MATERIALS AND WORKMANSHIP, UNLESS OTHERWISE NOTED, SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
20. ALL EQUIPMENT SHALL BE PROVIDED WITH ONE YEAR WARRANTY PARTS AND LABOR AND FIVE YEARS ON COMPRESSORS. WARRANTY PERIOD BEGINS UPON PROJECT ACCEPTANCE.
21. ALL MATERIAL AND EQUIPMENT TO BE NEW UNLESS OTHERWISE NOTED AND SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
22. THE CONTRACTOR SHALL BE RESPONSIBLE FOR HIS WORK WITH ITS COMPLETION AND FINAL ACCEPTANCE AND SHALL REPLACE ANY OF THE SAME WHICH MAY BE DAMAGED, LOST, OR STOLEN WITHOUT ADDITIONAL COST TO THE OWNER.
23. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE FAILURE OF ANY DUCTWORK SYSTEM OR EQUIPMENT TO FUNCTION PROPERLY UPON COMPLETION OF HIS WORK UPON SAID SYSTEM OR EQUIPMENT.

SHEET HISTORY SCHEDULE
ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

MECHANICAL
GENERAL NOTES, SYMBOL
LIST & ABBREVIATIONS
M0.1

GENERAL HVAC NOTES	
GENERAL:	
1. PROVIDE ALL MATERIAL AND EQUIPMENT AND PERFORM ALL LABOR REQUIRED TO INSTALL COMPLETE AND OPERABLE MECHANICAL SYSTEMS AS INDICATED ON THE DRAWINGS, AS SPECIFIED AND AS REQUIRED BY CODE.	
2. CONTRACT DOCUMENT DRAWINGS FOR MECHANICAL WORK (HVAC, PLUMBING, AND FIRE PROTECTION) ARE DIAGRAMMATIC AND ARE INTENDED TO CONVEY SCOPE AND GENERAL ARRANGEMENT ONLY.	
3. THE LOCATIONS OF ALL ITEMS SHOWN ON THE DRAWINGS OR CALLED FOR IN THE SPECIFICATIONS THAT ARE NOT FIXED BY DIMENSIONS ARE APPROXIMATE ONLY. THE EXACT LOCATIONS NECESSARY TO SECURE THE BEST CONDITIONS AND RESULTS MUST BE DETERMINED BY THE PROJECT SITE CONDITIONS AND SHALL HAVE THE APPROVAL OF THE ENGINEER BEFORE BEING INSTALLED. DO NOT SCALE DRAWINGS.	
4. WHEN MECHANICAL WORK (HVAC, PLUMBING, SHEET METAL, FIRE PROTECTION, ETC.) IS SUBCONTRACTED, IT SHALL BE THE MECHANICAL CONTRACTOR'S RESPONSIBILITY TO COORDINATE SUBCONTRACTORS AND THE ASSOCIATED CONTRACTS. WHEN DISCREPANCIES ARISE PERTAINING TO WHICH CONTRACTOR PROVIDES A PARTICULAR ITEM OF THE MECHANICAL CONTRACT OR WHICH CONTRACTOR PROVIDES FINAL CONNECTIONS FOR A PARTICULAR ITEM OF THE MECHANICAL CONTRACT, IT SHALL BE BROUGHT TO THE ATTENTION OF THE MECHANICAL CONTRACTOR, WHOSE DECISION SHALL BE FINAL.	
5. COORDINATE CONSTRUCTION OF ALL MECHANICAL WORK WITH ARCHITECTURAL, STRUCTURAL, CIVIL, ELECTRICAL WORK, ETC., SHOWN ON OTHER CONTRACT DOCUMENT DRAWINGS.	
6. INSTALL ALL MECHANICAL EQUIPMENT AND APPURTENANCES IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS, CONTRACT DOCUMENTS, AND APPLICABLE CODES AND REGULATIONS.	
7. WHERE TWO OR MORE ITEMS OF THE SAME TYPE OF EQUIPMENT ARE REQUIRED, THE PRODUCT OF ONE MANUFACTURER SHALL BE USED.	
8. COORDINATE ALL EQUIPMENT CONNECTIONS WITH MANUFACTURERS' CERTIFIED DRAWINGS, COORDINATE AND PROVIDE ALL DUCT AND PIPING TRANSITIONS REQUIRED FOR FINAL EQUIPMENT CONNECTIONS TO FURNISHED EQUIPMENT. FIELD VERIFY AND COORDINATE ALL DUCT AND PIPING DIMENSIONS BEFORE FABRICATION.	
9. ALL CONTROL WIRE AND CONDUIT SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE AND ELECTRICAL DIVISION OF THE SPECIFICATION.	
10. PROVIDE VIBRATION ISOLATION FOR ALL MECHANICAL EQUIPMENT TO PREVENT TRANSMISSION OF VIBRATION TO BUILDING STRUCTURE.	
11. LOCATE ALL TEMPERATURE, AND FLOW MEASURING DEVICES IN ACCESSIBLE LOCATIONS WITH THE STRAIGHT SECTION OF PIPE OR DUCT UP- AND DOWNSTREAM AS RECOMMENDED BY THE MANUFACTURER FOR GOOD ACCURACY.	
12. WHERE BEAMS ARE INDICATED TO BE PENETRATED BY DUCTWORK OR PIPING, COORDINATE DUCTWORK AND PIPING LAYOUT WITH BEAM OPENING SIZE AND OPENING LOCATIONS. COORDINATION SHALL BE DONE PRIOR TO THE FABRICATION OF DUCTWORK, CUTTING OF PIPING, OR FABRICATION OF BEAMS.	
13. ALL MISCELLANEOUS STEEL REQUIRED TO ENSURE PROPER INSTALLATION AND AS SHOWN IN THE DETAILS FOR DUCTWORK, AND EQUIPMENT (UNLESS OTHERWISE NOTED) SHALL BE FURNISHED AND INSTALLED BY THE MECHANICAL CONTRACTOR.	
14. PROVIDE ACCESS PANELS FOR INSTALLATION IN WALLS AND CEILINGS, WHERE REQUIRED TO SERVICE DAMPERS, VALVES, SMOKE DETECTORS, AND OTHER CONCEALED MECHANICAL EQUIPMENT. ACCESS PANELS SHALL BE TURNED OVER TO THE GENERAL CONTRACTOR FOR INSTALLATION. ACCESS PANELS SHALL HAVE THE EQUAL RATED CAPACITY (1HR, 2HR, ETC.) AS WALL.	
15. MECHANICAL EQUIPMENT, DUCTWORK, AND PIPING SHALL NOT BE SUPPORTED FROM A METAL DECK.	
16. ALL EQUIPMENT, PIPING, DUCTWORK, ETC., SHALL BE SUPPORTED AS DETAILED, SPECIFIED, AND REQUIRED TO PROVIDE A VIBRATION-FREE INSTALLATION.	
17. ALL DUCTWORK, PIPING, AND EQUIPMENT SUPPORTED FROM STRUCTURAL STEEL SHALL BE COORDINATED WITH THE GENERAL CONTRACTOR. ALL ATTACHMENTS TO STEEL BAR JOISTS, TRUSSES, OR JOIST GIRDERS SHALL BE AT PANEL POINTS. PROVIDE BEAM CLAMPS MEETING MSS STANDARDS. WELDING TO STRUCTURAL MEMBERS SHALL NOT BE PERMITTED. THE USE OF C-CLAMPS SHALL NOT BE PERMITTED.	
18. LOCATIONS AND SIZES OF ALL FLOOR, WALL, AND ROOF OPENINGS SHALL BE COORDINATED WITH ALL OTHER TRADES INVOLVED.	
19. ALL OPENINGS IN FIRE WALLS DUE TO DUCTWORK, PIPING, CONDUIT, ETC., SHALL BE FIRE STOPPED WITH A PRODUCT SIMILAR TO 3M OR APPROVED EQUAL.	
20. ALL CONDENSATE DRAIN LINES FROM EACH ROOF TOP UNIT SHALL BE PIPED FULL SIZE OF THE UNIT DRAIN OUTLET, WITH "P" TRAP, AND PIPED TO THE NEAREST DRAIN. SEE THE DETAILS SHOWN IN THE DRAWINGS OR THE CONTRACT SPECIFICATIONS FOR THE DEPTH OF THE AIR CONDITIONING CONDENSATE TRAP.	
21. REFER TO TYPICAL DETAILS FOR DUCTWORK, PIPING, AND EQUIPMENT INSTALLATION.	
22. ALL TESTS SHALL BE COMPLETED BEFORE ANY MECHANICAL EQUIPMENT OR PIPING INSULATION IS APPLIED.	
23. TESTING, ADJUSTING, AND BALANCING AGENCY SHALL BE A MEMBER OF THE ASSOCIATED AIR BALANCE COUNCIL (ABC) OR THE NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB). TESTING, ADJUSTING, AND BALANCING SHALL BE PERFORMED IN ACCORDANCE WITH THE ABC STANDARDS.	

HVAC DUCTWORK - SHEET METAL

- CERTAIN ITEMS SUCH AS RISES AND DROPS IN DUCTWORK, ACCESS DOORS, VOLUME DAMPERS, ETC. ARE INDICATED ON THE CONTRACT DOCUMENT DRAWINGS FOR CLARITY FOR A SPECIFIC LOCATION REQUIREMENT AND SHALL NOT BE INTERPRETED AS THE EXTENT OF THE REQUIREMENTS FOR THESE ITEMS.
- CONTRACTOR TO CHECK AND CORRECT ANY AND ALL DEFICIENCIES IN EXISTING DUCTS. ALL NEW DUCTWORK WILL COMPLY WITH THE LATEST SMACNA GUIDELINES AND CONFORM WITH REQUIREMENTS OF THE LATEST HANDBOOKS PUBLISHED BY ASHRAE.
- PROVIDE VOLUME DAMPER AT EACH TAP TO MAIN DUCT AND WHERE NECESSARY TO PROPERLY BALANCE SYSTEM.
- SUPPLY AND RETURN DUCTWORK 20' FROM ALL HVAC UNITS SHALL BE LINED WITH 1.5" ACOUSTICAL LINING.
- RE-INSULATE ALL DUCTWORK AND PIPING IN WHICH INSULATION HAS BEEN REMOVED OR DAMAGED WITH INSULATION EQUAL TO THE EXISTING INSULATION.
- CONTRACTOR SHALL SUPPLY AND INSTALL ALL NECESSARY SUPPLY DIFFUSERS AND RETURN AIR REGISTERS WHERE INDICATED ON THE DRAWING. COORDINATE LOCATION OF DIFFUSERS AND REGISTERS WITH REFLECTED CEILING PLAN.
- IN CORRIDORS WHERE CEILING SPEAKERS AND AIR DIFFUSERS ARE INDICATED BETWEEN THE SAME LIGHT FIXTURES, INSTALL BOTH DEVICES AT THE QUARTER POINTS BETWEEN THE FIXTURES.
- UNLESS OTHERWISE SHOWN, LOCATE ALL ROOM THERMOSTATS 4'-0" (CENTER LINE) ABOVE THE FINISHED FLOOR. NOTIFY THE ENGINEER OF ANY ROOMS WHERE THE PRECEDING LOCATION CANNOT BE MAINTAINED OR WHERE THERE IS A QUESTION ON LOCATION.
- ALL DUCTWORK SHALL CLEAR DOORS AND WINDOWS.
- ALL DUCTWORK DIMENSIONS, AS SHOWN ON THE DRAWINGS, ARE INTERNAL CLEAR DIMENSIONS AND DUCT SIZE SHALL BE INCREASED TO COMPENSATE FOR DUCT LINING THICKNESS.
- PROVIDE ALL 90-DEGREE SQUARE ELBOWS WITH DOUBLE RADIUS TURNING VANES UNLESS OTHERWISE INDICATED. ELBOWS IN DISHWASHER, KITCHEN, AND LAUNDRY EXHAUSTS SHALL BE OF UN-VANED SMOOTH RADIUS CONSTRUCTION WITH A RADIUS EQUAL TO 1-1/2 TIMES THE WIDTH OF THE DUCT. PROVIDE ACCESS DOORS UPSTREAM OF ALL ELBOWS WITH TURNING VANES.
- COORDINATE DIFFUSER, REGISTER, AND GRILL LOCATIONS WITH ARCHITECTURAL REFLECTED CEILING PLANS, LIGHTING, AND OTHER CEILING ITEMS AND MAKE MINOR DUCT MODIFICATIONS TO SUIT.
- ALL AIR HANDLING UNITS SHALL OPERATE WITHOUT MOISTURE CARRYOVER.
- LOCATE ALL MECHANICAL EQUIPMENT FOR UNOBSTRUCTED ACCESS TO UNIT ACCESS PANELS, CONTROLS, AND VALVING.
- PROVIDE FLEXIBLE CONNECTIONS IN ALL DUCTWORK SYSTEMS (SUPPLY, RETURN, AND EXHAUST) CONNECTED TO AIR HANDLING UNITS, FANS, AND OTHER EQUIPMENT THAT REQUIRE VIBRATION ISOLATION. FLEXIBLE CONNECTIONS SHALL BE PROVIDED AT THE POINT OF CONNECTION TO THE EQUIPMENT UNLESS OTHERWISE INDICATED.
- UNLESS OTHERWISE NOTED, ALL DUCTWORK IS OVERHEAD, TIGHT TO THE UNDERSIDE OF THE STRUCTURE, WITH SPACE FOR INSULATION IF NEEDED.
- RUNS OF FLEXIBLE DUCT SHALL NOT EXCEED 5 FT.
- ALL DUCTWORK SHALL BE COORDINATED WITH ALL TRADES INVOLVED, OFFSETS IN DUCTS, INCLUDING DIVIDED DUCTS AND TRANSITIONS AROUND OBSTRUCTIONS, SHALL BE PROVIDED AT NO ADDITIONAL COST TO THE OWNER.
- PROVIDE ACCESS DOORS IN DUCTWORK TO PROVIDE ACCESS FOR ALL SMOKE DETECTORS, FIRE DAMPERS, SMOKE DAMPERS, VOLUME DAMPERS, COILS, AND OTHER ITEMS LOCATED IN THE DUCTWORK THAT REQUIRE SERVICE AND/OR INSPECTION.
- PROVIDE ACCESS DOORS IN DUCTWORK FOR THE OPERATION, ADJUSTMENT, AND MAINTENANCE OF ALL FANS, VALVES, AND MECHANICAL EQUIPMENT.
- ALL DUCTS SHALL BE GROUNDED ACROSS FLEXIBLE CONNECTIONS WITH FLEXIBLE COPPER GROUNDING STRAPS. GROUNDING STRAPS SHALL BE BOLTED OR SOLDERED TO BOTH THE EQUIPMENT AND THE DUCT.
- SMOKE DETECTORS SHALL BE FURNISHED AND WIRED BY THE ELECTRICAL CONTRACTOR. THE MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR MOUNTING THE SMOKE DETECTOR IN DUCTWORK AS SHOWN ON THE DRAWINGS AND IN ACCORDANCE WITH THE MANUFACTURER'S PRINTED INSTRUCTIONS.
- SEE SPECIFICATIONS FOR DUCTWORK GAUGES, BRACING, HANGERS, AND OTHER REQUIREMENTS.
- ALL CONDENSATE DRAIN LINES FROM EACH ROOF TOP UNIT SHALL BE PIPED FULL SIZE OF THE UNIT DRAIN OUTLET, WITH "P" TRAP, AND PIPED TO THE NEAREST DRAIN. SEE THE DETAILS SHOWN IN THE DRAWINGS OR THE CONTRACT SPECIFICATIONS FOR THE DEPTH OF THE AIR CONDITIONING CONDENSATE TRAP.
- REFER TO TYPICAL DETAILS FOR DUCTWORK, PIPING, AND EQUIPMENT INSTALLATION.
- ALL TESTS SHALL BE COMPLETED BEFORE ANY MECHANICAL EQUIPMENT OR PIPING INSULATION IS APPLIED.
- TESTING, ADJUSTING, AND BALANCING AGENCY SHALL BE A MEMBER OF THE ASSOCIATED AIR BALANCE COUNCIL (ABC) OR THE NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB). TESTING, ADJUSTING, AND BALANCING SHALL BE PERFORMED IN ACCORDANCE WITH THE ABC STANDARDS.

SPECIFICATIONS**SECTION 0001 - NOTICE TO BIDDERS****1.1 BIDDERS REPRESENTATIONS**

- THE BIDDER BY MAKING A BID REPRESENTS THAT: THE BIDDER HAS READ AND UNDERSTANDS THE BIDDING DOCUMENTS, TO THE EXTENT THAT SUCH DOCUMENTATION RELATES TO THE WORK FOR WHICH THE BID IS SUBMITTED, AND FOR OTHER PORTIONS OF THE PROJECT, IF ANY, BEING BID CONCURRENTLY OR PRESENTLY UNDER CONSTRUCTION.
- THE BID IS MADE IN COMPLIANCE WITH THE BIDDING DOCUMENTS.
- THE SPECIFICATIONS AND DRAWINGS ARE INTENDED TO SERVE JOINTLY AS A BASIS FOR THE BIDDER TO SUBMIT A CONTRACT PRICE FOR THE MATERIAL AND LABOR.
- SHOULD CONFLICTS OR DISCREPANCIES OCCUR WITHIN THE BIDDING DOCUMENTS, THE ITEM OR ITEMS IN DISPUTE THAT REPRESENT THE GREATER COST SHALL PREVAIL IN THE FINAL BID.
- THE BID IS BASED UPON THE MATERIALS, EQUIPMENT AND SYSTEMS REQUIRED BY THE BIDDING DOCUMENTS WITHOUT EXCEPTION.

1.2 EXISTING CONDITIONS AND COORDINATION

- THE BIDDER HAS VISITED THE SITE, BECOME FAMILIAR WITH LOCAL CONDITIONS UNDER WHICH THE WORK IS TO BE PERFORMED AND HAS CORRELATED THE BIDDER'S PERSONAL OBSERVATIONS WITH THE REQUIREMENTS OF THE PROPOSED BIDDING DOCUMENTS.
- THE BIDDER SHALL PROPOSE COORDINATION OF WORK SUCH THAT CONFLICTS WITH OTHER TRADES AND SPACE ALLOCATIONS ARE AVOIDED.

1.3 RESPONSIBILITIES

- THE BIDDER UNDERSTANDS THAT ANY CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR THE TIMELY COMPLETION AND ACCEPTANCE OF THEIR WORK AND THAT ANY ITEMS DAMAGED, LOST OR STOLEN DURING TIME OF CONSTRUCTION SHALL BE REPAIRED OR REPLACED WITHOUT ANY ADDITIONAL COST TO THE OWNER.
- THE BIDDER UNDERSTANDS THAT ANY PROPOSED WORK IN OCCUPIED TENANT SPACES SHALL BE PERFORMED DURING TIMES OF NON-TENANT OCCUPANCY OR AS SCHEDULED OR DIRECTED BY THE BUILDING MANAGER.
- THE BIDDER UNDERSTANDS THAT ANY PROPOSED SHUT-DOWN OF EXISTING SYSTEMS DURING CONSTRUCTION SHALL BE PRE-ARRANGED WITH THE BUILDING MANAGER AND THAT SUCH SHUT-DOWNS ARE TO BE KEPT TO A MINIMUM.

END OF SECTION 0001

SECTION 0101 - QUALITY OF WORK**1.1 WORKMANSHIP**

- ALL WORK SHALL BE FREE FROM DEFECTS IN MATERIALS AND WORKMANSHIP FOR A PERIOD OF ONE YEAR FROM DATE OF FINAL ACCEPTANCE.
- ALL DEFECTS WHICH DEVELOP OR ARE DISCOVERED WITHIN THIS PERIOD SHALL BE REPAIRED BY THE CONTRACTOR TO THE SATISFACTION OF THE ARCHITECT OR BUILDING MANAGER AT NO ADDITIONAL COST TO THE OWNER.
- UPON COMPLETION OF THE WORK THE CONTRACTOR SHALL REMOVE FROM THE SITE ALL TOOLS, DEMOLISHED APPLIANCES AND ANY SURPLUS MATERIAL.

1.2 CODE COMPLIANCE

- ALL WORK SHALL MEET ALL STATE AND LOCAL CODES HAVING JURISDICTION.

END OF SECTION 0101

SECTION 0102 - REQUIRED DOCUMENTS**1.1 SHOP DRAWINGS**

- A SET OF PRINTS FOR ANY MECHANICAL WORK INCLUDING BUT NOT LIMITED TO, DUCTWORK AND PIPING LAYOUT SHALL BE SUBMITTED FOR APPROVAL TO THE ENGINEER PRIOR TO CONSTRUCTION OR PURCHASE OF MATERIALS.

1.2 SUBMITTALS

- EQUIPMENT SUBMITTALS OF ALL PROPOSED MECHANICAL AND AUXILIARY EQUIPMENT INCLUDING ALL ACCESSORIES SHALL BE SUBMITTED TO THE ENGINEER FOR REVIEW. ALL PERTINENT MODELS, SIZES, ACCESSORIES AND CHOICES SHALL BE CLEARLY CHECKED, PRINTED OR OTHERWISE INDICATED ON THE SUBMITTALS.

1.3 RECORD DRAWINGS

- UPON COMPLETION OF THE WORK, A RECORD DRAWING SHALL BE SUBMITTED TO THE OWNER DEPICTING ALL SUBSEQUENT CHANGES, ADDITIONS AND OR CORRECTIONS TO THE CONTRACT DRAWINGS AND OR CONTRACT SCOPE MADE DURING CONSTRUCTION. THIS DRAWING SHALL REPRESENT A COMPLETE RECORD OF THE WORK INSTALLED.

1.4 EQUIPMENT OPERATING INSTRUCTIONS

- ON COMPLETION AND ACCEPTANCE OF WORK, THIS CONTRACTOR SHALL FURNISH WRITTEN INSTRUCTIONS, EQUIPMENT MANUALS AND DEMONSTRATE TO THE OWNER THE PROPER OPERATION AND MAINTENANCE OF ALL EQUIPMENT AND APPARATUS FURNISHED UNDER THIS CONTRACT.
- THESE INSTRUCTIONS SHALL BE TYPED ON 8-1/2 IN. X 11 IN. PAPER AND BOUND IN THREE-RING BINDERS WITH CLEAR ACETATE COVERS. THE CONTRACTOR SHALL GIVE THREE COPIES OF THE INSTRUCTIONS TO THE OWNER AND ONE ELECTRONIC COPY TO THE ENGINEER.
- THE INSTRUCTION BOOKLET SHALL BE ORGANIZED IN SECTIONS, WITH ONE SECTION PER SYSTEM. THE COVER OF THE INSTRUCTION BOOKLET SHALL BEAR THE NAME, ADDRESS AND PHONE NUMBER OF THE PROJECT, ARCHITECT, ENGINEER, MECHANICAL CONTRACTOR AND SUBCONTRACTORS.

END OF SECTION 0102

SECTION 230517 - SLEEVES AND SLEEVE SEALS FOR HVAC PIPING**1.1 SLEEVE-SEAL SYSTEMS**

- FIELD-ASSEMBLED, MODULAR SEALING-ELEMENT UNIT FOR FILLING ANNUAL SPACE BETWEEN PIPING AND SLEEVE.
- SEALING ELEMENTS: EPDM RUBBER OR NBR.
- PRESSURE PLATES: CARBON STEEL, PLASTIC, STAINLESS STEEL.
- CONNECTING BOLTS AND NUTS: CARBON STEEL WITH CORROSION-RESISTANT COATING, STAINLESS STEEL.
- MANUFACTURERS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, AVAILABLE MANUFACTURERS OFFERING PRODUCTS THAT MAY BE INCORPORATED INTO THE WORK INCLUDE, BUT ARE NOT LIMITED TO, THE FOLLOWING:

- ADVANCE PRODUCTS & SYSTEMS, INC.
- CALPICO, INC.
- METRAFLEX COMPANY (THE).
- Pipeline Seal and Insulator, Inc.
- PROCO PRODUCTS, INC.

END OF SECTION 230529

SECTION 230548 - VIBRATION CONTROLS FOR HVAC PIPING AND EQUIPMENT**PART 1 - GENERAL****1.1 COMPONENTS**

- VIBRATION ISOLATORS:
 - 1. ISOLATOR PADS: NEOPRENE, RUBBER, HERMETICALLY AND/OR SEALED COMPRESSED FIBERGLASS
 - 2. MOUNTS: DOUBLE-DEFLECTION TYPE.
 - 3. RESTRAINED MOUNTS: ALL DIRECTIONAL MOUNTINGS WITH SEISMIC RESTRAINT; CAST-DUCTILE-IRON HOUSING.
 - 4. SPRING ISOLATORS: FREESTANDING, LATERALLY STABLE, OPEN-SPRING TYPE.
 - 5. RESTRAINED SPRING ISOLATORS: FREESTANDING, STEEL, OPEN-SPRING TYPE WITH SEISMIC RESTRAINT.
 - 6. HOUSED SPRING MOUNTS: DUCTILE-IRON OR STEEL HOUSING, WITH INTEGRAL, VERTICALLY ADJUSTABLE SEISMIC SNUBBERS.
 - 7. ELASTOMERIC HANGERS: DOUBLE-DEFLECTION TYPE.
 - 8. SPRING HANGERS: COMBINATION COIL-SPRING AND ELASTOMERIC-INSERT HANGERS WITH SPRING AND INSERT IN COMPRESSION.
 - 9. SPRING HANGERS WITH VERTICAL-LIMIT STOP: COMBINATION COIL-SPRING AND ELASTOMERIC-INSERT HANGERS WITH SPRING AND INSERT IN COMPRESSION AND WITH VERTICAL-LIMIT STOP.

END OF SECTION 230517

SECTION 230518 - ESCUTCHEONS FOR HVAC PIPING**PART 2 - PRODUCTS**

1. ESCUTCHEONS
 - A. ONE-PIECE, CAST-BRASS TYPE: WITH POLISHED, CHROME-PLATED AND ROUGH-BRASS FINISH AND SETSCREW FASTENER.
 - B. ONE-PIECE, DEEP-PATTERN TYPE: DEEP-DRAWN, BOX-SHAPED BRASS WITH CHROME-PLATED FINISH AND SPRING-CLIP FASTENERS.
 - C. ONE-PIECE, STAMPED-STEEL TYPE: WITH CHROME-PLATED FINISH AND SPRING-CLIP FASTENERS.
2. FLOOR PLATES
 - A. ONE-PIECE FLOOR PLATES: CAST-IRON FLANGE WITH HOLES FOR FASTENERS.

PART 3 - EXECUTION**3.1 INSTALLATION**

- INSTALL ESCUTCHEONS FOR PIPING PENETRATIONS OF WALLS, CEILINGS, AND FINISHED FLOORS.
- INSTALL ESCUTCHEONS WITH ID TO CLOSELY FIT AROUND PIPE, TUBE, AND INSULATION OF PIPING AND WITH OD THAT COMPLETELY COVERS OPENING.

1. ESCUTCHEONS FOR NEW PIPING:

- PIPING WITH FITTING OR SLEEVE PROTRUDING FROM WALL: ONE-PIECE, DEEP-PATTERN TYPE.
- INSULATED PIPING: ONE-PIECE, STAMPED-STEEL TYPE.
- BARE PIPING AT WALL AND FLOOR PENETRATIONS IN FINISHED SPACES: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED FINISH OR STAMPED-STEEL TYPE.
- BARE PIPING AT CEILING PENETRATIONS IN FINISHED SPACES: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED FINISH OR STAMPED-STEEL TYPE.

1.2 FIELD QUALITY CONTROL**A. TESTING:** BY EITHER: OWNER-ENGAGED AGENCY, CONTRACTOR-ENGAGED AGENCY, OR CONTRACTOR.**PART-2 PRODUCTS****1.1 VIBRATION ISOLATORS & SEISMIC-RESTRAINT DEVICES**

- AVAILABLE MANUFACTURERS: SUBJECT TO COMPLIANCE WITH REQUIRE

1. AIR SYSTEMS: CONSTANT VOLUME.

1.2 QUALITY ASSURANCE

A. THE CONTRACTOR SHALL PROCUCE THE SERVICES OF A TESTING, ADJUSTING AND BALANCING (TAB) SPECIALIST WHO SPECIALIZES IN HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS. THE TAB AGENT SHALL HAVE THE FOLLOWING QUALIFICATIONS: AABC, NEBB OR TABB CERTIFIED.

1.3 EXECUTION

A. THE TAB SPECIALIST SHALL PERFORM FLOW MEASUREMENTS OF ALL EXISTING AIR AND HYDRONIC SYSTEMS THAT ARE TO REMAIN OR TO BE INCORPORATED INTO NEW WORK PRIOR TO THE STARTING OF WORK IN THE PROJECT SCOPE. A REPORT OF THESE MEASUREMENTS, INDICATING ANY AND ALL DEFICIENCIES SHALL BE SUBMITTED FOR OWNER REVIEW.

B. THE TAB SPECIALIST SHALL PERFORM FLOW MEASUREMENTS OF ALL NEW AIR AND HYDRONIC SYSTEMS AS LISTED ABOVE IN THE PROJECT SCOPE. A REPORT OF THESE MEASUREMENTS, INDICATING ANY AND ALL DEFICIENCIES SHALL BE SUBMITTED FOR OWNER REVIEW.

C. THE REPORT SHALL INDICATE A SCHEMATIC DIAGRAM INDICATING LOCATIONS OF ALL EQUIPMENT TESTED AND MEASUREMENT LOCATIONS.

D. PRIOR TO FINAL INSPECTION OF THE WORK, THE TAB SPECIALIST SHALL BALANCE ALL SYSTEMS AS INDICATED ABOVE TO THE REQUIREMENTS OF THE DESIGN.

E. THE CONTRACTOR SHALL HAVE FURNISH AND INSTALL ALL ADDITIONAL BALANCING EQUIPMENT, PRESSURE TAPS, GAUGES AND OTHER EQUIPMENT AS REQUIRED FOR A PROPERLY BALANCED SYSTEM AT NO ADDITIONAL COST TO THE OWNER. SUCH ADDITIONAL EQUIPMENT SHALL ADHERE IN STRICT ACCORDANCE WITH THE RESPECTIVE EQUIPMENT MANUFACTURER'S RECOMMENDATIONS.

F. THE CONTRACTOR SHALL HAVE THE TESTING AND BALANCING SPECIALIST COORDINATE ALL WORK OF THIS SECTION WITH THE BUILDING MANAGER. BALANCING WORK SHALL NOT CONFLICT WITH OTHER WORK SO AS TO MAINTAIN COMPLETION WITHIN THE SPECIFIED TIME.

G. ALL INSTRUMENTS USED FOR TAB SHALL BE MAINTAINED IN GOOD WORKING CONDITION AND ACCURATELY CALIBRATED.

H. TOLERANCES: PLUS OR MINUS 5 PERCENT OF DESIGN VALUES.

I. INSPECTIONS: RANDOM CHECKS BY OWNER OR ARCHITECT TO VERIFY FINAL TESTING, ADJUSTING, AND BALANCING REPORT.

J. ADDITIONAL TESTS: RANDOM TESTS WITHIN 90 DAYS OF COMPLETING TAB TO VERIFY BALANCE CONDITIONS AND SEASONAL TESTS.

END OF SECTION 230593

SECTION 230713 - DUCT INSULATION

1.1 QUALITY ASSURANCE

SURFACE-BURNING CHARACTERISTICS: ALL INSULATION SHALL HAVE COMPOSITE (INSULATION JACKET OR FACING AND ADHESIVE USED TO ADHERE THE FACING OR JACKET TO THE INSULATION) A FLAME-SPREAD INDEX OF 25, AND SMOKE-DEVELOPED INDEX OF 50 FOR INSULATION INSTALLED INDOOR, 75 AND SMOKE-DEVELOPED INDEX OF 150 FOR INSULATION INSTALLED OUTDOORS; ACCORDING TO ASTM 84.

1.2 FIELD QUALITY CONTROL

A. FIELD INSPECTIONS: BY OWNER-ENGAGED AGENCY.

1.3 INDOOR DUCT AND PLENUM INSULATION SCHEDULE;

A. CONCEALED, RECTANGULAR, ROUND AND FLAT-oval, SUPPLY-RETURN, OUTDOOR-AND EXHAUST-AIR DUCT AND AIR PLENUM INSULATION:

B. FLEXIBLE ELASTOMERIC, MINERAL-FIBER BLANKET, MINERAL-FIBER BOARD OR POLYOLEFIN WITH MINIMUM INSTALLED THERMAL RESISTANCE AS FOLLOWS: UNCONDITIONED SPACES WITHIN BUILDING: R-6 WITHIN BUILDING ENVELOPE ASSEMBLY: R-6 OUTSIDE OF BUILDING: R-8

1.4 ITEMS NOT INSULATED:

1. FIBROUS-GLASS DUCTS.
2. METAL DUCTS WITH DUCT LINER OR SUFFICIENT THICKNESS TO COMPLY WITH ENERGY CODE ANDASHRAE/IESNA 90.1.
3. FACTORY-INSULATED FLEXIBLE DUCTS.
4. FACTORY-INSULATED PLENUMS AND CASINGS.
5. FLEXIBLE CONNECTORS.
6. VIBRATION-CONTROL DEVICES.
7. FACTORY-INSULATED ACCESS PANELS AND DOORS.
8. DUCTS THAT HAVE INTERNAL ACOUSTICAL LINING.

1.5 PRODUCTS

A. THE FOLLOWING INSULATION MANUFACTURERS WILL BE ACCEPTABLE:
1. JOHNS-MANVILLE
2. OWENS-CORNING

1.6 ACOUSTICAL TREATMENT

1. WHERE SHOWN ON THE DRAWINGS, LOW PRESSURE DUCTWORK SHALL BE LINED WITH 1.5" THICK R-6 AS MANUFACTURED BY DUCTMATE, 1-1/2 POUND MINIMUM DENSITY, NEOPRENE COATED, FLEXIBLE FIBERGLASS DUCT LINER. LINING SHALL COMPLY WITH NFPA 90A AND SHALL HAVE A FLAME SPREAD CLASSIFICATION OF NOT MORE THAN 25 AND A SMOKE DEVELOPED RATING NOT MORE THAN 50. DUCT SIZES WHERE LINING IS INDICATED ON PLANS ARE MINIMUM INSIDE CLEAR DIMENSIONS REQUIRED.

END OF SECTION 230713

SECTION 233113 - METAL DUCTS

A. 1. CONSTRUCTION
A. EACH DUCT SYSTEM SHALL BE CONSTRUCTED FOR THE SPECIFIC SMACNA DUCT PRESSURE CLASSIFICATIONS SHOWN ON THE CONTRACT DRAWINGS. WHERE NO PRESSURE CLASSES ARE SPECIFIED BY THE DESIGNER, THE SMACNA 1 INCH WG PRESSURE, SEAL CLASS "A".

B. ALL DUCTWORK SHALL BE CONSTRUCTED TO SMACNA 1" WG DESIGN AND NOT LESS THAN THE FOLLOWING STANDARDS:
1. CONSTRUCT SO THAT ALL INTERIOR SURFACES ARE SMOOTH. USE SPLIT AND DRIVE OR FLANGED AND BOLTED CONSTRUCTION WHEN FABRICATING RECTANGULAR DUCTWORK. USE SPIRAL LOCK SEAM CONSTRUCTION WHEN FABRICATING ROUND, SPIRAL DUCTWORK. SHEET METAL SCREWS MAY BE USED ON DUCT HANGERS, TRANSVERSE JOINTS AND OTHER SMACNA APPROVED LOCATIONS IF THE SCREW DOES NOT EXTEND MORE THAN 1/2 INCH INTO THE DUCT.

2. SHEET STEEL SHALL COMPLY WITH ASTMA653 STANDARD SPECIFICATION FOR STEEL SHEET METAL, ZINC COATED (GALVANIZED) OR ZINC IRON ALLOY-COATED (GALVANIZED) BY HOT DIP PROCESS, AND A924 STANDARD SPECIFICATION FOR GENERAL REQUIREMENT FOR SHEET METAL-COATED BY HOT DIP PROCESS. ALUMINUM IRON IS PERMITTED FOR SUPPORTS SHALL BE GALVANIZED. CONNECTIONS TO WALLS OR FLOOR SHALL BE AIR TIGHT WITH ANGLE IRON AND CAULKING. SEAL ALL DUCT SEAMS, TRANSVERSE AND LONGITUDINAL, AIR TIGHT. PROVIDE TURNING VANES ALL 90° ELB

3. USE ELBOWS AND TEES WITH A CENTER LINE RADIUS TO WIDTH OR DIAMETER RATIO OF 1.5, WHEREVER SPACE PERMITS. WHEN A SHORTER RADIUS MUST BE USED DUE TO LIMITED SPACE, INSTALL SINGLE WALL SHEET METAL SPANNER VANES IN ACCORDANCE WITH SMACNA PUBLICATIONS, TYPE RE-3. WHERE SPACE WILL NOT ALLOW AND THE VALUE OF THE RADIAL ELBOW AS SHOWN IN SMACNA PUBLICATIONS EXCEEDS 0.3, USE RECTANGULAR ELBOWS WITH TURNING VANES AS SPECIFIED IN SECTION 23-33-00. SQUARE THROAT-RADIUS HEEL ELBOWS WILL NOT BE ACCEPTABLE. STRAIGHT TAPS OR BULLHEAD TEES ARE NOT ACCEPTABLE.

4. WHERE RECTANGULAR ELBOWS ARE USED, PROVIDE TURNING VANES IN ACCORDANCE WITH SECTION 23-33-00.

5. PROVIDE EXPANDED TAKE-OFFS OR 45 DEGREE ENTRY FITTINGS FOR BRANCH DUCT CONNECTIONS WITH BRANCH DUCTWORK AIRFLOW VELOCITIES GREATER THAN 700 FPM. SQUARE EDGE 90-DEGREE TAKE-OFF FITTINGS OR STRAIGHT TAPS WILL NOT BE ACCEPTED.

6. BUTTON PUNCH SNAP-LOCK CONSTRUCTION WILL NOT BE ACCEPTED ON ALUMINUM DUCTWORK.

7. ROUND DUCTS MAY BE SUBSTITUTED FOR RECTANGULAR DUCTS IF SIZED IN ACCORDANCE WITH ASHRAE TABLE OF EQUIVALENT RECTANGULAR AND ROUND DUCTS. NO VARIATION OF DUCT CONFIGURATION OR SIZES PERMITTED EXCEPT BY WRITTEN PERMISSION OF THE ENGINEER.

END OF SECTION 233113

SECTION 233713 - DIFFUSERS AND GRILLES

A. 1. PRODUCTS
A. DIFFUSERS AND GRILLES SHALL BE FURNISHED AND INSTALLED FOR CAPACITIES AND IN LOCATIONS INDICATED ON DRAWINGS. ALL REGISTERS AND DIFFUSERS SHALL BE PRIME COATED STEEL OR EXTRUDED ALUMINUM FINISHED UNLESS OTHERWISE NOTED IN BAKED WHITE ENAMEL.

B. MANUFACTURERS: TITUS
1. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCT BY ONE OF THE FOLLOWING:

a. CARNES.
b. HART & COOLEY INC.
c. KRUEGER.
d. METALAIER, INC.
e. NAILOR INDUSTRIES INC.

END OF SECTION 233713

A. WHERE LATEST EDITION OF SMACNA DOES NOT CLEARLY STATE GAUGES AND/OR STIFFENERS TO BE USED OR, WHERE SMACNA STANDARDS REQUIRE INTERPRETATION, THE FOLLOWING MINIMUM METAL GAUGES AND BRACING SHALL BE USED:

USG	MAX. SIDE INCHES	TRANSVERSE JOINTS AND BRACING
22	UP TO 12	S SLIP, DRIVE SLIP, ONE INCH POCKET LOCK ON 8 FOOT CENTERS
22	13 TO 24	1"X1"X1/8" ANGLES ON 4 FOOT CENTERS
20	25 TO 35	1"X1"X1/8" ANGLES ON 2 FOOT CENTERS

B. PROVIDE TAPPING IN DUCTS FOR THERMOMETERS WHERE SPECIFIED. IN ADDITION, PROVIDE AN AIRTIGHT PLUGGED TAPPING LOCATED AS FOLLOWS:

1. UPSTREAM OF EACH REHEAT COIL AND VAV BOX.
2. DOWNSTREAM OF EACH REHEAT COIL AND VAV BOX.

C. FLAT OVAL OR ROUND DUCTWORK MAY BE PROVIDED IN LIEU OF RECTANGULAR DUCTWORK WITH THE REINFORCEMENT FOR FLAT SIDES SAME AS SPECIFIED FOR THE RECTANGULAR DUCTWORK, AND AS PER SMACNA FLAT OVAL DUCT CONSTRUCTION STANDARDS SHOWN IN FIG. 3-6 AND AS SHOWN IN FIG. 3-1 AND 3-2 FOR ROUND DUCTWORK.

D. ALL DUCTWORK SHALL BE SEALED TO CLASS "A" AND LEAK TESTED TO MEAT SMACNA CLASS 6 FOR RECTANGULAR AND CLASS 3 FOR ROUND DUCTS.

1.2 MATERIALS
A. SINGLE-WALL RECTANGULAR DUCTS AND FITTINGS.
B. SINGLE-WALL ROUND AND FLAT-oval DUCTS AND FITTINGS.

C. SHEET METAL MATERIALS:
1. GALVANIZED SHEET STEEL.
2. STAINLESS-STEEL SHEETS.
3. ALUMINUM SHEETS.

4. FACTORY-APPLIED ANTI-MICROBIAL COATING.

D. DUCT LINER:
1. FIBROUS GLASS, TYPE I, FLEXIBLE.
a. WITH ANTI-MICROBIAL EROSION-RESISTANT COATING.

2. FLEXIBLE ELASTOMERIC.
3. NATURAL FIBER.

E. SEALANT MATERIALS:
1. TWO-PART TAPE SEALING SYSTEM.
2. WATER-BASED JOINT AND SEAM SEALANT.

3. SOLVENT-BASED JOINT AND SEAM SEALANT.
4. FLANGED JOINT SEALANT.
5. FLANGE GASKETS.

6. ROUND DUCT JOINT O-RING SEALS.

1.3 DUCT CLEANING

THERMOSTATIC CONTROL NOTES:

C403.2.4.1 THERMOSTATIC CONTROLS

THE SUPPLY OF HEATING AND COOLING ENERGY TO EACH ZONE SHALL BE CONTROLLED BY INDIVIDUAL THERMOSTATIC CONTROLS CAPABLE OF RESPONDING TO TEMPERATURE WITHIN THE ZONE. WHERE HUMIDIFICATION OR DEHUMIDIFICATION OR BOTH IS PROVIDED, NOT FEWER THAN ONE HUMIDITY CONTROL DEVICE SHALL BE PROVIDED FOR EACH HUMIDITY CONTROL SYSTEM. EXCEPTION: INDEPENDENT PERIMETER SYSTEMS THAT ARE DESIGNED TO OFFSET THE BUILDING ENVELOPE HEAT LOSSES, GAINS OR BOTH SERVING ONE OR MORE PERIMETER ZONES ALSO SERVED BY AN INTERIOR SYSTEM PROVIDED THAT BOTH OF THE FOLLOWING CONDITIONS ARE MET:

1. THE PERIMETER SYSTEM INCLUDES NOT FEWER THAN ONE THERMOSTATIC CONTROL ZONE FOR EACH BUILDING EXPOSURE HAVING EXTERIOR WALLS FACING ONLY ONE ORIENTATION (WITHIN ± 45 DEGREES) (0.8 RAD) FOR MORE THAN 50 CONTIGUOUS FEET (15.240 MM).
2. THE PERIMETER SYSTEM HEATING AND COOLING SUPPLY IS CONTROLLED BY THERMOSTATS LOCATED WITHIN THE ZONES SERVED BY THE SYSTEM.

C403.2.4.1.1 HEAT PUMP SUPPLEMENTARY HEAT

HEAT PUMPS HAVING SUPPLEMENTARY ELECTRIC RESISTANCE HEAT SHALL HAVE CONTROLS THAT LIMIT SUPPLEMENTAL HEAT OPERATION TO ONLY THOSE TIMES WHEN:

1. THE VAPOR COMPRESSION CYCLE CANNOT PROVIDE THE NECESSARY HEATING ENERGY TO SATISFY THE THERMOSTAT SETTING.
2. THE HEAT PUMP IS OPERATING IN DEFREST MODE.
3. THE VAPOR COMPRESSION CYCLE MalfUNCTIONS, OR
4. THE THERMOSTAT MalfUNCTIONS.

C403.2.4.1.2 DEADBAND

WHERE USED TO CONTROL BOTH HEATING AND COOLING, ZONE THERMOSTATIC CONTROLS SHALL BE CONFIGURED TO PROVIDE A TEMPERATURE RANGE OR DEADBAND OF NOT LESS THAN 5°F (2.8°C) WITHIN WHICH THE SUPPLY OF HEATING AND COOLING ENERGY TO THE ZONE IS SHUT OFF OR REDUCED TO A MINIMUM.

EXCEPTIONS:

1. THERMOSTATS REQUIRING MANUAL CHANGEOVER BETWEEN HEATING AND COOLING MODES.
2. OCCUPANCIES OR APPLICATIONS REQUIRING PRECISION IN INDOOR TEMPERATURE CONTROL AS APPROVED BY THE CODE OFFICIAL.

C403.2.4.1.3 SETPOINT OVERLAP RESTRICTION

WHERE A ZONE HAS A SEPARATE HEATING AND A SEPARATE COOLING THERMOSTATIC CONTROL LOCATED WITHIN THE ZONE, A LIMIT SWITCH, MECHANICAL STOP OR DIRECT DIGITAL CONTROL SYSTEM WITH SOFTWARE PROGRAMMING SHALL BE CONFIGURED TO PREVENT THE HEATING SETPOINT FROM EXCEEDING THE COOLING SETPOINT AND TO MAINTAIN A DEADBAND IN ACCORDANCE WITH SECTION C403.2.4.1.2.

C403.2.4.2 OFF-HOUR CONTROLS

EACH ZONE SHALL BE PROVIDED WITH THERMOSTATIC SETBACK CONTROLS THAT ARE CONTROLLED BY EITHER AN AUTOMATIC TIME CLOCK OR PROGRAMMABLE CONTROL SYSTEM.

EXCEPTIONS:

1. ZONES THAT WILL BE OPERATED CONTINUOUSLY.
2. ZONES WITH A FULL HVAC LOAD DEMAND NOT EXCEEDING 6,800 BTU/H (2 KW) AND HAVING A MANUAL SHUTOFF SWITCH LOCATED WITH READY ACCESS.

C403.2.4.2.1 THERMOSTATIC SETBACK

THERMOSTATIC SETBACK CONTROLS SHALL BE CONFIGURED TO SET BACK OR TEMPORARILY OPERATE THE SYSTEM TO MAINTAIN ZONE TEMPERATURES DOWN TO 55°F (13°C) OR UP TO 85°F (29°C).

C403.2.4.2.2 AUTOMATIC SETBACK AND SHUTDOWN

AUTOMATIC TIME CLOCK OR PROGRAMMABLE CONTROLS SHALL BE CAPABLE OF STARTING AND STOPPING THE SYSTEM FOR SEVEN DIFFERENT DAILY SCHEDULES PER WEEK AND RETAINING THEIR PROGRAMMING AND TIME SETTING DURING A LOSS OF POWER FOR NOT FEWER THAN 10 HOURS. ADDITIONALLY, THE CONTROLS SHALL HAVE A MANUAL OVERRIDE THAT ALLOWS TEMPORARY OPERATION OF THE SYSTEM FOR UP TO 2 HOURS; A MANUALLY OPERATED TIMER CONFIGURED TO OPERATE THE SYSTEM FOR UP TO 2 HOURS; OR AN OCCUPANCY SENSOR.

C403.2.4.2.3 AUTOMATIC START & STOP

AUTOMATIC START AND STOP CONTROLS SHALL BE PROVIDED FOR EACH HVAC SYSTEM. THE AUTOMATIC START CONTROLS SHALL BE CONFIGURED TO AUTOMATICALLY ADJUST THE DAILY START TIME OF THE HVAC SYSTEM IN ORDER TO BRING EACH SPACE TO THE DESIRED OCCUPIED TEMPERATURE IMMEDIATELY PRIOR TO SCHEDULED OCCUPANCY. AUTOMATIC STOP CONTROLS SHALL BE PROVIDED FOR EACH HVAC SYSTEM WITH DIRECT DIGITAL CONTROL OF INDIVIDUAL ZONES. THE AUTOMATIC STOP CONTROLS SHALL BE CONFIGURED TO REDUCE THE HVAC SYSTEM'S HEATING TEMPERATURE SETPOINT AND INCREASE THE COOLING TEMPERATURE SETPOINT BY NOT LESS THAN 2°F (-16.6°C) BEFORE SCHEDULED UNOCCUPIED PERIODS BASED ON THE THERMAL LAG AND ACCEPTABLE DRIFT IN SPACE TEMPERATURE THAT IS WITHIN COMFORT LIMITS.

SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL


DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

MECHANICAL
SPECIFICATIONS
(2 OF 2)
M0.3



MECHANICAL FLOOR PLAN KEY NOTES:

- RELOCATE AND REUSE EXISTING THERMOSTATS AS SHOWN. IF EXISTING THERMOSTATS ARE NOT IN GOOD CONDITION, THEN INSTALL AND WIRE NEW 7-DAY PROGRAMMABLE THERMOSTATS. COORDINATE EXACT LOCATION WITH ARCHITECT AND OWNER PRIOR TO ROUGH-IN.
- EXISTING TEMPERATURE/HUMIDITY SENSORS (IF ANY) SHALL REMAIN AND SHALL BE REUSED. CONTRACTOR TO FIELD VERIFY EXACT LOCATION & WORKING CONDITION.
- INSTALL TYPE-I HOOD/TYPE-II GREASE EXHAUST HOOD. SUPPORT HOOD PER MANUFACTURER'S INSTALLATION INSTRUCTIONS. PROVIDE TRAPEZE HANGERS FOR ALL THREAD SUPPORT UNDER DUCTWORK AS REQUIRED. TRANSITION FROM HOOD CONNECTION TO WELDED KITCHEN EXHAUST DUCT SIZES SHOWN.
- 12"X12" EXHAUST DUCT FROM HOOD-3(N) UP THROUGH ROOF TO KEF-(N).
- 14"Ø GREASE DUCT TO BE PROVIDED WITH KITCHEN EQUIPMENT AND INSTALLED BY MECHANICAL CONTRACTOR. INSTALL PER MANUFACTURER'S INSTRUCTIONS.
- 10"Ø DUCT TO BE PROVIDED WITH KITCHEN EQUIPMENT AND INSTALLED BY MECHANICAL CONTRACTOR. INSTALL PER MANUFACTURER'S INSTRUCTIONS.
- CLEAN-OUT OPENINGS SHALL BE PROVIDED AT EVERY CHANCE IN DIRECTION WITHIN 10 FEET THAT ARE GREATER THAN 45 DEGREE. TIGHT-FITTING DOORS CONSTRUCTED OF STEEL HAVING A THICKNESS NOT LESS THAN THAT REQUIRED FOR THE DUCT. OPENING DOOR ASSEMBLIES SHALL HAVE A GASKET OR SEALANT THAT IS NONCOMBUSTIBLE AND LIQUID TIGHT, AND SHALL NOT HAVE FASTENERS THAT PENETRATE THE DUCT. THE OPENING DIMENSIONS SHALL BE 12X12 INCHES ON ACCESSIBLE SIDE OF DUCT. SPACING BETWEEN CLEAN OUT OPENING SHALL NOT BE MORE THAN 20 FEET. THE OPENING EDGES SHALL BE A MINIMUM OF 1 INCH (25 MM) FROM THE EDGES OF THE DUCT. WHERE LOCATED IN THE BOTTOM OF THE DUCT, CLEAN-OUT OPENINGS SHALL BE DESIGNED TO PROVIDE INTERNAL DAMMING AROUND THE OPENING, SHALL BE PROVIDED WITH GASKETING TO PRECLUDE GREASE LEAKAGE, SHALL PROVIDE FOR DRAINAGE OF GREASE DOWN THE DUCT AROUND THE DAM, AND SHALL BE APPROVED FOR THE APPLICATION.
- PROVIDE GREASE RESERVOIR AT THE LOWEST POINT IN GREASE EXHAUST DUCT OF DUCT RUN. GREASE EXHAUST DUCT TO HAVE 2% SLOPE TOWARDS THE GREASE RESERVOIR. COORDINATE WITH ARCHITECT FOR GREASE RESERVOIR ACCESS.
- CONTRACTOR TO REPLACE THE EXISTING SUPPLY/RETURN AIR DIFFUSERS WITH NEW. EXTEND THE DUCT FROM NEW LOCATION AND CONNECT TO EXISTING MAIN DUCTS.
- EXISTING SUPPLY & RETURN DUCTS FROM EXISTING RTUS TO REMAIN AND REUSED. CONTRACTOR TO FIELD VERIFY DUCTWORK LOCATIONS. MODIFY/EXTEND AS THE DUCTS NEEDED TO CONNECT WITH NEW /NEW RELOCATED DIFFUSERS. NOTIFY ARCHITECT/ENGINEER OF ANY DISCREPANCIES PRIOR TO BID AND START OF WORK.
- EXISTING TOILET EXHAUST SYSTEM TO REMAIN. CONTRACTOR TO VERIFY THE WORKING CONDITION OF THE FANS. CLEAN AND REFURBISH TO "LIKE-NEW" CONDITION. IF NOT WORKING PROPERLY REPLACE WITH THE SIMILAR KIND.
- 14"Ø EXHAUST DUCT FROM HOOD-1(N) UP THROUGH ROOF TO KEF-1(N).
- 10"Ø EXHAUST DUCT FROM HOOD-2(N) UP THROUGH ROOF TO KEF-2(N).
- 12"X12" EXHAUST DUCT TO BE PROVIDED WITH KITCHEN EQUIPMENT AND INSTALLED BY MECHANICAL CONTRACTOR. INSTALL PER MANUFACTURER'S INSTRUCTIONS.
- EXTEND MAKE-UP AIR DUCT FROM UP TO MAKE-UP AIR UNIT ON ROOF MAU-1(N).
- LOCATION OF ANSUL SYSTEM REMOTE MANUAL PULL STATION. VERIFY EXACT LOCATION WITH KITCHEN EQUIPMENT SUPPLIER.
- SIZE, INSTALL AND ROUTE THE DUCT IN KITCHEN/PREP AREA BASED ON ACTUAL SITE CONDITIONS. IF THE SUPPLY AIR DIFFUSER IS LESS THAN 10 FT. AWAY FROM HOOD PROVIDE THE PERFORATED TYPE. COORDINATE ALL DUCTWORK AND SUPPLY AIR DIFFUSER LOCATIONS WITH THE ARCHITECT.
- ROUTE CONDENSATE DRAIN LINE FROM AC-1(N) TO NEAREST DRAIN POINT. PROVIDE HORIZONTAL SLOPE IN THE DIRECTION OF DISCHARGE OF NOT LESS THAN $\frac{1}{8}$ TH UNITS VERTICAL IN 12 UNITS HORIZONTAL.
- INSTALL AND WIRE A NEW 7-DAY PROGRAMMABLE THERMOSTAT FOR AC-1(N). MOUNT THERMOSTAT 48" A.F.F. PROVIDE LOCKING CLEAR PLASTIC COVER FOR THERMOSTAT. COORDINATE EXACT LOCATION WITH ARCHITECT AND OWNER PRIOR TO ROUGH-IN.
- FURNISH & INSTALL MOTORIZED DAMPER IN OUTSIDE AIR DUCT FOR CONTROL OF OUTSIDE AIR & INTERLOCK WITH RESPECTIVE AC-1(N) FOR CONTROL OF OUTSIDE AIR.
- ROUTE 6"Ø OUTSIDE AIR INTAKE DUCT UP THROUGH ROOF.

SHEET HISTORY SCHEDULE
ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:


QAQC:


APPROVED BY:

PROJECT NUMBER:

MECHANICAL FLOOR PLAN

M1.0





MECHANICAL GENERAL NOTES

- A. COORDINATE LOCATIONS AND SIZES OF ROOF OPENINGS WITH OWNER AND STRUCTURAL ENGINEERS.
- B. EQUIPMENT SIZES, DIMENSIONS AND REQUIRED CONNECTIONS SHALL BE VERIFIED WITH THE ACTUAL EQUIPMENT SELECTED VENDOR DRAWINGS BEFORE FABRICATION OF STRUCTURE, PIPING ETC.
- C. CONTRACTOR SHALL COORDINATE ELECTRICAL REQUIREMENTS FOR ALL HVAC BASED ON ACTUAL EQUIPMENT SELECTED PRIOR TO INSTALLATION.
- D. ALL SOURCE OF MECHANICAL INTAKE SHALL MAINTAIN 10 LINEAR FEET SEPARATION BETWEEN ANY SOURCE OF EXHAUST. CONTRACTOR IS RESPONSIBLE TO ADJUST DUCT LENGTH AS NEEDED.
- E. TEST AND BALANCE AIR SYSTEMS. PROVIDE REPORT TO GENERAL CONTRACTOR AND OWNER.
- F. PATCH THE EXISTING PENETRATIONS OF THE ROOF IF EXISTING PENETRATION IS NOT FEASIBLE/WORKABLE FOR NEW UNITS. COORDINATE WITH ROOFING AND MECHANICAL CONTRACTOR.
- G. ALL NEW MECHANICAL EQUIPMENT'S WEIGHTS ARE INCLUDING ROOF CURBS AND/OR ADAPTORS.
- H. M.C TO COORDINATE INSTALLATION OF WATER HEATER EXHAUST FLUE WITH PLUMBING CONTRACTOR.
- I. ALL SHUT DOWNS OF EXISTING SYSTEMS SHALL BE SCHEDULED AND APPROVED BY THE OWNER PRIOR TO COMMENCING WITH WORK.
- J. PROVIDE INSULATION FOR REFRIGERANT PIPES AS PER ENERGY CODE.
- K. PROVIDE WEATHER PROOF COATING FOR ALL EXPOSED PIPES.

MECHANICAL ROOF PLAN KEY NOTES:

- ① COORDINATE FINAL LOCATION OF EQUIPMENT WITH STRUCTURAL DRAWINGS. INSTALL ALL NEW EQUIPMENT ON THE NEW ROOF CURBS.
- ② EXISTING MECHANICAL ROOFTOP UNITS TO REMAIN & TO BE REUSED. CLEAN AND REFURBISH TO "LIKE-NEW" CONDITION. REPAIR/REPLACE ANY ACCESSORIES AS REQUIRED TO PROVIDE A FULLY FUNCTIONING UNIT VERIFIED IN FIELD PRIOR TO BID. VERIFY FINAL LOCATION ON FILED. NOTIFY ARCHITECT/ENGINEER OF ANY DISCREPANCIES PRIOR TO BID AND START OF WORK.
- ③ GUARDS SHALL BE PROVIDED WHERE VARIOUS COMPONENTS THAT REQUIRE SERVICE ARE LOCATED WITHIN 10 FEET OF A ROOF EDGE OR OPEN SIDE OF A WALKING SURFACE AND SUCH EDGE OR OPEN SIDE IS LOCATED MORE THAN 30 INCHES ABOVE THE FLOOR, ROOF OR GRADE BELOW. THE GUARD SHALL EXTEND NOT LESS THAN 30 INCHES BEYOND EACH END OF SUCH COMPONENTS. THE GUARD SHALL BE CONSTRUCTED SO AS TO PREVENT THE PASSAGE OF A SPHERE 21 INCHES IN DIAMETER.
- ④ EXISTING CONDENSATE DRAIN LINES FROM THE EXISTING RTUS SHALL REMAIN & SHALL BE REUSED. FLUSH THE EXISTING DRAIN LINES. REPAIR/REPLACE IN CASE OF DAMAGE. CONTRACTOR TO FIELD VERIFY EXACT LOCATION & CONDITION.
- ⑤ NEW MAKE-UP AIR UNIT AND ROOF CURB ARE PROVIDED. PROVIDE FLEXIBLE CONNECTION ON THE SUPPLY DUCT CONNECTION TRANSITION TO DUCT SIZE INDICATED. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID.
- ⑥ PROVIDE NEW ROOF MOUNTED EXHAUST FAN AND FAN CURB. COORDINATE INSTALLATION OF FAN WITH LANDLORD AND EXISTING CONDITIONS TO ENSURE THAT EXHAUST OUTLETS SHALL BE LOCATED NOT LESS THAN 10 FT. HORIZONTALLY OR 3 FT. VERTICALLY FROM ANY OUTSIDE AIR INTAKE SOURCE.
- ⑦ ROUTE CONDENSATE DRAIN FROM MAU ON THE ROOF TO THE NEAREST DRAIN POINT. CONNECT TO A DRAIN LINE VIA AIR GAP IN AN APPROVED MANNER.
- ⑧ ALL OUTSIDE AIR INTAKES SHALL BE LOCATED A MINIMUM OF 10 FT HORIZONTAL OR 3 FT. VERTICAL FROM ANY SANITARY VENT, EXHAUST FAN DISCHARGE AND FLUE OF OTHER GAS FIRED EQUIPMENT.
- ⑨ PROVIDE A 3' TALL WIND BAND FOR EXHAUST FAN. COORDINATE INSTALLATION OF FAN & EXISTING CONDITIONS WITH LANDLORD TO ENSURE THAT EXHAUST OUTLETS SHALL BE LOCATED NOT LESS THAN 3' ABOVE AIR INTAKE SOURCE.
- ⑩ 6" OUTSIDE AIR INTAKE DUCT UP THROUGH ROOF WITH TALL CONE FLASHING, WEATHER SKIRT, BIRDSCREEN & ROOF CAP. MAINTAIN A MINIMUM OF 10'-0" FROM ANY EXHAUST AIR SOURCE.
- ⑪ PROVIDE NEW CONDENSING UNIT CU-1(N). COORDINATE FINAL LOCATION OF THE UNIT WITH LANDLORD/ARCHITECT PRIOR TO INSTALLATION. UNIT TO BE INSTALLED WITH MANUFACTURER'S RECOMMENDED CLEARANCES.
- ⑫ PIPING SHOULD RUN ABOVE FINISHED FLOOR.
- ⑬ CONTRACTOR TO FIELD VERIFY EXISTING VTR LOCATION AND SIZE. PROVIDE NEW VTR IF NOT EXISTING. MAINTAIN A MINIMUM OF 10'-0" FROM ANY OUTSIDE AIR SOURCE.

SHEET HISTORY SCHEDULE
ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:


APPROVED BY:

PROJECT NUMBER:

MECHANICAL
ROOF PLAN

M1.1


GRAPHIC SCALE: 1/4" = 1'-0"
0 4' 8' 12' 16'



1 LOW PRESSURE BALANCING DAMPER
M5.0 N.T.S

2 ROOF MOUNTED EXHAUST FAN DETAIL
M5.0 N.T.S

3 LOW VELOCITY DUCTWORK ELBOWS
M5.0 N.T.S





4 SUPPLY AIR DUCTWORK SUB-MAIN/BRANCH DUCT CONNECTION
M5.0 N.T.S

5 ACOUSTICAL TREATMENT DUCT LINING
M5.0 N.T.S


6 FLEXIBLE CONNECTION (DUCT-EQUIPMENT)
M5.0 N.T.S

MECHANICAL DETAILS (1 OF 3)


M5.0




1 METHOD OF HANGING DUCTWORK
M5.1 N.T.S.




3 DETAIL FOR DUCT PENETRATION THROUGH ROOF
M5.1 N.T.S.



4 ROUND DUCT TAKE OFF DETAIL
M5.1 N.T.S.



5 ROOF MOUNTED EXHAUST FAN WITH WIND BAND DETAIL
M5.1 N.T.S.



ACCEPTABLE FOR 170 MPH ZONE
VERIFY ON SITE WITH GENERAL CONTRACTOR

6 ROOF TOP UNIT INSTALLATION ON ROOF
M5.1 N.T.S.

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:


APPROVED BY:

PROJECT NUMBER:


MECHANICAL

DETAILS (2 OF 3)


M5.1



1 METHOD OF HANGING REFRIGERANT PIPING
M5.2 N.T.S




2 MOTORIZED DAMPER DETAIL
M5.2 N.T.S



NOTE: 1. UNIT & STAND SHALL BE ANCHORED TO WITHSTAND F.B.C.-2010 HURRICANE WIND FORCE REQUIREMENTS - HVHZ 1620.2

3 CONDENSING UNIT MOUNTING DETAIL
M5.2 N.T.S



4 VIBRATION ISOLATOR
M5.2 N.T.S

5 CASSETTE SPLIT HEAT PUMP UNIT DETAIL
M5.2 N.T.S

SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

MECHANICAL

DETAILS (3 OF 3)

M5.2

1. S.A.E. :- SAME AS EXISTING, V.I.F:- VERIFY IN F
2. EXISTING RTU WITH ALL ACCESSORIES TO REM
3. CONTRACTOR TO CONFIRM IF EXISTING RTUS
4. CONTRACTOR TO FIELD VERIFY EXACT LOCATI
5. IF REQUIRED, PROVIDE NEW THERMOSTATS C
6. CONTRACTOR TO REBALANCE OUTSIDE AIR &
7. REPLACE ALL THE FILTERS. PROVIDE MINIMUM

10. PROVIDE VIBRATION ISOLATOR FOR UNIT MOUNTING.

9) PROVIDE FRESH AIR INTAKE KIT FOR OUTSIDE AIR INTEGRATION.

7) OUTDOOR CONDENSING UNIT TO BE LOCATED WITH PROPER CLEARANCES AND MUST PREVENT RE-CIRCULATION OF AIR. COORDINATE WITH MANUFACTURER AND ARCHITECT.

ROOM NAME	AREA (SQ.FT.)	NUMBER OF PEOPLE/1000 SQ.FT AS PER 2023 FMC	NUMBER OF PEOPLE AS PER 2023 FMC	NUMBER OF CHAIR	FINAL PEOPLE NO.	MIN OUTSIDE AIR AS PER 2023 FMC		REQUIRED OUTSIDE AIR CFM	PROVIDED OUTSIDE AIR CFM	EXHAUST AIRFLOW RATE (CFM/SQ.FT) OR (CFM/FIXTURE)	REQUIRED EXHAUST (CFM)	PROVIDED EXHAUST (CFM)
						CFM/PEOPLE	CFM/SQ.FT					
001-ENTRANCE	115	10	2	0	0	5	0.06	7	4180	0	0	0
002-ENTRANCE LOBBY	49	10	1	0	0	5	0.06	3		0	0	0
003-DINING	897	70	63	55	60	7.5	0.18	611		0	0	0
004-SERVICE COUNTER	219	15	4	2	3	7.5	0.12	49		0	0	0
005-DRIVE-THRU	109	2	1	1	1	10	0.12	23		0	0	0
006-HOTLINE	261	20	6	0	3	7.5	0.12	54		0.7	183	2577
007-PREP	377	20	8	0	4	7.5	0.12	75		0	0	1450
008-SCULLERY	221	0	0	0	0	0	0.12	27		0	0	0
009-OFFICE	43	5	1	1	1	5	0.06	8		0	0	0
010-MALE RR	73	0	0	0	0	0	0	0		70	70	70
011-FEMALE RR	85	0	0	0	0	0	0	0		70	70	70
012-LOBBY	58	0	0	0	0	0	0.06	3		0	0	0
TOTAL	2507	-	-	-	72	-	-	860	4180	-	323	4167

AIR BALANCE TABLE					
UNIT	AREA SERVED	SUPPLY AIR (CFM)	OUTSIDE AIR (CFM)	RETURN AIR (CFM)	EXHAUST AIR (CFM)
RTU-1(E)	SEE PLAN	2000 CFM	1050 CFM	950 CFM	0 CFM
RTU-2(E)	SEE PLAN	2000 CFM	840 CFM	1160 CFM	0 CFM
RTU-3(E)	SEE PLAN	2000 CFM	840 CFM	1160 CFM	0 CFM
AC-1(N)	SEE PLAN	1253 CFM	50 CFM	1203 CFM	0 CFM
MAU-1(N)	SEE PLAN	1400 CFM	1400 CFM	0 CFM	0 CFM
EF-1(N)	MALE RESTROOM	-	-	-	70 CFM
EF-2(N)	FEMALE RESTROOM	-	-	-	70 CFM
KEF-1(N)	KITCHEN	-	-	-	2052 CFM
KEF-2(N)	KITCHEN	-	-	-	525 CFM
KEF-3(N)	SEE PLAN	-	-	-	1450 CFM
TOTAL:		8653 CFM	4180 CFM	4473 CFM	4167 CFM
BUILDING PRESSURE:			13 CFM	POSITIVE

HOODS SCHEDULE											
INIT ID	TAG	MANUFACTURER	LENGTH	MODEL	TYPE	COOKING	EXHAUST			CONSTRUCTION	WEIGHT
			(FEET-INCH)			TEMPERATURE (DEG F)	AIR (CFM)	COLLAR (INCH)	S.P (IN. W.G.)		(LBS)
OD-1(N)	PIZZA OVEN	CAPTIVE-AIRE	12'-0"	6630 ND-2-PSP-F	I	600	2052	14"	0.81	430 STAINLESS STEEL WHERE EXPOSED	1290
OD-2(N)	PASTAMAGIC	CAPTIVE-AIRE	3'-0"	5430 VHB-G-ND	II	700	525	10"	0.051	430 STAINLESS STEEL 100%	260
OD-3(N)	KETTLES	CAPTIVE-AIRE	8'-6"	5430 VHB-G-ND	II	700	1450	13"X13"	0.5	430 STAINLESS STEEL 100%	450

REFER TO HOOD DETAIL SHEETS FOR MORE INFORMATION

AIR TERMINAL DEVICES SCHEDULE							
TAG	SIZE (IN.)	DESCRIPTION	CONSTRUCTION	FINISH	BASIS OF DESIGN		NOTES
					MANUFACTURER	MODEL	
DS-1	24X24	SUPPLY AIR DIFFUSER	ALUMINUM	WHITE	TITUS	OMNI-AA	ALL
DS-2	24X24	PERFORATED SUPPLY AIR DIFFUSER	ALUMINUM	WHITE	TITUS	PAS	ALL
DR-1	24X24	RETURN AIR DIFFUSER	ALUMINUM	WHITE	TITUS	350FL	ALL

:-

VIDE FRAME FOR MOUNTING AIR DEVICE IN LAY-IN GRID CEILING UNLESS REFLECTED CEILING PLAN INDICATES HARD CEILING. IN AREAS WITH HARD GS, PROVIDE FRAMES FOR SURFACE MOUNTING.

LESS OTHERWISE NOTED, BRANCH DUCTS SERVING AIR DEVICES SHALL BE SAME SIZE AS NECK OF AIR DEVICE.

ORDINATE FINAL COLOR/FINISH WITH ARCHITECT/OWNER.

DEVICE SHALL BE OF GALVANIZED FINISH WHEN INSTALLED ON EXPOSED DUCTWORK.

KIMUM NOISE CRITERION RATING < 35 DBA.

OUND NECK DIFFUSERS: NECK SIZES SHALL BE:-

A: 901-1100 CFM

A: 600-900 CFM

A: 376-599 CFM

A: 226-375 CFM

101-225 CFM

0-100 CFM

VIDE FRAME FOR MOUNTING AIR DEVICE IN LAY-IN GRID CEILING UNLESS REFLECTED CEILING PLAN INDICATES HARD CEILING. IN AREAS WITH HARD GS, PROVIDE FRAMES FOR SURFACE MOUNTING.

ESS OTHERWISE NOTED, BRANCH DUCTS SERVING AIR DEVICES SHALL BE SAME SIZE AS NECK OF AIR DEVICE.

RDINATE FINAL COLOR/FINISH WITH ARCHITECT/OWNER.

DEVICE SHALL BE OF GALVANIZED FINISH WHEN INSTALLED ON EXPOSED DUCTWORK.

KIMUM NOISE CRITERION RATING < 35 DBA.

UND NECK DIFFUSERS: NECK SIZES SHALL BE:-

A: 901-1100 CFM

A: 600-900 CFM

A: 376-599 CFM

A: 226-375 CFM

101-225 CFM

0-100 CFM

FAZOLI'S, KISSIMMEE, FL

ISSUE DATE:

ISSUE DATE:

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

MECHANICAL COMPUTER-AIDS

M7.0

M6.0

System Checksums

By Trial

RTU-1

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Mo/Hr: 8 / 19								Mo/Hr: Sum of OADB: Peaks				Mo/Hr: Heating Design OADB: 38				Cooling	Heating	Single Zone	
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Space Peak Btu/h	Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	SADB	55.3	90.3	Property of FAZOLI'S		
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	Btu/h	(%)	Btu/h	Btu/h	Btu/h	(%)	Ra Plenum	77.1	70.9	ENCL		
Envelope Loads								Envelope Loads				Envelope Loads				Temperatures			
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0	Skylite Solar	0	0	0	SADB	55.3	90.3	
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0	Skylite Cond	0	0	0	Ra Plenum	77.1	70.9	
Roof Cond	0	6,185	6,185	3	0	0	0	Roof Cond	0	0	0	Roof Cond	0	0	0	Return	77.1	70.9	
Glass Solar	10,579	0	10,579	5	14,531	15	14,531	Glass Solar	0	0	0	Glass Solar	0	0	0	Ret/OA	80.4	59.3	
Glass/Door Cond	2,279	0	2,279	1	2,079	2	2,079	Glass/Door Cond	-6,377	-6,377	3.68	Glass/Door Cond	-6,377	-6,377	3.68	Fn MtrTD	0.0	0.0	
Wall Cond	11,292	7,301	18,593	8	12,559	13	12,559	Wall Cond	-7,897	-13,090	7.55	Wall Cond	-7,897	-13,090	7.55	Fn BldTD	0.0	0.0	
Partition/Door	0	0	0	0	0	0	0	Partition/Door	0	0	0	Partition/Door	0	0	0	Fn Frict	0.0	0.0	
Floor	0	0	0	0	0	0	0	Floor	-5,190	-5,190	3.00	Floor	-5,190	-5,190	3.00				
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0	0	Adjacent Floor	0	0	0				
Infiltration	37,003		37,003	16	10,899	11	10,899	Infiltration	-33,174	-33,174	19.14	Infiltration	-33,174	-33,174	19.14				
<i>Sub Total ==></i>	<i>61,153</i>	<i>13,486</i>	<i>74,639</i>	<i>32</i>	<i>40,067</i>	<i>42</i>	<i>40,067</i>	<i>Sub Total ==></i>	<i>-52,637</i>	<i>-60,636</i>	<i>34.99</i>	<i>Sub Total ==></i>	<i>-52,637</i>	<i>-60,636</i>	<i>34.99</i>				
Internal Loads								Internal Loads				Internal Loads				AIRFLOWS			
Lights	8,428	2,107	10,535	5	8,186	9	8,186	Lights	0	0	0.00	Lights	0	0	0.00	Diffuser	5,019	5,019	
People	27,946	0	27,946	12	13,716	14	13,716	People	0	0	0.00	People	0	0	0.00	Terminal	5,019	5,019	
Misc	32,532	0	32,532	14	32,170	34	32,170	Misc	0	0	0.00	Misc	0	0	0.00	Main Fan	5,019	5,019	
<i>Sub Total ==></i>	<i>68,907</i>	<i>2,107</i>	<i>71,014</i>	<i>31</i>	<i>54,071</i>	<i>57</i>	<i>54,071</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	Sec Fan	0	0	
Ceiling Load	1,635	-1,635	0	0	1,358	1	1,358	Ceiling Load	-851	0	0.00	Ceiling Load	-851	0	0.00	Nom Vent	1,800	1,800	
Ventilation Load	0	0	91,987	40	0	0	0	Ventilation Load	0	-67,190	38.77	Ventilation Load	0	-67,190	38.77	AHU Vent	1,800	1,800	
Adj Air Trans Heat	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	Adj Air Trans Heat	0	0	0	Infil	734	889	
Dehumid. Ov Sizing			0	0				Ov/Undr Sizing	-48,715	-48,715	28.11	Ov/Undr Sizing	-48,715	-48,715	28.11	MinStop/Rh	0	0	
Ov/Undr Sizing	0	0	0	0	0	0	0	Exhaust Heat	3,253	-1.88		Exhaust Heat	3,253	-1.88		Return	5,752	5,907	
Exhaust Heat		-6,094	-6,094	-3				OA Preheat Diff.	0	0.00		OA Preheat Diff.	0	0.00		Exhaust	2,534	2,689	
Sup. Fan Heat		0	0	0	0			RA Preheat Diff.	0	0.00		RA Preheat Diff.	0	0.00		Rm Exh	0	0	
Ret. Fan Heat	0	0	0	0	0			Additional Reheat	0	0.00		Additional Reheat	0	0.00		Auxiliary	0	0	
Duct Heat Pkup	0	0	0	0	0			Underflr Sup Ht Pkup	0	0.00		Underflr Sup Ht Pkup	0	0.00		Leakage Dwn	0	0	
Underflr Sup Ht Pkup		0	0	0	0			Supply Air Leakage	0	0.00		Supply Air Leakage	0	0.00		Leakage Ups	0	0	
Supply Air Leakage	0	0	0	0	0			<i>Grand Total ==></i>	<i>-102,203</i>	<i>-173,287</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-102,203</i>	<i>-173,287</i>	<i>100.00</i>				
<i>Grand Total ==></i>	<i>131,695</i>	<i>7,864</i>	<i>231,545</i>	<i>100.00</i>	<i>95,497</i>	<i>100.00</i>													
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION				ENGINEERING CKS			
Total Capacity ton	22.2	266.3	Sens Cap. MBh	142.1	Coil Airflow cfm	5,019	Enter DB/WB/HR °F	81.1	Leave DB/WB/HR °F	55.3	Gross Total ft²	2,465	Capacity MBh	35.9	Cooling	35.9	Heating		
Aux Clg	0.0	0.0		0.0		0		0.0	53.1	Glass (%)	0	Main Htg	-216.6	5,019	59.3	90.3			
Opt Vent	0.0	0.0		0.0		0		0.0	57.0			Aux Htg	0.0	0	0.0	0.0			
<i>Total</i>	<i>22.2</i>	<i>266.3</i>										Preheat	0.0	0	0.0	0.0			
												Humidif	0.0	0	0.0	0.0			
												Opt Vent	0.0	0	0.0	0.0			
												<i>Total</i>	<i>-216.6</i>						

Project Name: FAZOLIS
Dataset Name: HLC-FAZOLI.trc

TRACE® 700 v6.3.3 calculated at 08:34 PM on 10/08/2024
Alternative - 1 System Checksums Report Page 1 of 1

PERMIT SET

ISSUE DATE:

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

HEAT LOAD
CALCULATION
REPORTS
M7.0

FOR QUESTIONS, CALL THE
REGIONAL OFFICE
PHONE: 7270-570-0981
EMAIL: reg@privaterestaurants.com

HOOD INFORMATION – JOB#7024843

HOOD NUID	TAG	MODEL	MANUFACTURER	LENGTH	CUTTING TYPE	ABRASION DUTY	DESIGN CFM/ATT	TOTAL EXH CFM	WITH LEN/HEI/THI	SP	SUPR. CFM	TOTAL EXH CFM	HOOD CONSTRUCTION	END TO ROW
1	PIZZA OVEN	6420 NS-2-PSF-f Vibr-G-ND	CAPTURE-AIR	12'-0"	DEG	1	HEAVY	171	2052	14"	4"	420	420 SS WHERE EXPOSED ALONE	420 SS ALONE
2	PASTA/MIC	5430 Vibr-G-ND	CAPTURE-AIR	3'-0"	DEG	700	N/A	175	525	4"	10"	420	420 SS ALONE	420 SS ALONE

HOOD INFORMATION

HOOD NUID	TAG	TYPE	FILTER(S)	GTY	TYPE	LOCATION	GUARD	SIZE	TYPE	FE/ST/CEM/ETC	ELECTRICAL	SWITCHES	HOOD SYSTEM/TYPE	MODEL #	
1	PIZZA OVEN	CAPTRATE SILO FILTER	9	20"	85% SEE FILTER GFC	4	LSS SERIES 26	ND	LEFT	12"X46"X30"	TANK F	4.0/4.0	SC-33110WA	1 LIGHT YES 12.50	1 LIGHT 1 FAN NO 250 LBS
2	PASTA/MIC	CAPTRATE SILO FILTER	9	20"	85% SEE FILTER GFC	4	LSS SERIES 26	ND	LEFT	12"X46"X30"	TANK F	4.0/4.0	SC-33110WA	1 LIGHT YES 12.50	1 LIGHT 1 FAN NO 250 LBS

HOOD OPTIONS

OPTION

FIELD WRAPPER 1800" HIGH FRONT LEFT, RIGHT

LEFT QUARTER END PANEL 23" TOP WIDTH, 0" BOTTOM WIDTH, 23" HIGH 430 SS.

INSULATION FOR TOP OF HOOD, STRUCTURAL FRONT PANEL.

FIELD WRAPPER 1800" HIGH FRONT LEFT, RIGHT

FIELD WRAPPER 1800" HIGH X 26'0" LONG 23" TOP WIDTH, 0" BOTTOM WIDTH, 23" HIGH 430 SS.

LEFT QUARTER END PANEL 23" TOP WIDTH, 0" BOTTOM WIDTH, 23" HIGH 430 SS.

INSULATION FOR TOP OF HOOD.

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

MA 6" 28" 350 0.017

MA 6" 28" 350 0.017

REINFORDED SUPPLY PLUMING(S)

HOOD NUID TAG PUS LENGTH TYPE WIDTH HEIGHT TYPE LENGTH DIA SP

1 PIZZA OVEN Front 156" 9" 6" 28" MA 6" 28" 260 0.017

LI'S, KISSIMMEE, FL

1000

BY:

MBER:

HOOD

H1.2

111.2

MAINTAINED DOWNSREAM OF UNIT DISCHARGE AS OUTLINED IN AMCA PUBLICATION 201. WHEN USING REGULAR DUCTWORK, ELBOWS MUST BE RADIUS THROAT, RADIUS BACK WITH TURNING VANE, FLEXIBLE DUCTWORK AND SQUARE THROAT/SQUARE BACK ELBOWS SHOULD NOT BE USED. ANY TRANSITION AND/OR TURNS IN THE DUCTWORK WILL CAUSE SYSTEM EFFECT. SYSTEM EFFECT WILL DRAMATICALLY INCREASE STATIC PRESSURE AND REDUCE AIRFLOW. DO NOT RELY ON UNIT TO SUPPORT DUCT IN ANY WAY. FAILURE TO PROPERLY SIZE DUCTWORK MAY CAUSE SYSTEM EFFECTS AND REDUCE PERFORMANCE OF THE EQUIPMENT. SUGGESTED STRAIGHT DUCT SIZE IS 20.75" x 21.5".

3C - NORMAL OPERATION

MINIMUM 1'

4' TRAP HEIGHT

H

H = 6" FOR EACH 1' OF MAXIMUM NEGATIVE STATIC PRESSURE + 1'
J = HALF OF H IF H < 12"
L = H + J + PIPE DIAMETER + INSULATION

UNIT

G

Front View Dimensions:

- CURB OUTLINE: 41" x 71"
- WEIGHT: 297 LBS
- DISCHARGE CUTOUT: 21 1/4"
- ENTERING POWER: 354 LBS
- MASS CENTER: 26"
- DISCHARGE: 20 5/8"
- DISCHARGE: 5 13/16"
- DISCHARGE: 14 7/16"
- DISCHARGE: 6 1/4"
- DISCHARGE: 5 5/8"
- DISCHARGE: 7 3/4"

Side View Dimensions:

- WEIGHT: 204 LBS
- WEIGHT: 243 LBS

The image contains two technical line drawings. The left drawing is a cross-sectional view of a duct system. It features a large rectangular duct with a ribbed filter or grille on the left side. The top edge of the duct is labeled 'LOUVERED OUTSIDE AIR INTAKE'. Various dimensions are indicated: height is 47 5/16", width is 48 3/16", depth is 18", and internal height is 3 1/2". A small red rectangular component is located near the bottom center. The right drawing is a perspective view of a truss structure, likely a roof truss. It shows a triangular frame with a central support. The vertical height of the truss is labeled as 6' and the horizontal span is labeled as 18'.

FACTORY INSTALLED SAFETY DISCONNECT SWITCH.

1' INPT. SS. EVAPORATOR DRAIN STRAP REQ'D.
4" MINIMUM TRAP DEPTH.

MINIMUM SWING DIST. PER ANCAW

71"

75 7/16"

77 15/16"

20 7/8"

71" 1 1/2" DUCT HANGER WIDTH, TYP.


A technical line drawing of a rectangular duct system. The duct is oriented vertically and appears to be a section of a larger system. The top edge of the duct is labeled "SERVICE CLEARANCE 3 FT." with a leader line. The bottom edge is labeled "CLEARANCE TO COMBUSTIBLES 0 FT." with a leader line. The left side of the duct is labeled "CLEARANCE TO COMBUSTIBLES 0 FT." with a leader line. The right side of the duct is labeled "CLEARANCE TO COMBUSTIBLES 0 FT." with a leader line. The front face of the duct has a circular vent or filter on the left and a ribbed section on the right. The back face of the duct has a ribbed section. The top and bottom edges of the duct are straight and parallel.

The image features a large, diagonal red watermark with the word "Engineers" in a bold, sans-serif font. To the left of the watermark, there is a red checkmark. Below the watermark, there are four separate electrical circuit diagrams labeled A, B, C, and D. Each diagram is a complex network of lines, components, and labels, typical of industrial or technical electrical schematics. Diagram A is on the left, B is above it, C is below A, and D is below B. The entire image has a white background.

PERMIT SET

SHEET HISTORY SCHEDULE		
ISSUE DATE:		
FAZOLI'S, KISSIMMEE, FL		
DRAWN BY:		
QAQC:		
APPROVED BY:		
PROJECT NUMBER:		
 HOOD DETAILS (4 OF 4)		
H1.3		

Property of NY Engineers



ELECTRICAL SYMBOLS LIST					GENERAL NOTES (APPLY TO ALL "E" DRAWINGS)	
SWITCHES AND CONTROLS		POWER AND TELECOMMUNICATION		ELECTRICAL ABBREVIATIONS		
\$ ₀	20A SPST TOGGLE SWITCH U.O.N. "0" DENOTES LIGHTING FIXTURE CONTROLLED.	(J)	JUNCTION BOX WITH BLANK COVER PLATE	A	AMPERES	EA
\$ _{OS}	OCCUPANCY SENSOR SWITCH	(J)	JUNCTION BOX WITH BLANK COVER PLATE, CEILING MOUNTED..	A/C, AC	AIR CONDITIONING UNIT	EC
□	DOOR JAMB SWITCH	(D)	DUPLEX CONVENIENCE RECEPTACLE, +18" AFF OR AS NOTED.	AF	AMPERE FRAME/AMP FUSE	EF
PC	WALL MOUNTED PHOTOCELL MOUNTED IN NEMA 3R ENCLOSURE.	(D)	DUPLEX DEDICATED RECEPTACLE, +18" AFF OR AS NOTED.	AFF	ABOVE FINISHED FLOOR	EM
OS _A	CEILING OCCUPANCY SENSOR, NUMBER INDICATES TYPE; SEE OCCUPANCY SENSOR SCHEDULE. 'A' LETTER REFERS TO WIRING DIAGRAM.	(D)	DUPLEX WITH USB	AS	AMP SWITCH	EMT
DS	CEILING MOUNTED DAYLIGHT SENSOR.	(D)	DUPLEX CONVENIENCE RECEPTACLE, +18" AFF OR AS NOTED.	AIC	AMPS INTERRUPTING CAPACITY	EQUIP
		(D)	DUPLEX DEDICATED GFI RECEPTACLE, +18" AFF OR AS NOTED.	AT	AMP TRIP	ER
		(D)	CEILING/FLOOR MOUNTED RECEPTACLE	ATS	AUTOMATIC TRANSFER SWITCH	ETR
3	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSIST OF 1#12 Ø, 1#12 N, & 1#12 G. IN 3/4", UNLESS OTHERWISE NOTED.	(D)	SPECIAL RECEPTACLE	AUTO	AUTOMATIC	EWF
UP-		(D)	NETWORK INTERFACE DEVICE. NID IS 'ONT' BOX WHICH INCLUDES BOTH 'ONT' AND ITS SISTER BOX AS PER VERIZON STANDARDS.	AWG	AMERICAN WIRE GAUGE	EWH
3 5	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSIST OF 2#12 Ø, 2#12 N, & 2#12 G. IN 3/4", UNLESS OTHERWISE NOTED.	(D)	QUAD RECEPTACLE	C	CONDUIT	FA
UP-		(D)	TELEPHONE/DATA OUTLET, 4" SQUARE OUTLET BOX WITH SINGLE GANG COLLAR AND BLANK PLATE. PROVIDE 3/4" E.C., U.O.N., UP TO HUNG CEILING AND TERMINATE WITH 90° ELBOW, BUSHING AND DRAG WIRE.	C/B,CB	CIRCUIT BREAKER	FBO
3 5 7	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSIST OF 3#12 Ø, 3#12 N, & 3#12 G. IN 3/4", UNLESS OTHERWISE NOTED.	(D)		CKT	CIRCUIT	FDR
UP-		(D)	TELEPHONE OUTLET, WALL-MOUNTED +48" AFF UNO TEL / DATA OUTLET TO BE PROVIDED WITH 1" CONDUIT U.O.N. TO H.C. AND TERMINATED WITH 90 DEGREE REEL ELBOW AND BUSHING. TEL / DATA OUTLET PLATE SHALL BE PROVIDED WITH 1 1/4" DIAMETER GROMMETED OPENING.	CLG	CEILING	FIBO
—○	CONDUIT TURNING UP, SEE FLOOR PLANS FOR CONDITIONS.	(D)		COMM	COMMUNICATION	FIXT
—●	CONDUIT TURNING DOWN, SEE FLOOR PLANS FOR CONDITION.	(D)		CT	CURRENT TRANSFORMER	FL
—	CONDUIT AND WIRE TO BUILDING GROUND.	(D)		CU	COPPER	FLUOR
—	CABLE TRAY, WIDTH AND MOUNTING AS NOTED.	(D)		°C	DEGREE CELSIUS	G
—	UNDERGROUND	(D)		°F	DEGREE FAHRENHEIT	GFI
—	EXISTING	(D)		DIA	DIAMETER	GP
—	NEW	(D)		DISC	DISCONNECT	HC
ELECTRICAL DRAWING LIST						
E0.1	ELECTRICAL SYMBOL LIST, ABBREVIATIONS & GENERAL NOTES	(M)	AC INDOOR UNIT MOTOR AS NOTED WITH LIQUID TIGHT FLEXIBLE CONNECTION WITH JUNCTION BOX AND MOTOR SWITCH.	DWH	DOMESTIC WATER HEATER	HZ
E0.2	ELECTRICAL SPECIFICATIONS SHEET 1 OF 2	(M)	AC OUTDOOR UNIT MOTOR AS NOTED WITH CONTROLLER AND DISCONNECT SWITCH WITH WEATHER PROOF.	DWG	DRAWING	IC
E0.3	ELECTRICAL SPECIFICATIONS SHEET 2 OF 2	(D)	NON FUSED DISCONNECT SWITCH AMPERAGE, AND NUMBER OF POLES AS NOTED.	JB	JUNCTION BOX	PP
E1.0	ELECTRICAL LIGHTING PLAN MAIN FLOOR	(D)	30A NON FUSED DISCONNECT SWITCH	KCMIL	ONE THOUSAND CIRCULAR MILS	PVC
E2.0	ELECTRICAL POWER PLAN MAIN FLOOR	(D)	60A NON FUSED DISCONNECT SWITCH	KV	KILOVOLT	PWR
E2.1	ELECTRICAL POWER PLAN ROOF PLAN	(D)	100A NON FUSED DISCONNECT SWITCH	KVA	KILOVOLT-AMPERES	R
E3.0	ELECTRICAL DETAILS	(D)	200A NON FUSED DISCONNECT SWITCH	KW	KILOWATTS	RE
E4.0	ELECTRICAL PANEL SCHEDULE AND RISER DIAGRAM	(D)	COMBINATION MAGNETIC STARTER AND DISCONNECT SWITCH, FURNISHED BY HVAC/CONTRACTOR, INSTALLED AND WIRED BY ELECTRICAL CONTRACTOR.	LP	LIGHTING PANEL	REC
		(D)	400 350 FUSED DISCONNECT SWITCH AND FUSE AMPERAGE AS INDICATED. TOP NUMBER DENOTES SWITCH SIZE AND BOTTOM NUMBER DENOTES FUSE.	LTG	LIGHTING	RGS
		(D)	COMBINATION SOLID-STATE MOTOR STARTER.	MAX	MAXIMUM	RR
		(D)	MOTORIZED DAMPER.	MC	MOTOR CONTROLLER	SECT
		(D)	FIRE SMOKE DAMPER	MCB	MAIN CIRCUIT BREAKER	SPDT
		(D)	DUPLEX PUMP. NUMBER INDICATES HP RATING OF PUMP.	MER	MECHANICAL EQUIPMENT ROOM	SPST
		(D)	1.5 kW ELECTRICAL HEATER, NUMBER DENOTES HEATER RATING	MIN	MINIMUM	SPEC
				MLO	MAIN LUGS ONLY	SW
				MTD	MOUNTED	SWBD
				MTS	MANUAL TRANSFER SWITCH	SYM
				N	NEUTRAL	SYS
				NE	NEW DEVICE TO REPLACE EXISTING	TELE
				NIC	NOT IN CONTRACT	TEMP
				NL	NIGHT LIGHT	TXF
				NTS	NOT TO SCALE	TYP
				OC	ON CENTER	UON
				P	POLES	V
				PB	PULLBOX	VA
				PC	PERSONAL COMPUTER	VAV
				Ø	PHASE	VFD
				PNL	PANEL	VP
				W	WATT	WP
				W	WIRE	XFMR
				WH	WALL HEATER	ZRT
				E	EXISTING	IG
CODES & STANDARDS					GENERAL NOTES (APPLY TO ALL "E" DRAWINGS)	
2023 FBC - ENERGY CONSERVATION, 8TH EDITION (IECC 2021) 2020 FLORIDA ELECTRICAL CODE (NFPA 70, 2020)					GENERAL NOTES (APPLY TO ALL "E" DRAWINGS)	
PROOF OF						

ELECTRICAL SPECIFICATIONS

1. GENERAL:

- A. THE "GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION," AIA DOCUMENT, LATEST EDITION, AND THESE SPECIFICATIONS AS APPLICABLE ARE PART OF THIS CONTRACT.
- B. DRAWINGS ARE DIAGRAMMATIC AND INDICATE GENERAL ARRANGEMENT OF SYSTEMS AND WORK. CONDUIT ROUTING IS SHOWN DIAGRAMMATICALLY AND DOES NOT SHOW ALL OFFSETS, DROPS AND RISES. CONTRACTOR IS RESPONSIBLE FOR DETERMINING THE PRICE FOR ROUTING OF CONDUIT TO AVOID OBSTRUCTIONS. COORDINATION WITH EXISTING SERVICES, INCLUDING THOSE OF OTHER TRADES, IS REQUIRED. MAINTAIN HEADROOM AND SPACE CONDITIONS.
- C. BIDDERS, BEFORE SUBMITTING PROPOSALS, SHALL VISIT AND CAREFULLY EXAMINE THE WORK AFFECTED BY THIS WORK TO FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS AND THE DIFFICULTIES THAT WILL ATTEND THE EXECUTION OF THIS WORK. SUBMISSION OF A PROPOSAL WILL BE CONSTRUED AS EVIDENCE THAT SUCH AN EXAMINATION HAS BEEN MADE, AND LATER CLAIMS WILL NOT BE RECOGNIZED FOR EXTRA LABOR, EQUIPMENT, OR MATERIALS, REQUIRED BECAUSE OF DIFFICULTIES ENCOUNTERED WHICH COULD HAVE BEEN FORESEEN HAD SUCH AN EXAMINATION BEEN MADE.
- D. INSTALL WORK SO AS TO BE READILY ACCESSIBLE FOR OPERATION, MAINTENANCE AND REPAIR. MINOR DEVIATIONS FROM DRAWING MAY BE MADE TO ACCOMPLISH THIS, BUT CHANGES WHICH INVOLVE EXTRA COST SHALL NOT BE MADE WITHOUT APPROVAL.
- E. REMOVAL AND RELOCATION OF CERTAIN EXISTING WORK MAY BE NECESSARY FOR THE PERFORMANCE OF THE GENERAL WORK. ALL EXISTING CONDITIONS CANNOT BE COMPLETELY DETAILED ON THE DRAWINGS. THE CONTRACTOR SHALL SURVEY THE SITE AND INCLUDE ALL CHANGES AND CHARGES IN MAKING UP THE WORK PROPOSAL.
- F. CONNECTIONS TO EXISTING WORK: INSTALL NEW WORK AND CONNECT TO EXISTING WORK WITH MINIMUM INTERFERENCE TO EXISTING FACILITIES. TEMPORARY SHUTDOWNS OF EXISTING SERVICES SHALL BE PERFORMED AT NO ADDITIONAL CHARGES. AT TIMES NOT TO INTERFERE WITH NORMAL OPERATION OF EXISTING FACILITIES AND ONLY WITH WRITTEN CONSENT OF OWNER. ALARM AND EMERGENCY SYSTEMS SHALL NOT BE INTERRUPTED. MAINTAIN CONTINUOUS OPERATION OF EXISTING FACILITIES AS REQUIRED. IF NECESSARY TEMPORARY CONDUIT AND CABLES SHALL BE USED AND EXISTING WORK CONNECT NEW WORK TO EXISTING WORK IN NEAT AND ACCEPTABLE MANNER. RESTORE EXISTING DISTURBED WORK TO ORIGINAL CONDITION, INCLUDING MAINTENANCE OF WIRING CONTINUITY AS REQUIRED.
- G. DISCONNECT, REMOVE AND/OR RELOCATE EXISTING MATERIAL, EQUIPMENT AND OTHER WORK AS NOTED OR REQUIRED FOR PROPER INSTALLATION OF NEW WORK.
- H. THE CONTRACTOR SHALL KEEP ALL EQUIPMENT AND MATERIALS, AND ALL PARTS OF THE BUILDING EXTERIOR SPACES AND ADJACENT STREETS, SIDEWALKS AND PAVEMENTS, FREE FROM MATERIAL AND DEBRIS RESULTING FROM THE EXECUTION OF THIS WORK. EXCESS MATERIALS WILL NOT BE PERMITTED TO ACCUMULATE EITHER ON THE INTERIOR OR THE EXTERIOR.
- I. SEAL OPENINGS THROUGH PARTITIONS, WALLS AND FLOORS WITH MINERAL WOOL OR OTHER NONCOMBUSTIBLE MATERIAL, UNLESS OTHERWISE NOTED.
- J. PROVIDE ALL NECESSARY FLASHING AND COUNTER FLASHING TO MAINTAIN THE WATERPROOF INTEGRITY OF THE BUILDING AS REQUIRED. BY THE INSTALLATION OR REMOVAL OF CONDUIT AND EQUIPMENT, PROVIDE EQUIPMENT CURBS AS REQUIRED.
- K. ALL EXISTING MATERIAL, EQUIPMENT AND CONSTRUCTION DEBRIS TO BE REMOVED UNDER THIS CONTRACT SHALL BECOME THE PROPERTY OF THE CONTRACTOR. IF EXCEPTED, SPECIFIED EQUIPMENT AND APPARATUS IS REQUESTED BY THE BUILDING REPRESENTATIVE, ARCHITECT OR AS NOTED TO BE RELOCATED ON THE DRAWINGS, REMOVED EQUIPMENT SHALL BE PROPERLY DISPOSED OF BY THIS CONTRACTOR.
- L. THE CONTRACTOR'S PROPOSAL FOR ALL WORK SHALL BE PREDICATED ON THE PERFORMANCE OF THE WORK DURING REGULAR WORKING HOURS AS DIRECTED. HOWEVER, THE CONTRACTOR SHALL INSTALL WORK DURING OVERTIME HOURS AND THE ADDITIONAL COST TO BE CHARGED THEREFOR SHALL BE ONLY THE "PREMIUM" PORTION OF THE WAGES PAID.
- M. UNLESS OTHERWISE SPECIFICALLY NOTED OR SPECIFIED, INCLUDE ALL CUTTING AND PATCHING OF EXISTING FLOORS, WALLS, PARTITIONS AND OTHER MATERIALS IN THE EXISTING BUILDING. THE CONTRACTOR SHALL RESTORE THESE AREAS TO ORIGINAL CONDITION.
- N. ALL MATERIAL AND EQUIPMENT SHALL BE NEW UNLESS OTHERWISE NOTED AND SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
- O. INSURANCE: PROVIDE IN ACCORDANCE WITH OWNER/BUILDING REQUIREMENTS AND SHALL INCLUDE A HOLD HARMLESS CLAUSE FOR OWNER AND ENGINEER.
- P. THE FINAL ACCEPTANCE SHALL BE MADE AFTER THE CONTRACTOR HAS ADJUSTED HIS EQUIPMENT, TESTED THE VARIOUS SYSTEMS, DEMONSTRATED THAT IT FULFILLS THE REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS AND HAS FURNISHED ALL THE REQUIRED CERTIFICATE OF INSPECTION AND APPROVAL.

2. GENERAL PROVISIONS FOR ELECTRICAL WORK:

- A. DEFINITIONS:

 - 1) "PROVIDE": TO FURNISH, INSTALL AND CONNECT UP COMPLETE AND READY FOR SAFE AND REGULAR OPERATION THE PARTICULAR WORK REFERRED TO UNLESS SPECIFICALLY OTHERWISE NOTED.
 - 2) "INSTALL": TO ERECT, MOUNT AND CONNECT COMPLETE WITH RELATED ACCESSORIES.
 - 3) "FURNISH" OR "SUPPLY": TO PURCHASE, ACQUIRE, AND DELIVER COMPLETE WITH RELATED ACCESSORIES.
 - 4) "WORK": LABOR, MATERIALS, EQUIPMENT, APPARATUS, CONTROLS, ACCESSORIES AND OTHER ITEMS REQUIRED FOR PROPER AND COMPLETE INSTALLATION.
 - 5) "WIRING": RACEWAY, FITTINGS, WIRE, BOXES, AND RELATED ITEMS.
 - 6) "CONCEALED": EMBEDDED IN MASONRY OR OTHER CONSTRUCTION, INSTALLED IN FURRED SPACES, WITHIN DOUBLE PARTITIONS OR HUNG CEILINGS, IN TRENCHES, IN CRAWL SPACES, OR IN ENCLOSURES.
 - 7) "EXPOSED": NOT INSTALLED UNDERGROUND OR "CONCEALED" AS DEFINED ABOVE.
 - 8) "SIMILAR" OR "EQUAL": EQUAL IN MATERIALS, WEIGHT, SIZE, DESIGN AND EFFICIENCY OF SPECIFIED PRODUCT.
 - B. TEMPORARY LIGHT AND POWER: PROVIDE TEMPORARY LIGHT AND POWER SYSTEMS AT EARLIEST POSSIBLE DATE WITHIN THE CONSTRUCTION AREAS FOR THE REQUIREMENTS OF ALL TRADES AS HEREIN DESCRIBED. EXTEND SYSTEMS TO NEW CONSTRUCTION AS SOON AS PHYSICALLY POSSIBLE. MAINTAIN SYSTEM DURING WORKING OWNER. PROVIDE ALL REQUIRED MAINTENANCE, INCLUDING LAMPS AND SOCKETS.
 - C. QUALITY ASSURANCE

 - 1) QUALITY OF MATERIALS: ALL EQUIPMENT SHALL BE NEW SPECIFICATION GRADE, FREE FROM DEFECTS AND LISTED BY APPROVED TESTING AGENCY AND BEARING THEIR LABELS. MATERIALS AND EQUIPMENT OF SIMILAR APPLICATION SHALL BE OF SAME MANUFACTURER, EXCEPT AS NOTED.

2) GUARANTEE: ALL MATERIALS AND WORKMANSHIP SHALL BE GUARANTEED AS DEFINED IN PARAGRAPH 2.C.

3) CURRENT CHARACTERISTICS:

- a. SERVICE: 120/208 VOLT, 3 PHASE, 4 WIRE, 60 HERTZ WITH GROUNDED NEUTRAL.
- b. DISTRIBUTION: 120/208 VOLT, 3 PHASE, 4 WIRE, 60 HERTZ WITH GROUNDED NEUTRAL.

4) HEIGHTS OF OUTLETS:

- a. FROM FINISHED FLOOR TO CENTERLINE OF OUTLETS FOR:
 - RECEPTACLES AND TELEPHONES: 1 FT-6 IN.
 - WALL SWITCHES: 4 FT-0 IN.
 - WALL FIXTURES: 7 FT-0 IN.
 - MOTOR CONTROLLERS: 5 FT-0 IN.
 - CLOCKS: 7 FT-6 IN
- b. EXCEPTIONS: AT JUNCTION OF DIFFERENT WALL FINISH MATERIALS, ON MOLDING OR BREAK IN WALL SURFACE, IN VIOLATION OF CODE, OR AS NOTED OR DIRECTED.

D. PRODUCT DELIVERY, STORAGE AND HANDLING

- 1) MOVING OF EQUIPMENT: WHERE NECESSARY, SHIP IN CARTED SECTIONS OF SIZE TO PERMIT PASSING THROUGH AVAILABLE SPACES.
- 2) ACCESSIBILITY: FOR OPERATION, MAINTENANCE AND REPAIR, MINOR DEVIATIONS SHALL BE PERMITTED. CHANGES OF MAGNITUDE OR INVOLVING EXTRA COST ARE NOT PERMISSIBLE WITHOUT REVIEW. GROUP CONCEALED ELECTRICAL EQUIPMENT REQUIRING ACCESS WITH EQUIPMENT FREELY ACCESSIBLE THROUGH ACCESS DOORS.

E. MATERIALS

- 1) NAMEPLATES: PROVIDE BLACK LAMICOID SHEET WITH 3/4 IN. WHITE LETTERING FASTENED WITH EPOXY CEMENT FOR EACH DISCONNECT SWITCH, CIRCUIT BREAKER, PANEL, CABINET, TRANSFORMER, ENCLOSURE, MOTOR CONTROLLER AND THE LIKE. NAMEPLATES SHALL DESCRIBE THE NAME AND NUMBER OF EACH COMPONENT.
- 2) CABLE TAGS: TAG EACH CONDUCTOR PASSING THROUGH SPLICE OR PULL BOX WITH A WHITE LINEN TAG, INDICATING POINT OF ORIGIN AND TERMINATION OF THE CIRCUIT.
- 3) INSERTS AND SUPPORTS:
 - a. INSERTS: STEEL, SLOTTED TYPE, FACTORY PAINTED.
 - SINGLE ROD: SIMILAR TO GRINNELL FIG. 281.
 - MULTI-ROD: SIMILAR TO FEE AND MASON SERIES 9000 WITH END CAPS AND CLOSURE STRIPS.
 - CLIP FORM NAILS FLUSH WITH INSERTS.
 - MAXIMUM LOADING 75 PERCENT OF RATING.
 - b. SUPPORTS FROM BUILDING CONSTRUCTION: INSERTS, BEAM CLAMPS, STEEL FISHPLATES (IN CONCRETE FILL ONLY), CANTILEVER BRACKETS OR OTHER MEANS. SUBMIT FOR REVIEW.
 - c. GROUPED LINES AND SERVICES: TRAPEZE HANGERS OF BOLTED ANGLES OR CHANNELS.
 - d. WHERE BUILDING CONSTRUCTION IS INADEQUATE: PROVIDE ADDITIONAL FRAMING. SUBMIT FOR REVIEW.
- 4) PAINT SHALL BE THE BEST GRADE FOR ITS PURPOSE, DELIVER IN ORIGINAL SEALED CONTAINERS AND APPLY IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS. COLORS SHALL BE AS SELECTED BY ARCHITECT OR ENGINEER. UTILIZE GALVANIZED IRON PRIMER ON PANEL AND PULL BOXES, AFTER FABRICATION, UTILIZE HOT DIPPED GALVANIZED OR DIPPED IN ZINC BASED PRIMER FOR: OUTLET BOXES, JUNCTION BOXES, CONDUIT HANGERS, RODS, INSERTS AND SUPPORTS. ZINC BASED PRIMER WITH FINISH TO MATCH SURROUNDINGS SHALL BE USED FOR MARRED SURFACES OF STEEL EQUIPMENT AND RACEWAYS. A FIELD-APPLIED ZINC BASED PRIME COAT SHALL BE UTILIZED FOR STEEL OR IRONWORK.
- 5) BRUSH AND CLEAN WORK PRIOR TO CONCEALING, PAINTING AND ACCEPTANCE. PAINTED EXPOSED WORK SOILED OR DAMAGED; CLEAN AND REPAIR TO MATCH ADJOINING WORK BEFORE FINAL ACCEPTANCE. REMOVE DEBRIS FROM INSIDE AND OUTSIDE OF MATERIAL AND EQUIPMENT.
- 6) FINAL LOCATIONS AND MOUNTING ORIENTATIONS OF ALL SWITCHES, RECEPTACLES AND LIGHT FIXTURES SHALL BE VERIFIED WITH ARCHITECT.
- 7) ALL ACCESS DOOR LOCATIONS SHALL BE REVIEWED BY ARCHITECT PRIOR TO INSTALLATION.

3. SCOPE OF WORK:

- A. SCOPE OF WORK SHALL CONSIST OF PROVIDING LABOR, MATERIALS, EQUIPMENT, SERVICES AND FEES NECESSARY FOR COMPLETE AND SAFE INSTALLATION IN CONFORMITY WITH THE NATIONAL ELECTRICAL CODE, AND ALL OTHER APPLICABLE INDUSTRY, NATIONAL AND LOCAL CODES AND STANDARDS HAVING JURISDICTION, AS INDICATED ON DRAWINGS AND HEREIN SPECIFIED.
- B. ALL DRAWINGS, PLANS, DETAILS, SPECIFICATIONS AND SPECIFICATION ADDENDA ARE MADE PART OF THIS CONTRACT AND SHALL APPLY TO ALL WORK UNDER THE CONTRACT UNLESS OTHERWISE AMENDED, MODIFIED, SUPPLIED OR SPECIFIED HEREIN.
- C. THE CONTRACTOR SHALL FURNISH A WRITTEN GUARANTEE TO REPLACE OR REPAIR PROMPTLY AND ASSUME RESPONSIBILITY FOR ALL EXPENSES INCURRED FOR ANY WORKMANSHIP AND EQUIPMENT IN WHICH DEFECTS DEVELOP WITHIN ONE YEAR FROM THE DATE OF FINAL CERTIFICATE FOR PAYMENT AND/OR FROM DATE OF ACTUAL USE OF EQUIPMENT OR OCCUPANCY OF SPACES BY OWNER. INCLUDED IN THE GUARANTEE IS THE WORK TO BE DONE, WHICHEVER DATE IS EARLIER. THIS WORK SHALL BE DONE AS DIRECTED BY THE OWNER. THIS GUARANTEE SHALL ALSO PROVIDED THAT WHERE DEFECTS OCCUR, THE CONTRACTOR WILL ASSUME RESPONSIBILITY OF OTHER TRADES AFFECTED BY DEFECTS, REPAIR OR REPLACEMENTS IN EQUIPMENT SUPPLIED BY THE CONTRACTOR.
- D. THE CONTRACTOR SHALL GIVE NECESSARY NOTICE, FILE DRAWINGS AND SPECIFICATIONS WITH ALL DEPARTMENTS HAVING JURISDICTION, WORK AND PAY ALL FEES THEREFORE. THE CONTRACTOR SHALL ARRANGE FOR INSPECTION AND TESTS OF ANY OR ALL PARTS OF THE WORK IF SO REQUIRED BY AUTHORITIES AND PAY ALL CHARGES FOR SAME. THE CONTRACTOR SHALL PAY ALL COSTS FOR AND FURNISH NECESSARY AS EQUIPMENT THAT THE WORK INSTALLED CONFORMS WITH ALL REGULATIONS WHERE THEY APPLY TO THIS WORK.
- E. CONTRACTOR SHALL PERFORM ALL CONTROLLED INSPECTIONS IN ACCORDANCE WITH THE BUILDING CODE. SECURE ALL REQUIRED PERMITS AND APPROVALS AND TRANSMIT SAME TO OWNER. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL FEES.
- F. AREAS WITH NO ELECTRICAL WORK SHALL REMAIN AS IS. CONTRACTOR SHALL MAINTAIN CONTINUITY OF ALL ELECTRICAL SYSTEMS TO ALL AREAS NOT COVERED BY THIS RENOVATION AND SHALL PROVIDE 48 HOUR NOTICE TO LANDLORD OF ANY PLANNED POWER INTERRUPTIONS OR SIGNAL SYSTEM OUTAGES.

4. SHOP DRAWINGS

- A. PRIOR TO THE INSTALLATION OF ANY WORK AND PROCUREMENT OF EQUIPMENT, CONTRACTOR SHALL PROVIDE COMPLETE SETS OF COORDINATED SHOP DRAWINGS OF ALL NEW AND EXISTING EQUIPMENT, INDICATING CAPACITY, DIMENSIONS AND SEQUENCE OF OPERATION FOR WRITTEN APPROVAL BY THE ARCHITECT AND ENGINEER.
- B. INDICATE ON EACH SHOP DRAWINGS SUBMITTED:
 - 1) PROJECT NAME AND LOCATION
 - 2) NAME OF ARCHITECT AND ENGINEER
 - 3) ITEM IDENTIFICATION
 - 4) APPROVAL STAMP OF PRIME CONTRACTOR
- C. SUBMISSIONS:
 - 1) SUBMISSIONS 11 IN. X 17 IN. OR SMALLER: IF THE SUBMISSION IS A CATALOG CUT, THEN THE CONTRACTOR SHALL SUBMIT ONE ORIGINAL AND TWO COPIES. OTHERWISE, HE SHALL SUBMIT THREE COPIES. THE ARCHITECT WILL FORWARD THE ORIGINAL AND ONE COPY (TWO COPIES WHEN NO ORIGINAL IS RECEIVED) TO THE ENGINEER. ALL CATALOG CUTS SHALL BE COMPLETE.
 - 2) SUBMISSIONS LARGER THAN 11 IN. X 17 IN.: SUBMIT TWO PRINTS AND ONE PAPER SEPIA TO THE ARCHITECT. THE ARCHITECT WILL FORWARD ONE PRINT AND THE PAPER SEPIA TO THE ENGINEER.
- D. SUBMIT SHOP DRAWINGS FOR THE FOLLOWING:
 - 1) SAFETY/DISCONNECT SWITCHES
 - 2) FUSES
 - 3) CIRCUIT BREAKERS
 - 4) PANEL BOARDS/LOAD CENTER (INCLUDING DIMENSIONS, SCHEDULES, AND CATALOG CUTS).
 - 5) RACEWAYS
 - 6) WIRE AND CABLE
 - 7) WALL SWITCHES
 - 8) INSERTION RECEPTACLES
 - 9) MOMENTARY CONTACT SWITCHES
 - 10) TIME SWITCHES
 - 11) LIGHTING FIXTURES.
- E. ASSIST AND PROVIDE ALL NECESSARY INFORMATION, DIAGRAMS, SKETCHES, ETC. TO THE HVAC CONTRACTOR, FOR THE PREPARATION OF COORDINATED SHOP DRAWINGS INDICATING ROUTING OF FEEDERS, CONTROL CONDUITS, RECESSED FIXTURES AND ADJACENT NEARBY PIPING AND DUCTWORK WHERE APPLICABLE, CERTIFIED BY ALL TRADES AND APPROVED BY THE CONTRACTOR. SUBMIT ONE (1) COPY (FOUR) BOOKBOUND OPERATING AND SERVICE MANUALS WHICH SHALL INCLUDE COPIES OF ALL SHOP DRAWINGS, PROVIDE SHOP DRAWINGS FOR PANELS, FIXTURES, WIRING DEVICES, CONDUIT, CABLE, DISCONNECT SWITCH, RELAYS, CONTRACTORS, AND OTHER SYSTEMS AS DIRECTED BY THE ENGINEER.
- F. AS-BUILT DRAWINGS AND EQUIPMENT OPERATIONAL INSTRUCTIONS

 - A. UPON COMPLETION AND ACCEPTANCE OF WORK, CONTRACTOR SHALL FURNISH WRITTEN INSTRUCTIONS AND EQUIPMENT MANUALS AND DEMONSTRATE TO THE OWNER THE PROPER OPERATION AND MAINTENANCE OF ALL EQUIPMENT AND APPARATUS FURNISHED UNDER THIS CONTRACT.
 - B. THESE INSTRUCTIONS SHALL BE TYPED ON 8-1/2 IN. X 11 IN. PAPER, AND BOUND IN THREE-RING BINDERS WITH CLEAR ACETATE COVERS. CONTRACTOR SHALL GIVE THREE COPIES OF THE INSTRUCTIONS TO THE OWNER AND ONE COPY TO THE ENGINEER.
 - C. THE INSTRUCTION BOOKLET SHALL BEAR THE NAME, ADDRESS AND TELEPHONE NUMBER OF THE PROJECT, ARCHITECT AND ENGINEER.
 - D. REPRODUCIBLE "AS-BUILT" DRAWINGS SHALL BE PROVIDED INDICATING THE AS INSTALLED CONDITIONS OF THE WORK. "AS-BUILT" DRAWINGS SHALL BE PROVIDED TO THE ARCHITECT AFTER COMPLETION OF THE INSTALLATION.

- G. LOW-VOLTAGE DISTRIBUTION EQUIPMENT:

 - A. PROVIDE COMPLETE EQUIPMENT INCLUDING: SWITCHES, FUSES, CIRCUIT BREAKERS, PANELS AND TRANSFORMERS.
 - B. ALL EQUIPMENT SHALL CONFORM TO NEMA, ANSI AND IEEE STANDARDS.
 - C. DISCONNECT SWITCHES SHALL BE FUSED OR NONFUSED AS NOTED. VOLTAGE SHALL BE AS REQUIRED. SWITCHES SHALL BE HEAVY DUTY, EXCEPT AS NOTED. LOAD-SIDE SWITCHES SHALL BE NONFUSED, LOAD-BREAK,AVING MAXIMUM RATINGS OF 20 AMP AT 600 VOLTS AND 30 AMP AT 240 VOLTS. TWO-POLE SWITCHES SHALL BE SIMILAR TO HART AND HEGEMAN NO. 6808F. THREE-POLE SWITCHES SHALL BE SIMILAR TO HART AND HEGEMAN NO. 7810F. KNIFE-BLADE TYPE SWITCHES SHALL BE LOAD BREAK, QUICK-MAKE-QUICK-BREAK, UL CLASS R UP TO 600 VOLTS, MAXIMUM RATING EXCEPT AS NOTED, SHALL BE 800 AMP. ALL CIRCUIT BREAKERS SHALL BE PROVIDED. SWITCHES SHALL BE SIMILAR TO GENERAL ELECTRIC QMR. ALL SWITCH ENCLOSURES SHALL BE DEAD FRONT, NEMA TYPE 1, EXCEPT AS NOTED.

- H. FUSES:

 - A. CIRCUITS 0 TO 600 AMPERES SHALL BE PROTECTED BY FUSES SIMILAR TO CURRENT LIMITING BUSSMAN LOW-PEAK DUAL-ELEMENT TIME-DELAY LPN-RK (AMPISP (250V) /LPS-RK (AMPISP (600V) OR LPJ (AMPISP (600V) UL CLASS RK1 OR CLASS J), AND BE LISTED BY UL WITH AN INTERRUPTING RATING OF 300,000 AMPERES RMS SYMMETRICAL.
 - B. MOTOR CIRCUITS - ALL INDIVIDUAL MOTOR CIRCUITS WITH FULL LOAD AMPERE RATINGS (FOL) OF 400 AMPERES OR LESS SHALL BE PROTECTED BY FUSE SIMILAR TO CURRENT LIMITING BUSSMANN LOW-PEAK DUAL-ELEMENT TIME-DELAY LPN-RK (AMPISP (250V) /LPS-RK (AMPISP (600V) OR LPJ (AMPISP (600V) UL CLASS RK1 OR CLASS J), AND BE LISTED BY UL WITH AN INTERRUPTING RATING OF 300,000 AMPERES RMS SYMMETRICAL.
 - C. ALL FUSES SHALL BE PROVIDED BY SAME MANUFACTURER.
 - D. PROVIDE 1 SPACE MATCHING FUSE FOR EACH SET OF 3.
 - E. CIRCUIT BREAKERS: MOLDED CASE BREAKERS SHALL BE THERMAL-MAGNETIC, QUICK-MAKE-QUICK-BREAK, BOLT-ON TYPE, MANUALLY OPERATED WITH INSULATED TRIP-FREE HANDLE. MULTI-POLE TYPE BREAKERS SHALL CONTAIN INTERNAL TRIP BAR. TERMINALS SHALL BE SUITABLY COATED ON INSULATED CABLE. FURNISH AUXILIARY DEVICES WHERE REQUIRED FOR SHUNT-TRIPPING, OPEN AND CLOSE MOTOR OPERATOR, AND ALARM INDICATION. ENCLOSURES SHALL BE DEAD FRONT, NEMA TYPE 1, EXCEPT AS NOTED. FRAMES, IC AND INTERCHANGEABLE TRIPS SHALL BE AS FOLLOWS, UNLESS OTHERWISE NOTED:
 - 1) 120 VOLTS, 100-AMP FRAME: 10,000 AMPS, 1 POLE.
 - 2) 120/208 VOLTS, 225-AMP FRAME: 22,000 AMPS MINIMUM

8. DISTRIBUTION PANELBOARDS, CIRCUIT BREAKER TYPE:

- A. THREE PHASE, 4 OR 5 WIRE, COPPER BUS BARS, WITH 2, 3, OR 4 WIRE BRANCHES, AS NOTED. CAPACITY OF PANEL AND CIRCUITS, AS NOTED BELOW. PANELBOARD TO HAVE GROUND BUS SAME SIZE AS PHASE BUSES.
- B. CABINETS: CODE GAUGE GALVANIZED SHEET STEEL PRIMED AND PAINTED WITH TRIM AND DOOR, TYPE AS NOTED, LAP AND RIVET CORNERS OR FORM AS APPROVED.
- C. TRIM: ONE PIECE FULL FINISH PRIMED AND PAINTED SHEET STEEL. TRIM SHALL BE MOUNTED WITH A CONTINUOUS PIANO HINGE CONFIGURED IN SUCH A MANNER THAT IT SHALL BE POSSIBLE TO GAIN FULL ACCESS TO CIRCUIT BREAKERS AND WIRING GUTTERS WITHOUT REMOVING THE TRIM. PROVIDE A MULTI-PIN CYLINDER LOCK (YALE, CORBIN OR EQUAL) TO LATCH THE TRIM. KEYS SHALL BE MILLED.
- D. HARDWARE: MULTI-PIN, CYLINDER LOCKS WITH MILLED KEYS. ALL PANELS SHALL BE KEYED ALIKE. DOOR OVER 48" HIGH SHALL BE EQUIPPED WITH A CHROME PLATED VAULT HANDLE, BUILT-IN LOCK AND 3-POINT CATCH FASTENING DOOR AT TOP, BOTTOM AND CENTER.
- E. HINGES: CONCEALED, CONTINUOUS PIANO HINGE AS DESCRIBED ABOVE.
- F. DIRECTORY HOLDER: MEAL FRAME WITH NONBREAKABLE TRANSPARENT COVER AND DIRECTORY CARD. ENTRIES TO BE TYPEWRITTEN BY ELECTRICAL CONTRACTOR. PROVIDE AN ENGRAVED LAMINATED NAMEPLATE ADJACENT TO EACH BRANCH BREAKER. MOUNT WITH SELF-TAPPING MACHINE SCREWS.
- G. FURNISH MULTI-CABLE LUGS WHERE REQUIRED. DOUBLE LUGGING NOT PERMITTED. SECURE LUGS TO BUSES BY STUD BOLTS.
- H. PANELBOARD CONSTRUCTION FOR BOLTED TYPE BREAKERS. MINIMUM SHORT CIRCUIT RATING 25,000 AMPERES, RMS SYMMETRICAL FOR ALL 120/208V APPLICATIONS. INDIVIDUAL CIRCUIT BREAKERS SHALL HAVE MINIMUM 100A FRAME, TRIPS SIZED AS SHOWN ON THE PLANS.
- I. MINIMUM GUTTER SPACES: PANELS WITH 225 AMPERE MAINS, 5-1/2" MINIMUM, 400 AMPERES AND OVER, MINIMUM GUTTER 8-1/2" FOR PANELS WITH THROUGH FEEDERS. INCREASE GUTTER WIDTH BY 2" MINIMUM AND ADD SHEET STEEL SPACER BARRIERS BETWEEN THE PANEL AND FEEDER. THROUGH FEEDER POSITION OF THE BACK BOX. BRANCH CIRCUIT BREAKERS SHALL BE MECHANICALLY INTERLOCKED WHEN SHOWN ON DRAWINGS.
- J. DISTRIBUTION AND SUB-DISTRIBUTION PANELBOARDS SHALL BE A MINIMUM OF 30" WIDE AND 10" DEEP.
- K. PANELBOARD SHALL HAVE MAIN CIRCUIT BREAKER OR MAIN LUGS AS INDICATED ON THE DRAWINGS. QUANTITY, POLES AND TRIP RATINGS OF BRANCH CIRCUIT BREAKERS TO BE AS INDICATED ON DRAWINGS.
- L. PANELBOARD SHALL HAVE ENGRAVED WHITE CORE, BLACK LAMACOID NAMEPLATE SCREWED ONTO PANE TRIM WITH DESIGNATION LISTED (PANELBOARD NAME, VOLTAGE, RATING OR MAINS IN AMPS).

9. DISTRIBUTION PANELBOARDS, SWITCH AND FUSE:

- A. THREE PHASE, 3 OR 4 WIRE WITH COPPER BUS BARS. ALL THROUGH BUS SHALL BE INSULATED.
- B. NEMA CLASS 1 CONSTRUCTION TO ACCOMMODATE FUSIBLE, INDIVIDUALLY ENCLOSED SWITCHES, FRONT REMOVABLE, SWITCH AND DOOR INTERLOCKS. COVERS TO BE PAD-LOCKABLE.
- C. PANELBOARD SHALL BE CONSTRUCTED OF CODE-GAUGE STEEL, GRAY FINISH OVER RUST INHIBITOR, FOR SURFACE MOUNTING. BOX AND PANEL FRAME SHALL BE FLANGED AND REINFORCED FOR RIGID SUPPORT OF INTERIOR AND ACCURATE ALIGNMENT OF INTERIOR WITH FRONT TRIMS TO BE FASTENED TO BACK BOX WITH SCREWS.
- D. ALL BRANCH SWITCHES SHALL HAVE INDIVIDUAL ENGRAVED LAMACOID NAMEPLATES (BLACK WITH WHITE CORE).
- E. DISTRIBUTION PANELBOARD CONSTRUCTION MINIMUM SHORT CIRCUIT RATING 25,000 AMPERES, RMS SYMMETRICAL FOR ALL 120/208V APPLICATIONS.
- F. DISCONNECTS

 - 1) DISCONNECT SWITCHES SHALL CONFORM TO NEMA AND UL STANDARDS, AND SHALL BE HORSEPOWER RATED.
 - 2) SWITCHING MECHANISM SHALL BE QUICK-MAKE, QUICK-BREAK, SINGLE THROW WITH EXTERNAL OPERATING HANDLE MECHANICALLY INTERLOCKED WITH ENCLOSURE COVER TO PROVIDE ACCESS TO INTERIOR WHEN DISCONNECT IS IN OFF POSITION ONLY. PROVIDE MEANS TO EACH OPERATING HANDLE TO OPEN AND CLOSE POSITION. DESIGNATE ON THE ENCLOSURE THE OPEN AND CLOSED POSITION OF THE OPERATING HANDLE.
 - 3) SWITCHES SHALL BE OF THE DOUBLE STATIONARY CONTACT TYPE.
 - 4) SWITCHES SHALL BE EQUIPPED WITH REJECTION TYPE FUSE HOLDERS, FUSIBLE, AS SHOWN ON THE DRAWINGS; PROVIDE COMPLETE WITH FUSES AS SCHEDULED.

- G. INSTALLATION

 - 1) DISTRIBUTION PANELBOARD SHALL BE MOUNTED TO STRUCTURAL STEEL CHANNEL (KINDOF) WHICH SHALL BE BOLTED TO THE WALL USING EXPANSION ANCHORS FOR LARGE PANELS.

H. IDENTIFICATION

 - 1) PROVIDE NAMEPLATE AT EACH SWITCH IDENTIFYING THE LOAD SERVED.
 - 2) NAMEPLATES SHALL BE MOUNTED ON THE FRONT COVER SECURED WITH SELF-TAPPING SCREWS OR NUTS AND BOLTS. NAMEPLATES SHALL BE LAMINATED PHENOLIC, BLACK WITH A MINIMUM OF 1/4" HIGH WHITE LETTERING.

I. DISTRIBUTION AND SUB-DISTRIBUTION PANELBOARDS SHALL BE A MINIMUM OF 30" WIDE AND 10" DEEP.

J. POWER PANELBOARDS SHALL BE SIMILAR TO GENERAL ELECTRIC TYPE "OMR", AS MANUFACTURED BY ATLAS SWITCH COMPANY, ELECTRIC SWITCHBOARD COMPANY OR APPROVED EQUAL.

K. PANELBOARD SHALL HAVE MAIN CIRCUIT BREAKER OR MAIN LUGS AS INDICATED ON THE DRAWINGS. QUANTITY, POLES AND TRIP RATINGS OF BRANCH CIRCUIT BREAKERS TO BE AS INDICATED ON DRAWINGS.

L. PANELBOARD SHALL HAVE ENGRAVED WHITE CORE, BLACK LAMACOID NAMEPLATE SCREWED ONTO PANE TRIM WITH DESIGNATION LISTED (PANELBOARD NAME, VOLTAGE, RATING OR MAINS IN AMPS).

B. MATERIALS

 - 1) RACEWAYS:
 - a. RIGID STEEL CONDUIT: FULL-WEIGHT PIPE, GALVANIZED, THREADED.
 - b. ELECTRO-METALIC TUBING (EMT): THIN WALL PIPE, GALVANIZED, THREADLESS.
 - c. FLEXIBLE STEEL CONDUIT: CONTINUOUS SINGLE STRIP, GALVANIZED.
 - d. WIRE-WAYS: WIRE SHALL BE AS NOTED, MINIMUM NO. 16 GAUGE STEEL CONDUIT WITH GROUND CONTINUITY. FINISH SHALL BE BAKED ENAMEL. COVERS SHALL BE SCREW-ON.
 - e. SURFACE METAL RACEWAY: SIZE AS NOTED. BASE 0.04 IN., COVER 0.25 IN. MATERIAL SHALL BE STEEL. FINISH SHALL BE BAKED ENAMEL. COVERS SHALL BE SCREW-ON.

FAZOLI'S, KISSIMMEE, FL
ISSUE DATE:
DRAWN BY:
QAQC:
APPROVED BY:
PROJECT NUMBER:
ELECTRICAL SPECIFICATIONS
SHEET 1 OF 2
EO.2

ELECTRICAL SPECIFICATIONS (CONT.)

3) BOXES:

a. OUTLET BOXES: EXCEPT AS OTHERWISE REQUIRED BY CONSTRUCTION, DEVICES OR WIRING, BOXES SHALL BE STAMPED STEEL, 4 IN. SQUARE OR OCTAGON FOR FIXTURES. BOXES ABOVE CEILING SHALL BE 1-1/2 IN. DEEP. BOXES IN CEILING OR SLAB SHALL BE 3 IN. DEEP. BOXES IN WALL FOR FIXTURES SHALL BE 2-3/4 IN. DEEP. BOXES IN WALL FOR RECEPTACLES AND SWITCHES SHALL BE 1-1/2 IN. DEEP. FURNISH WITH RAISED COVERS AND FIXTURE STUDS WHERE REQUIRED. WITHOUT FIXTURE OR DEVICE, FURNISH BLANK COVER. OFFSET BACK-TO-BACK OUTLETS WITH MINIMUM 6 IN. SEPARATION.

b. JUNCTION AND PULL BOXES: GALVANIZED SHEET STEEL WITH SCREW-ON COVERS, EXCEPT AS NOTED. FURNISH WITH INSULATED SUPPORTS FOR CABLES. LOCATIONS SHALL BE AS NOTED OR REQUIRED AND ACCESSIBLE. PROVIDE BARRIERS IN NEW AND RENOVATED BOXES BETWEEN 120/208 VOLT AND 265/460 VOLT WIRING AND BETWEEN EMERGENCY AND NORMAL WIRING. FLOOR BOXES SHALL BE SUITABLE FOR CONDUIT AND DEVICES NOTED. RAISED OUTLETS SHALL BE HUBBELL #B2414 SERIES WITH ABOVE FLOOR FITTING. TELEPHONE: BUSHED HOLE. POWER: DUPLEX RECEPTACLE OR OTHER AS NOTED. INCREASE SIZE TO SUIT AS NECESSARY. FLUSH OUTLETS SHALL BE HUBBELL #B2414 SERIES WITH FLUSH FLOOR FITTING FOR TELEPHONE AND FLUSH DUAL FLAT COVER WITH DUPLEX RECEPTACLE FOR POWER AS NOTED. INCREASE SIZE TO SUIT AS NECESSARY.

c. PROVIDE RACEWAYS ONLY AS HEREIN SPECIFIED, EXCEPT AS NOTED. RACEWAYS SHALL BE RUN CONCEALED, EXCEPT AS NOTED.

PROVIDE RACEWAY SUPPORT UTILIZING CEILING TRAPEZE, STRAP HANGERS, OR WALL BRACKETS. PROVIDE U-BOLTS AT EACH FLOOR LEVEL OF RISER RACEWAYS AND CONNECTED TO ACCEPTABLE SUPPORT. PROVIDE RISER CLAMPS AT EACH FLOOR LEVEL OF RISER RACEWAYS AND RESTING ON SLAB. FOR THROUGH-THE-FLOOR SYSTEMS, UTILIZE AN ASSEMBLY SIMILAR TO HUBBELL FIRE RATED POKE-THROUGH-FLOOR BOX SYSTEM. FOR ABOVE FLOOR FITTINGS, TELEPHONE SHALL BE BUSHED HOLE AND POWER SHALL BE DUPLEX RECEPTACLE OR OTHER AS NOTED. PROVIDE SEPARATION BARRIER BETWEEN POWER AND TELEPHONE COMPARTMENTS. PROVIDE JUNCTION BOX ON UNDERSIDE OF FLOOR. PACK FITTING TO RESTORE FIRE RATING OF FLOOR.

SECURE ALL RACEWAYS TO SUPPORTS WITH PIPE STRAPS OR U-BOLTS. SPACING OF SUPPORTS SHALL BE A MINIMUM OF 10 FT ON CENTER FOR METALLIC RACEWAY AND AS REQUIRED FOR NONMETALLIC RACEWAY. SPACING SHALL BE 5 FT ON CENTER FOR WIREWAYS AND PER CODE AND AS NOTED FOR OTHERS. MOUNT SUPPORTS TO STRUCTURE MASONRY WITH TOGGLE BOLTS OR HOLLOW MASONRY EXPANSION SHELLS OR INSERTS. COMPRESS BRICK, MASONRY, WOOD SCREWS ON METAL BEAM CLAMPS. ON FERROCONCRETE, WOOD SCREWS ON WOOD, AND PAN THROUGH STRAPS IN METAL DECK NAILS, RAWL PLUGS OR WOOD PLUGS SHALL NOT BE PERMITTED. WHERE REQUIRED BY STRUCTURE, FURNISH THROUGH BOLTS AND FISHPLATES.

EXPOSED RACEWAYS SHALL BE RUN PARALLEL WITH OR AT RIGHT ANGLES TO WALLS. PROVIDE CLEARANCE WITH WATER, STEAM OR OTHER PIPING (MINIMUM 3 IN. SEPARATION FROM STEAM AND HOT WATER PIPES, EXCEPT 1 IN. FROM PIPE COVER AT CROSSINGS AND 18 IN. FOR PARALLEL RUNS). FOR HUNG CEILING OUTLETS, RUN IN HUNG CEILING AND CONNECT TO CEILING SUPPORT CHANNELS. IN MASONRY AND Poured CONCRETE, RUN VERTICALLY ONLY.

MANTAIN GROUNDING CONTINUITY OF INTERRUPTED METALLIC RACEWAYS WITH GROUND CONDUCTOR, AND IN FLEXIBLE CONDUIT FOR FEEDERS AND MOTOR TERMINAL CONNECTIONS.

EMPTY RACEWAYS OVER 10 FT LONG: PROVIDE FISH OR PULL WIRE, GALVANIZED OR NYLON ROPE.

RIGID STEEL CONDUIT SHALL BE PERMITTED FOR FEEDERS AND BRANCH CIRCUITS. PAINT MALE THREADS OF FLAT-THREADED CONDUIT WITH GRAPHITE-BASE PIPE COMPOUND AND BUTT CONDUIT ENDS TO CUP UP MARRED SURFACES AND FILED-CUT THREADS. CRC-COLD GALVANIZED EMT SHALL BE PERMITTED FOR BRANCH CIRCUITS ONLY. IN DRY LOCATIONS, DRY WALLS, HUNG CEILINGS, HOLLOW BLOCK WALLS AND FURRED SPACES. EMT SHALL NOT BE PERMITTED IN RAISED FLOORS.

RIGID STEEL CONDUIT SHALL BE UTILIZED FOR SHORT CONNECTIONS WHERE RIGID CONDUIT IS IMPRACTICAL. FROM OUTLET BOX TO RECESSED LIGHTING FIXTURE: PROVIDE MINIMUM 4 FT AND MAXIMUM 6 FT LENGTHS. FOR FINAL CONNECTION TO MOTOR TERMINAL BOX, TRANSFORMER AND OTHER VIBRATING EQUIPMENT: PROVIDE WITH POLYVINYL SHEATHING AND GROUND CONDUCTOR. MINIMUM LENGTH: 18 IN. WITH SLACK. CONNECT GROUND CONDUCTOR TO ENCLOSURE OR RACEWAY AT EACH END. FOR EXPANSION JOINT CROSSINGS, CROSS AT RIGHT ANGLES AND ANCHOR ENDS.

CUT CONDUIT ENDS SQUARE. REAM SMOOTH. PAINT MALE THREADS OF FIELD THREADED RACEWAYS WITH GRAPHITE BASE PIPE COMPOUND. DRAW UP TIGHT WITH RACEWAY COUPLING.

ALL COUPLINGS SHALL BE COMPRESSION TYPE. NO SET SCREW FITTINGS.

EXPANSION FITTINGS SHALL BE INSTALLED AT RIGHT ANGLES WITH CLIP JOINT CENTERED IN EXPANSION JOINT. PROVIDE A LENGTH OF RUN IN ACCORDANCE MANUFACTURER'S RECOMMENDATIONS. PRESET FITTINGS SHALL ALLOW FOR TEMPERATURE VARIATION.

RACEWAYS PASSING THROUGH FIRE-RATED CONSTRUCTION: SEAL OPENING WITH FIRE SEALANT.

D. PROVIDE CABLE SUPPORTS IN ACCORDANCE WITH NATIONAL ELECTRIC CODE ARTICLE 300.19. CABLE SUPPORTS SHALL UTILIZE A ONE-PIECE PLUG WITH POZI-GRIP WEDGING PLUG AS MANUFACTURED BY OZ-GEDNEY. TYPE SF SHALL BE USED FOR ARMORED CABLE.

INSTALL CABLE SUPPORTS AT THE TOP OF A VERTICAL RISE AND PROVIDE INTERMEDIATE ADDITIONAL SUPPORTS AS REQUIRED TO LIMIT SUPPORTED CONDUCTOR LENGTHS TO NOT GREATER THAN THOSE SPECIFIED IN TABLE 300.19(A).

A. ERECT WALL AND SWITCH OUTLETS IN ADVANCE OF FURRING AND FIREPROOFING. OUTLET BOXES SHALL BE SET SQUARE AND TRUE WITH BUILDING FINISH. SECURE TO BUILDING STRUCTURE BY ADJUSTABLE STRAP, IRON OR GROUT IN WITH MASONRY. VERIFY OUTLET LOCATIONS IN FINISHED SPACES WITH ARCHITECTURAL DRAWINGS OF INTERIOR DETAILS AND FINISHES. PROVIDE BARRIERS BETWEEN SWITCHES CONNECTED TO DIFFERENT PHASES FOR VOLTAGES EXCEEDING 150 VOLTS TO GROUND.

10. WIRING DEVICES:

A. WIRING DEVICES SHALL BE SPECIFICATION GRADE UNLESS OTHERWISE SPECIFIED. ALL DEVICES SHALL BE FLUSH MOUNTED, UNLESS OTHERWISE NOTED. PROVIDE COMPLETE MATERIAL AND ACCESSORIES AS NOTED.

B. LOCAL WALL SWITCHES SHALL BE ROCKER TYPE, QUIET OPERATING, RATED 20 AMP, 120/277 VOLT, AC, SIMILAR TO LEVITON DECORA SERIES A5621 (SINGLE POLE), A5623 (3-WAY) AND A5624 (4-WAY).

C. STRAIGHT BLADE RECEPTACLES SHALL BE COMMERCIAL SPECIFICATION GRADE DUPLEX CONVENIENCE 125 VOLTS, 2 POLE, 3 WIRE, U GROUND SLOT, DECORA SERIES BY LEVITON. GROUNDED, EXCEPT AS NOTED.

1) SINGLE GANG, RECESSED, DUPLEX RECEPTACLE: TAMPER RESISTANT, 2-POLE, 3-WIRE GROUNDING, 15A, 125V, NEMA 5-20; LEVITON 689 SERIES (COLOR AS SPECIFIED BY ARCHITECT).

2) USB CHARGER/ DUPLEX TAMPER-RESISTANT RECEPTACLE: TAMPER RESISTANT,

11. LIGHTING FIXTURES:

A. FIXTURES TO BE AS SPECIFIED BY ARCHITECT AND SHALL BE COMPLETELY FACTORY ASSEMBLED, WIRED AND EQUIPPED WITH ALL NECESSARY SOCKETS, BALLASTS, SUPPORTING HARDWARE AND ACCESSORIES. REFER TO DRAWINGS FOR INDIVIDUAL FIXTURE DESCRIPTIONS.

B. FIXTURE CATALOG NUMBERS USED TO ILLUSTRATE EQUIPMENT TYPE DO NOT NECESSARILY DENOTE REQUIRED MOUNTING EQUIPMENT OR ACCESSORIES. PROVIDE ACCESSORIES TO SUIT.

C. BALLAST: CLASS P, HIGH POWER FACTOR, LOWEST AVAILABLE NEMA RATED NOISE LEVEL, ETI AND CBM APPROVED. ENERGY SAVING TYPE, TRIGGER START FOR 24-INCH LAMPS AND RAPID START FOR 48-INCH, TWO LAMP BALLASTS; NO THREE LAMP BALLASTS. BALLASTS SHALL BE ADVANCE MAGNETEK, UNIVERSAL OR EQUAL.

D. LED DRIVERS SHALL BE ELECTRONIC TYPE, LABELED AS COMPLIANT WITH RADIO FREQUENCY INTERFERENCE (RFI) REQUIREMENTS OF FCC TITLE 47, PART 15 AND COMPLY WITH NEMA SSL-1 "ELECTRONIC DRIVERS FOR LED DEVICES, ARRAYS OR SYSTEMS". LED DRIVERS SHALL HAVE A SOUND RATING OF "A", HAVE A MINIMUM EFFICIENCY OF 85% AND BE RATED FOR A THD OF LESS THAN 20% AT ALL INPUT VOLTAGES.

E. DIMMABLE LED DRIVERS SHALL BE CAPABLE OF DIMMING WITHOUT LED STROBING OR FLICKER ACROSS THEIR FULL DIMMING RANGE. PROVIDE TYPE OF LED DRIVER AS PER LIGHTING FIXTURE SCHEDULE. DIMMABLE LED DRIVERS SHALL BE 0-10V WHERE NOT INDICATED.

F. CONTINUOUS ROW, TWO LAMP STRIP FIXTURES SHALL BE STAGGERED TYPE.

G. FLUORESCENT LIGHTING FIXTURES, INCLUDING GENERAL CONSTRUCTION, LAMPS AND BALLASTS SHALL CONFORM TO THE ENERGY EFFICIENCY REQUIREMENTS OF CONSOLIDATED EDISON CO. AND QUALITY FOR A UTILITY REBATE TO OWNER UNDER CON EDISON'S ENLIGHTENED ENERGY LIGHTING REBATE PROGRAM. CONTRACTOR SHALL COORDINATE REBATE PROGRAM WITH CON EDISON AND ARRANGE FOR CON EDISON TO PERFORM A SURVEY TO INVENTORY ALL EXISTING FIXTURES PRIOR TO DEMOLITION.

H. EXIT SIGNS SHALL BE PRECISION DIE-CAST ALUMINUM HOUSING WITH LASER-FORMED ACRYLIC LEGEND. EXIT SIGNS SHALL COMPLY WITH UL 924 AND BE MEA APPROVED. AC POWERED WITH PREMIUM LONG-LIFE NICKEL CADMIUM BATTERY WITH STANDARD UL LISTED 3-HOUR RUN TIME. PROVIDE WITH INTEGRAL AUTOMATIC CHARGER IN A SELF CONTAINED POWER PACK. LED INDICATOR WITH PUSH TO TEST SWITCH.

12. TELEPHONE CONDUIT SYSTEM:

A. PROVIDE COMPLETE SYSTEM OF RACEWAYS AND ACCESSORIES, OUTLET BOXES, SLEEVES AND FISHWIRES.

B. EQUIPMENT SHALL CONFORM TO REQUIREMENTS OF TELEPHONE COMPANY.

C. OUTLETS SHALL BE:
1) WALL; 4 IN. SQUARE WITH BUSHED COVER PLATE.

D. PROVIDE FISHWIRES, IN RACEWAYS OVER 10 FT LONG.

E. CONDUIT SHALL BE 3/4 IN. MINIMUM. FURNISH EMPTY CONDUIT FROM OUTLET BOX TO BUSHED END THRU WALL 6" BELOW THE PLASTER CEILING.

F. FACE RACEWAYS IN ROOMS SHALL HUBBELL HBL500, HBL750 OR HBL2000 SERIES OR AS ACCEPTABLE.

14. PANEL BOARDS:

A. PANELBOARDS SHALL BE OF THE DEAD FRONT TYPE. MANUFACTURED IN CODE GAUGE AND SIZE BOXES FOR MOUNTING AS INDICATED ON PLANS COMPLETE WITH TRIM, DOORS AND LOCKS. ALL LOCKS SHALL BE KEYED ALIKE.

B. CIRCUIT BREAKERS SHALL BE OF THE BOLT-ON THERMAL MAGNETIC MOLDED CASE TYPE, AND SHALL HAVE THE TRIP RATINGS AND NUMBER OF POLES SHOWN IN SCHEDULES ON THE CONTRACT DRAWINGS. FOR BLANK (SPACE) COMPARTMENTS, PROVIDE FULL RATED BUS. MINIMUM GUTTER SPACES SHALL BE 5-3/4", SIDES, TOP AND BOTTOM, INCREASE FOR THROUGH FEEDERS. PROVIDE 25% COPPER GROUND BUS AND 100% COPPER NEUTRAL BUS AND INCREASE NEUTRAL BUS INDICATED.

C. LOCKING TABS SHALL BE PROVIDED ON ALL CIRCUIT BREAKERS SERVING EMERGENCY LIGHTING, FIRE ALARM SYSTEM, SECURITY SYSTEMS AND OTHER EMERGENCY OR CRITICAL EQUIPMENT AND AS NOTED ON THE CONTRACT DRAWINGS. A TOTAL OF 5 SPARE LOCKING TABS SHALL BE FURNISHED TO THE OWNER.

D. BUSES SHALL BE HARD DRAWN COPPER OF 98 PERCENT CONDUCTIVITY AND SHALL HAVE CROSS SECTIONAL AREAS LARGE ENOUGH TO LIMIT THE TEMPERATURE RISE, WHEN CARRYING FULL LOAD, TO 35 DEGREES C. ABOVE AN AMBIENT INSIDE THE ENCLOSURE OF 55 DEGREES C. AS IS DEFINED IN IEEE STANDARD RULES. MAIN BUS CAPACITY SHALL BE AS SHOWN ON THE CONTRACT DRAWINGS.

E. ENCLOSURES SHALL BE SURFACE OR FLUSH AS INDICATED. TRIMS SHALL BE SECURED TO PANEL WITH MACHINE SCREWS. COVERS SHALL BE HINGED DOOR-IN-DOOR CONSTRUCTION WITH CYLINDER LOCKS AND CATCHES. LOCKS MUST BE COMPATIBLE WITH BUILDING STANDARD KEY SYSTEM AND WHEN NONE EXISTS, THEY SHALL BE SIMILAR TO A YALE NO. 911 KEY.

F. DISTRIBUTION AND SUB-DISTRIBUTION PANELBOARD SHALL BE A MINIMUM OF 30" WIDE AND 10" DEEP.

G. ALL STANDARD PANELBOARDS SHALL BE A MINIMUM OF 20" WIDE AND 5 3/4" DEEP.

H. FURNISH ALL PANELBOARDS WITH FEED-THRU LUGS UNLESS OTHERWISE INDICATED ON THE DRAWINGS.

I. ALL NEW PANELBOARDS SHALL BE PROVIDED WITH AN ENGRAVED WHITE CORE LAMACOID NAMEPLATE, WITH 3/4 IN. WHITE LETTERING ON A BLACK BACKGROUND, WITH DESIGNATION LISTED (PANELBOARD NAME) FASTENED WITH EPOXY CEMENT OR OVAL HEAD CHROME PLATED MACHINE SCREWS.

J. THE CIRCUIT DIRECTORY SHALL BE TYPEWRITTEN AND PROVIDED INSIDE EACH PANEL DOOR TO INDICATE EQUIPMENT AND/OR AREA


SERVED. DIRECTORY HOLDER SHALL BE METAL FRAME WITH CLEAR PLASTIC, TRANSPARENT COVER. THE TYPEWRITTEN LIST INDICATING CIRCUIT NUMBERS, OUTLETS SUPPLIED AND THEIR LOCATIONS SHALL BE PROVIDED.

K. TIE-BARS SHALL NOT BE USED TO CREATE MULTI-POLE CIRCUITS. MAXIMUM 42 CIRCUITS ALLOWED.

L. ONLY ONE WIRE SHALL BE INSTALLED UNDER EACH CIRCUIT BREAKER LUG.

M. SHORT CIRCUIT RATING OF PANELBOARDS SHALL NOT BE LESS THAN AS INDICATED ON THE CONTRACT DRAWINGS OR SPECIFIED HEREIN. WHERE NOT INDICATED OR SPECIFIED THE MINIMUM SHORT CIRCUIT RATING SHALL BE EQUAL TO THE INTERRUPTING CAPACITY OF THE LOWEST RATED CIRCUIT BREAKER IN THE PANELBOARD, BUT IN NO CASE LESS THAN 10,000 AMPERES R.M.S. SYMMETRICAL FOR 208Y/120 VOLT SYSTEM AND 14,000 AMPERES R.M.S. SYMMETRICAL FOR 480Y/277 VOLT SYSTEM. SERIES RATED PANELBOARDS SHALL BE USED TO ACHIEVE REQUIRED SHORT CIRCUIT RATINGS.

N. FOR ALL EXISTING PANELBOARDS, CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKERS TO REPLACE EXISTING AS REQUIRED AS INDICATED ON DRAWINGS.




LIGHTING FIXTURE SCHEDULE						
TAG	DESCRIPTION	MANUFACTURER	MODEL	COMMENTS	WATTAGE	NOTES
L01	24 X 48 TROFFER	LITHONIA	EPANL-24-40L-35K	OR APPROVED EQUAL	38.8	1
L02	PENDANT	HI-UTE MFG CO. LIGHTING	H-26118-130-93/CB8-91	COPPER PENDANT / NO LIP-INC DOMES	28	1,2
L03	4" RECESSED DOWNLIGHT	LOTUS LED LIGHTS	LL4R-50K-WH	WHITE TRIM	13.5	1
L04	24X24 TROFFER	LITHONIA	EPANL-22-34L-35K	OR APPROVED EQUAL	31.3	1
A	WIC LIGHT FIXTURE	EXISTING	-	-	30	1,2
B	WIC LIGHT FIXTURE	EXISTING	-	-	30	1,2
EX	EXIT SIGN WITH EMERGENCY LIGHT	EXISTING	-	-	5	1
EM	EXIT SIGN	EXISTING	-	-	5	1
NOTES:						
1 COORDINATE EXACT MAKE/MODEL NUMBER WITH THE OWNER/ARCHITECT.						
2 THE LIGHTING FIXTURE WATTAGE HAS BEEN ASSUMED FOR THE COMCHECK AND LOAD CALCULATION PURPOSES ONLY. COORDINATE FINAL SELECTION BY ARCHITECT.						

LIGHTING PLAN GENERAL NOTES:	
A. ELECTRICAL SWITCHES:	CONTROLS AND SWITCHES INTENDED TO BE USED BY THE OCCUPANT OF A ROOM OR AREA TO CONTROL LIGHTING AND RECEPTACLE OUTLETS, APPLIANCES OR COOLING, HEATING AND VENTILATING EQUIPMENT, SHALL COMPLY WITH CODE EXCEPT THE LOW REACH SHALL BE MEASURED TO THE BOTTOM OF THE OUTLET BOX AND THE HIGH REACH SHALL BE MEASURED TO THE TOP OF THE OUTLET BOX.
B. E.C. TO VERIFY REQUIREMENT OF THE NO. OF SWITCHES AND CONTROL PER PLAN AND PROVIDE ACCORDINGLY.	
C. MINIMUM #12 AWG COPPER WIRING SHALL BE USED FOR THE LIGHTING CIRCUIT.	
D. THE NEUTRAL AND GROUNDING ARE NOT SHOWN ON THE DRAWING. E.C. TO PROVIDE AS REQUIRED.	
E. EMERGENCY LIGHT SHALL TURN ON DURING POWER FAILURE WHEREAS ALL EXIT SIGNS SHALL BE PERMANENTLY ON.	

LIGHTING FIXTURE SCHEDULE NOTES:	
ELECTRICAL SYMBOLS	
\$	LIGHT SWITCH
\$	SWITCH W/ DIMMER
\$	3-WAY SWITCH
\$	3-WAY SWITCH W/ DIMMER
1:	LIGHT FIXTURE TAG
01	SWITCHING SYSTEM
\$	SWITCH NUMBER
\$	MANUAL OVERRIDE SWITCH
\$	SWITCH WITH OCCUPANCY SENSOR
E =	EXISTING LIGHTING FIXTURE

LIGHTING PLAN KEYED NOTES:	
1. EXISTING EMERGENCY LIGHTING FIXTURE AND EXIT SIGN FIXTURES SHALL REMAIN AND WIRE THEM TO CIRCUIT B#15. THE E.C. SHALL VERIFY THE OPERABLE CONDITION OF FIXTURES IN THE FIELD. REPLACE IF FOUND INOPERABLE.	
2. E.C. SHALL PROVIDE DISCONNECT SWITCH AND ELECTRICAL WHIP FOR NEW SIGN IN THE FIELD. COORDINATE EXACT LOCATION WITH ARCHITECT/OWNER. COORDINATE EXACT POWER REQUIREMENTS WITH THE SIGNAGE VENDOR.	
3. TIME CLOCK AND LIGHTING CONTACTORS FOR LIGHTING CONTROL. E.C. SHALL COORDINATE EXACT LOCATION IN FIELD. REFER LIGHTING CONTACTOR TYPICAL DETAIL.	
4. MANUAL OVERRIDE SWITCH. THE OVERRIDE SWITCH, WHEN INITIATED, SHALL PERMIT THE CONTROLLED LIGHTING TO REMAIN ON FOR NOT MORE THAN 2 HOURS.	
5. WALL MOUNTED OCCUPANCY SENSOR WITH SWITCH.	
6. E.C. SHALL COORDINATE EXACT LOCATION OF THE SWITCH BANK IN THE FIELD. ALL THE SWITCHES TAGGED AS (\$@SB) IN THE PLAN SHALL BE INSTALLED IN THE SWITCH BANK. REFER TO THE LIGHTING PLAN FOR NUMBER OF THE SWITCHES REQUIRED.	
7. EXISTING LIGHTING FIXTURES ALONG WITH THEIR CIRCUITS AND CONTROLS SHALL REMAIN. E.C. SHALL VERIFY OPERABLE CONDITIONS IN THE FIELD. REPLACE IF FOUND INOPERABLE.	
8. NEW EMERGENCY LIGHTING FIXTURE TO BE CONNECTED IN LOOP WITH EXISTING EMERGENCY LIGHTING FIXTURES.	
9. PROVIDE JUNCTION BOX, CIRCUIT, AND SWITCH FOR HOOD LIGHTING. COORDINATE THE EXACT LOCATION OF THE SWITCH IN THE FIELD.	
10. E.C. SHALL COORDINATE WITH ARCHITECT/OWNER FOR EXACT LOCATION OF PHOTOCELL IN THE FIELD.	
11. DOOR JAMB SWITCH FOR LIGHTING CONTROL.	
12. LIGHTING IN THE DAYLIGHT ZONE SHALL BE CONTROLLED THROUGH DAY LIGHT SENSOR. E.C. SHALL COORDINATE EXACT LOCATION WITH ARCHITECT/OWNER IN THE FIELD.	

SHEET HISTORY SCHEDULE
ISSUE DATE:
FAZOLI'S, KISSIMMEE, FL
DRAWN BY:
QAQC:
APPROVED BY:
PROJECT NUMBER:
ELECTRICAL LIGHTING PLAN
MAIN FLOOR
E1.0



OWER PLAN KEYED NOTES:

1. E.C SHALL VERIFY WITH THE ARCHITECT/OWNER FOR THE EXACT LOCATION OF THE PANELS IN THE FIELD. ALSO, ENSURE CLEAR WORKING AND DEDICATED SPACE HAVE BEEN PROVIDED PER CODE.
2. E.C. SHALL COORDINATE WITH ARCHITECT/OWNER FOR THE EXACT LOCATION OF THE JUNCTION BOX IN THE FIELD.
3. E.C SHALL COORDINATE WITH PLUMBING CONTRACTOR FOR EXACT LOCATION AND ELECTRICAL CONNECTION REQUIREMENT OF THE UNIT IN THE FIELD. PROVIDE CIRCUIT AND CONTROL AS REQUIRED.
4. EXISTING ELECTRICAL EQUIPMENT SHALL REMAIN CONNECTED TO THE EXISTING CIRCUIT. E.C. SHALL REARRANGE THE CIRCUITS ON THE SITE IF REQUIRED.
5. E.C. SHALL COORDINATE EXACT CONNECTION TYPE WITH THE VENDOR/OWNER PRIOR TO ROUGH IN.
6. E.C. SHALL COORDINATE WITH THE ARCHITECT/OWNER TO COMPLETE THE WIRING AND STUB UP THE ELECTRIC TO CONNECT THE COUNTER TO THE JUNCTION BOX.
7. E.C. SHALL COORDINATE WITH ARCHITECT/OWNER FOR THE EXACT LOCATION OF THE OUTLETS IN THE FIELD.
8. THE EXISTING WATER (EX. WH) HEATER SHALL REMAIN CONNECTED TO THE EXISTING CIRCUIT. E.C. SHALL VERIFY THE OPERABLE CONDITION OF THE ELECTRICAL CIRCUIT AND CONTROLS IN THE FIELD. IF THE EXISTING CIRCUIT AND CONTROL IS INOPERABLE, REROUTE THE WIRING TO THE INDICATED CIRCUIT WITH A SUITABLE BREAKER RATING. INFORM THE ENGINEER OF RECORD BEFORE BID.
9. E.C SHALL COORDINATE WITH THE MECHANICAL CONTRACTOR FOR EXACT LOCATION AND ELECTRICAL CONNECTION REQUIREMENT OF THE UNIT IN THE FIELD. PROVIDE CIRCUIT AND CONTROL AS REQUIRED.
10. PLYWOOD-BACKED OUTLET FOR DATA AND TELEPHONE SERVICES. COORDINATE WITH THE ARCHITECT/OWNER/SERVICE PROVIDER FOR MOUNTING HEIGHT, LOCATION AND OTHER REQUIREMENTS. PROVIDE CONDUIT AND CONNECTION AS REQUIRED.
11. E.C SHALL COORDINATE WITH THE EQUIPMENT MANUFACTURER FOR EXACT LOCATION AND ELECTRICAL CONNECTION REQUIREMENT OF THE UNIT IN THE FIELD. PROVIDE CIRCUIT AND CONTROL AS REQUIRED.
12. EXISTING HAND DRYER AND GFI RECEPTACLE SHALL REMAIN CONNECTED TO THE EXISTING CIRCUIT. E.C. SHALL VERIFY THE OPERABLE CONDITION OF THE ELECTRICAL CIRCUIT AND CONTROL IN THE FIELD. REPLACE IF FOUND INOPERABLE. BASE BID ACCORDINGLY.
13. E.C. SHALL COORDINATE WITH ARCHITECT/OWNER FOR THE EXACT LOCATION OF THE CEILING MOUNTED DUPLEX RECEPTACLE AND DATA OUTLET FOR WIFI IN THE FIELD.
14. PROVIDE A CEILING-MOUNTED JUNCTION BOX ("J" BOX) ABOVE THE MENU BOARD (ABOVE THE DRIVE-THRU WINDOW) TO SUPPLY POWER FOR THE ELECTRONIC MENU BOARD IN DRIVE-THRU. ENSURE THE BOX IS PROPERLY WIRED TO SUPPORT TWO LED DRIVERS AND COMPLIES WITH NEC.

KITCHEN EQUIPMENT GENERAL NOTES

THIS SCHEDULE SHOWS ALL CIRCUITING INFORMATION FOR KITCHEN / FOOD SERVICE EQUIPMENT.

NEMA X-XX DESIGNATES NEMA PLUG TYPE AND AMPERAGE.

VERIFY ALL INSTALLATION REQUIREMENTS WITH FOOD SERVICE CONSULTANT AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN.

VERIFY ALL MCA AND MOCP REQUIREMENTS WITH SUBMITTED AND APPROVED EQUIPMENT PRIOR TO ELECTRICAL ROUGH-IN.

VERIFY NEMA RECEPTACLE CONFIGURATIONS WITH EQUIPMENT VENDOR PRIOR TO ELECTRICAL ROUGH-IN.

CONTRACTOR IS RESPONSIBLE FOR FURNISHING AND INSTALLING ALL CONDUIT, WIRE, SUPPORT SYSTEM, DISCONNECTS, AND OUTLETS TO ALLOW FOR A COMPLETE CODE COMPLIANT KITCHEN INSTALLATION.

ALL ELECTRICAL EQUIPMENT LOCATED ON WALLS OF PRODUCTION KITCHEN AREAS SHALL BE A MINIMUM OF 48" AFF UNLESS NOTED OTHERWISE. ALL ELECTRICAL EQUIPMENT LOCATED ABOVE COUNTERS OF KITCHEN AREAS SHALL BE 6" ABOVE COUNTER UNLESS NOTED OTHERWISE. ALL ELECTRICAL EQUIPMENT LOCATED BELOW COUNTERS AND WITHIN CASEWORK OF KITCHEN AREAS SHALL BE 6" BELOW THE TOP OF COUNTERS UNLESS NOTED OTHERWISE.

ALL RECEPTACLES IN KITCHEN AREA SHALL BE GFCI PROTECTED. E.C. SHALL PROVIDE AND INSTALL GFCI CIRCUIT BREAKERS FOR ALL CIRCUITS FEEDING KITCHEN EQUIPMENT REQUIRING GFCI PROTECTION THAT ARE INACCESSIBLE, BEFORE OR AFTER APPLIANCE HAS BEEN INSTALLED, IF RECEPTACLE DOESNT PROVIDE GFCI PROTECTION. NEC 210.8 AND 422.5(A).

LOCATIONS OF DISCONNECTS FOR EACH PIECE OF EQUIPMENT MAY NOT BE SHOWN ON PLANS. IF DISCONNECT FOR EQUIPMENT IS NOT SHOWN, CONTRACTOR TO FIELD COORDINATE LOCATION IN ACCORDANCE WITH CODE.

CONTRACTOR SHALL LIMIT THE AMOUNT OF EXPOSED CONDUIT. ANY EXPOSED CONDUIT SHALL BE LIQUID TIGHT FLEXIBLE METAL CONDUIT OR RIGID GALVANIZED STEEL CONDUIT.

COORDINATE EXACT LOCATION OF ALL REMOTE CONDENSING UNITS WITH HVAC AND FOOD SERVICE DRAWINGS.

FUSED DISCONNECTS SHALL HAVE FUSES SIZED AS LISTED ON EQUIPMENT NAMEPLATE, OTHERWISE MATCH UPSTREAM OVERCURRENT DEVICE IF NO MAXIMUM OVER CURRENT SIZE LISTED ON EQUIPMENT, UNLESS NOTED OTHERWISE.

POWER PLAN GENERAL NOTES:

- A. EXACT LOCATION OF MECHANICAL, PLUMBING, KITCHEN, FURNITURE SYSTEMS, OWNER FURNISHED EQUIPMENT ETC. THAT REQUIRE ELECTRICAL CONNECTIONS ARE SHOWN ON THE MECHANICAL, PLUMBING, AND/OR ARCHITECTURAL DRAWINGS. E.C. TO COORDINATE EXACT LOCATIONS WITH RESPECTIVE CONTRACTORS AND/OR VENDORS PRIOR TO ANY ROUGH-INS.
- B. REVIEW AND COORDINATE WITH ALL TRADES CONTRACT DOCUMENTS TO DETERMINE SPECIFIC MOUNTING LOCATIONS FOR EQUIPMENT WITH ELECTRICAL CONNECTIONS. COORDINATE EXACT MOUNTING LOCATIONS WITH THE SPECIFIC TRADE AND ARCHITECT.
- C. MINIMUM CONDUCTOR SIZE FOR 120V BRANCH CIRCUITS SHALL BE 12-AWG. FOR 120V BRANCH CIRCUITS WITH HOME-RUN OVER 100 LINEAR FEET, A MINIMUM WIRE SIZE OF 10-AWG SHALL BE PROVIDED FROM FIRST JUNCTION/OUTLET BOX TO BRANCH CIRCUIT PANEL BOARD. FOR 120V BRANCH CIRCUITS WITH HOME RUN OVER 150 LINEAR FEET, A MINIMUM OF 8-AWG SHALL BE PROVIDED FROM FIRST JUNCTION/OUTLET BOX TO BRANCH CIRCUIT PANEL BOARD.
- D. ALL WIRING SHALL BE IDENTIFIED BY PANEL BOARD AND CIRCUIT NUMBERS IN ALL CABINETS, JUNCTION BOXES, WIRING TROUGHS, ENCLOSURES, SPLICE OR TERMINATION POINTS ETC.
- E. ALL 120V, 15A AND 20A RECEPTACLES IN KITCHEN AREA SHALL BE "GFCI" IN ACCORDANCE WITH NEC ARTICLE 210.8(B). GFI RECEPTACLE TO BE MOUNTED AT ACCESSIBLE LOCATION. ELSE PROVIDE GFI RATED BREAKER AT PANEL FOR KITCHEN EQUIPMENT.
- F. ELECTRICAL CONDUCTORS FOR FEEDERS AND BRANCH CIRCUITS COMBINED SHALL BE SIZED FOR A MAXIMUM OF 5 PERCENT VOLTAGE DROP.
- G. COORDINATE EXACT LOCATION AND ELECTRICAL CONNECTION REQUIREMENTS OF THE MOTORIZED DAMPERS AND THERMOSTATS IN THE FIELD. PROVIDE WIRING AS REQUIRED.
- H. REUSE EXISTING OR PROVIDE NEW DATA/TELEPHONE BOARD. COORDINATE WITH THE ARCHITECT/VENDOR.

E.C. SHALL VERIFY REQUIREMENT OF THE SHOW WINDOW WITH THE OWNER AND PROVIDE RECEPTACLES AND CIRCUITS IF REQUIRED.

- I. THE ARCHITECTURAL PLAN SHALL TAKE PRECEDENCE OVER THE ELECTRICAL DRAWING FOR EQUIPMENT LOCATION AND MOUNTING HEIGHT.

SHEET HISTORY SCHEDULE

ISSUE DATE

DRAWN BY:

QAQC:

ELECTRICAL POWER PLAN MAIN FLOOR

ROOF POWER PLAN GENERAL NOTES:


A. GFI MARKED ON THE PLAN INDICATES THAT THE CIRCUIT SHALL BE GFI PROTECTED. E.C. SHALL PROVIDE A GFI BREAKER IN THE PANEL FOR THE INDICATED CIRCUIT IF EITHER THE RECEPTACLE IS NOT AVAILABLE OR NOT ACCESSIBLE.

B. A 125-VOLT, SINGLE-PHASE, 15- OR 20-AMPERE-RATED RECEPTACLE OUTLET SHALL BE INSTALLED AT AN ACCESSIBLE LOCATION WITHIN 7.5 M (25 FT) OF THE EQUIPMENT AS SPECIFIED IN 210.63(A) AND (B) AS PER NEC 210.63.

ROOF POWER PLAN KEYED NOTES:

1. EXISTING (E) MECHANICAL UNITS SHALL REMAIN CONNECTED TO THE EXISTING CIRCUIT. THE E.C. SHALL VERIFY THE OPERABLE CONDITION OF THE ELECTRICAL CIRCUIT AND CONTROLS IN THE FIELD. IF THE EXISTING CIRCUIT IS INOPERABLE OR UNAVAILABLE, REROUTE THE WIRING TO THE INDICATED CIRCUIT WITH A SUITABLE BREAKER RATING. INFORM THE ENGINEER OF RECORD BEFORE BID.

2. E.C. SHALL COORDINATE WITH THE MECHANICAL CONTRACTOR FOR EXACT LOCATION AND ELECTRICAL CONNECTION REQUIREMENT OF THE UNIT IN THE FIELD. PROVIDE CIRCUIT AND CONTROL AS REQUIRED.



SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL




DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

ELECTRICAL POWER PLAN
ROOF PLAN



SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

ELECTRICAL DETAILS

E3.0

PANEL: MSP (NEW)				SERVICE ENTRANCE RATED PANEL				MOUNTING: SURFACE								
208Y/120	VOLTS	PHASE	3	-	-	-	-	DEMAND LOAD	205.96	PANEL LOCATION:	ELECTRIC ROOM					
600A	MLO	WIRE	4	-	-	-	-	DEMAND CURRENT	572.37	FED FROM:	METER					
NOTE:																
CKT NO.	TRIP AMPS	DESCRIPTION OF LOAD	LOAD TYPE	LOAD (KVA)	MINIMUM BRANCH CIRCUIT	PER PHASE (KVA)	A	B	C	MINIMUM BRANCH CIRCUIT	LOAD (KVA)	LOAD TYPE	DESCRIPTION OF LOAD	TRIP AMPS	CKT NO.	
1	125/3P	SPARE				8.04				8.04	H				2	
3						8.04				8.04	H	RTU-1(E)		70/3P	4	
5			O	26.05	4#600KCM + 1#3G, 3 1/2"	31.09				8.04	H				6	
7	400/3P	PANEL-A	O	26.05	4#600KCM + 1#3G, 3 1/2"	31.09				3#8 + 1#10G, 3/4"	5.04	H	RTU-2(E)		45/3P	10
9			O	26.05		31.09				5.04	H					12
11			O	21.48	4#600KCM + 1#3G, 3 1/2"	26.52				5.04	H	RTU-3(E)		45/3P	14	
13	400/3P	PANEL-C	O	21.48	4#600KCM + 1#3G, 3 1/2"	26.52				5.04	H				16	
15			O	21.48		26.52				5.04	H				18	
17			H	3.01	3#10 + 1#10G, 3/4"	3.01						SPACE			20	
19	30/3P	MAU-1(N)	H	3.01		3.01						SPACE			22	
21			H	3.01		3.01						SPACE			24	
23			H	3.01		0.00						SPACE			26	
25		SPACE										SPACE			28	
27		SPACE										SPACE			30	
29		SPACE														
						68.65	68.65	65.64								

PANEL: B (NEW)				-				MOUNTING: SURFACE							
208Y/120	VOLTS	PHASE	3	-	-	-	-	DEMAND LOAD	16.23	PANEL LOCATION:	ELECTRIC ROOM				
125A	MLO	WIRE	4	-	-	-	-	DEMAND CURRENT	45.09	FED FROM:	PANEL-C				
NOTE:															
CKT NO.	TRIP AMPS	DESCRIPTION OF LOAD	LOAD TYPE	LOAD (KVA)	MINIMUM BRANCH CIRCUIT	PER PHASE (KVA)	A	B	C	MINIMUM BRANCH CIRCUIT	LOAD (KVA)	LOAD TYPE	DESCRIPTION OF LOAD	TRIP AMPS	CKT NO.
1	20	DINING ROOM LIGHTING	L	1.20	2#12 + 1#12G, 3/4"	1.20						SPARE		20	2
3	20	E64-C02 SENSOR/ALARM	O	0.12	2#12 + 1#12G, 3/4"	0.12						SPARE		20	4
5	20	NEW SIGN	L	1.20	2#12 + 1#12G, 3/4"	1.20						TIME CLOCK		20	6
7	20	NEW SIGN	L	1.20	2#12 + 1#12G, 3/4"	1.20						CEILING MOUNTED RECEPT.		20	8
9	20	BATHROOM LIGHTS, EF-1(N), EF-2(N)	L	0.20	2#12 + 1#12G, 3/4"	0.20						TAKE OUT MONITOR & DRIVE		20	10
11	20	OFFICE, PREP & ELECTRIC ROOM LIGHTING	L	0.39	2#12 + 1#12G, 3/4"	0.39						THRU EXPO		20	12
13	20	HOOD LIGHTING	L	0.50	2#12 + 1#12G, 3/4"	0.50						TV OUTLETS		20	14
15	20	EMERGENCY LIGHTING	L	0.10	2#12 + 1#12G, 3/4"	0.10						KEF-1(N)		20	16
17	20	ACCESS POINT RECEPT.	R	0.18	2#12 + 1#12G, 3/4"	0.18						SPARE		20	18
19	20	SPARE				0.00						SPARE		20	20
21	20	SPARE				0.00						SPARE		20	22
23	20	SPARE				0.52						SPARE		20	24
25	20	SPARE				0.10						WIB LIGHTS		20	26
27	20	SPARE				0.72						ORDER KIOSK		20	28
29	20	SPARE				1.07						KEF-3(N)		20	30
						4.08	3.33	3.98							

PANEL: A (NEW)				-				MOUNTING: SURFACE							
208Y/120	VOLTS	PHASE	3	-	-	-	-	DEMAND LOAD	78.15	PANEL LOCATION:	ELECTRIC ROOM				
400A	MLO	WIRE	4	-	-	-	-	DEMAND CURRENT	217.17	FED FROM:	MAIN SERVICE PANEL				
NOTE:															
CKT NO.	TRIP AMPS	DESCRIPTION OF LOAD	LOAD TYPE	LOAD (KVA)	MINIMUM BRANCH CIRCUIT	PER PHASE (KVA)	A	B	C	MINIMUM BRANCH CIRCUIT	LOAD (KVA)	LOAD TYPE	DESCRIPTION OF LOAD	TRIP AMPS	CKT NO.
1	20	E01-COUNTERTOP SELF-SERVE ICE/BEVERAGE DISPENSER	E	0.50	2#12 + 1#12G, 3/4"	1.58				2#12 + 1#12G, 3/4"	1.08	R	OFFICE RECEPTACLE	20	2
3	20	E02-REFRIGERATOR, UNDERCOUNTER	E	0.36	2#12 + 1#12G, 3/4"	0.72				2#12 + 1#12G, 3/4"	0.36	R	DATA/TEL. RECEPT.	20	4
5	20	E06-REFRIGERATOR, REACH-IN	E	0.20	2#12 + 1#12G, 3/4"	0.66				2#12 + 1#12G, 3/4"	0.46	E	E36-REFRIGERATOR, SANDWICH/SALAD PREP	20	6
7	20	E55-KETTLE HOOD (HOOD-3(N))	O	0.50	2#12 + 1#12G, 3/4"	1.03				2#12 + 1#12G, 3/4"	0.53	E	E36.1-REFRIGERATOR, SANDWICH/SALAD PREP	20	8
9	20	CONVENIENCE OUTLET	R	0.72	2#12 + 1#12G, 3/4"	1.72				2#12 + 1#12G, 3/4"	1.00	R	WIRELESS HEAD SETS, DIGITAL DISPLAY	20	10
11	20	E27-DISPENSER, BEVERAGE/NON-CARBONATED	E	1.44	2#12 + 1#12G, 3/4"	1.46				2#12 + 1#12G, 3/4"	0.46	E	E36-REFRIGERATOR, SANDWICH/SALAD PREP	20	12
13	30	SPARE				1.46				2#12 + 1#12G, 3/4"	1.46	E	E44.1-WARMER, MERCHANDISER	20	14
15	20	E49-COOK LINE EXHAUST HOOD (HOOD-1(N))	O	0.50	2#12 + 1#12G, 3/4"	1.96				2#12 + 1#12G, 3/4"	1.46	E	E44.1-WARMER, MERCHANDISER	20	16
17	20	E01.1-ICE MAKER CUBE STYLE	E	1.46	2#12 + 1#12G, 3/4"	1.82				2#12 + 1#12G, 3/4"	0.36	R	DRIVE THRU STEAM MONITOR	20	18
19	30	SPARE				1.75				2#12 + 1#12G, 3/4"	1.75	E	E46-HOLDING CABINET	20	20
21	20	E01.1-ICE MAKER CUBE STYLE	E	1.46	2#12 + 1#12G, 3/4"	2.79				2#12 + 1#12G, 3/4"	1.33	E	E47-WARMER, FOOD OVERHEAD	20	22
23	20	CONVENIENCE OUTLET	R	0.72	2#12 + 1#12G, 3/4"	5.52				2#12 + 1#12G, 3/4"	4.80	E	E62-ELECTRIC FRYERS	20	24
25	20	OVEN IN & OUT MONITOR	O	0.50	2#12 + 1#12G, 3/4"	5.30		</td							

PLUMBING SYMBOLS LIST	
— GSAN —	GREASE SANITARY SEWER (UNDERFLOOR)
— SAN —	SANITARY SEWER (UNDERFLOOR)
— EX.GSAN —	EXISTING GREASE SANITARY SEWER (UNDERFLOOR)
— EX.V —	EXISTING VENT PIPING
— VENT PIPING —	VENT PIPING
— COLD WATER PIPING —	COLD WATER PIPING
— HOT WATER PIPING —	HOT WATER PIPING
— HOT WATER RETURN PIPING —	HOT WATER RETURN PIPING
— FILTER PIPING —	FILTER PIPING
— EXISTING COLD WATER PIPING —	EXISTING COLD WATER PIPING
— P-TRAP —	P-TRAP
— PIPE UP —	PIPE UP
— PIPE DROP —	PIPE DROP
— PLUGGED OUTLET/CLEANOUT —	PLUGGED OUTLET/CLEANOUT
— POINT OF CONNECTION —	POINT OF CONNECTION
— SECONDARY BFP —	SECONDARY BFP

PLUMBING SPECIFICATIONS:	
1. BASIC PLUMBING REQUIREMENTS, MATERIALS AND METHODS	1.01 SCOPES
A. PROVIDE ALL MATERIAL, TOOLS, SUPERVISION AND LABOR INCLUDING ALL MISCELLANEOUS AND INCIDENTAL ITEMS REQUIRED FOR COMPLETE AND OPERABLE PLUMBING INSTALLATIONS AS SHOWN OR DESCRIBED ON THE DRAWINGS AND IN THESE SPECIFICATIONS.	A. FURNISH: TO PURCHASE, PROCUER, ACQUIRE AND DELIVER, COMPLETE WITH RELATED ACCESSORIES.
B. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING AND NEW CONDITIONS AND MATERIALS WITHIN THE CONSTRUCTION AREA. ANY DAMAGE CAUSED BY THE CONTRACTOR SHALL BE REPAIRED TO THE OWNER'S SATISFACTION.	B. INSTALL: TO ERECT, MOUNT AND CONNECT, COMPLETE WITH RELATED ACCESSORIES.
C. OBTAIN ALL PERMITS, PAY ALL PERMIT FEES AND SCHEDULE ALL REQUIRED INSPECTIONS. COPIES OF ALL PERMITS AND INSPECTION CERTIFICATES SHALL BE FORWARDED TO THE OWNER FOR RECORD.	C. PROVIDE: TO FURNISH AND INSTALL.
D. THE GENERAL CONDITIONS OF THE CONTRACT AND ALL DIVISION 1 REQUIREMENTS APPLY TO THE WORK OF THIS SECTION.	D. PLUMBING CONTRACTOR, THE CONTRACTOR, THIS CONTRACTOR: THE CONTRACTOR FOR PLUMBING WORK WHICH IS SPECIFIED HEREIN AND SHOWN ON THESE DRAWINGS.
E. THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO SUBMITTING BID TO DETERMINE CONDITIONS AND THE EXTENT OF THE WORK. BY COMMENCING WORK, THE CONTRACTOR ACKNOWLEDGES HIS CONFIRMATION OF ALL CONDITIONS AS ACCEPTABLE WITH REFERENCE TO HIS CONTRACT, SCOPE OF WORK AND BID PRICE SUCH THAT NO ADDITIONAL COMPENSATION SHALL BE FORTHCOMING FOR UNFORESEEN EXISTING CONDITIONS.	1.06 DRAWINGS
F. IN ALL AREAS SUBJECT TO FREEZING CONDITIONS, THE CONTRACTOR SHALL PROVIDE FREEZE PROTECTION FOR ALL DOMESTIC WATER PIPING INSTALLED UNDER HIS CONTRACT.	A. THE DRAWINGS ARE DIAGRAMMATIC AND ARE INTENDED TO ILLUSTRATE THE GENERAL ARRANGEMENT AND ROUTING OF PIPING AND GENERAL LOCATIONS OF EQUIPMENT. PRECISE LOCATIONS OF EQUIPMENT, RISERS AND STACKS, AND ROUTING AND ELEVATION OF ALL PIPING SYSTEMS SHALL BE COORDINATED IN THE FIELD WITH THE ARCHITECT, ARCHITECTURAL DRAWINGS, THE WORK OF OTHER TRADES, EXISTING AND NEW BUILDING CONDITIONS AND/OR THE PREFERENCES OF THE OWNER/TENANT AS CONSTRUCTION PROCEEDS. ALL PIPING SHALL BE INSTALLED CONCEALED IN FINISHED SPACES, UNLESS NOTED OTHERWISE.
G. ALL ELECTRICAL REQUIREMENTS SHALL BE COORDINATED WITH THE CONTRACTOR FOR ELECTRICAL WORK. THIS CONTRACTOR IS RESPONSIBLE FOR ALL LOW VOLTAGE WIRING FOR EQUIPMENT INSTALLED UNDER HIS CONTRACT. THE CONTRACTOR FOR ELECTRICAL WORK IS RESPONSIBLE FOR LINE VOLTAGE POWER WIRING ONLY.	B. PROVIDE ALL NECESSARY INCIDENTAL MATERIALS AND ACCESSORIES REQUIRED TO MAKE THE WORK COMPLETE IN ALL RESPECTS, EVEN IF NOT PARTICULARLY SHOWN OR SPECIFIED.
H. COLOR AND FINISH SELECTIONS FOR ALL MATERIALS, INCLUDING PAINTING OF PIPING, SHALL BE AS DIRECTED AND/OR APPROVED BY THE ARCHITECT.	C. REFER TO PLUMBING EQUIPMENT/FIXTURE SCHEDULE ON THE DRAWINGS FOR ALL FIXTURE AND EQUIPMENT SPECIFICATIONS.
I. MINOR DETAILS NOT SHOWN OR SPECIFIED, BUT NECESSARY FOR THE PROPER AND ACCEPTABLE CONSTRUCTION, INSTALLATION OR OPERATION OF ANY PART OF THE WORK AS DETERMINED BY THE ENGINEER SHALL BE INCLUDED AS IF SPECIFIED OR INDICATED ON THE DRAWINGS.	D. REFER TO FIXTURE CONNECTION SIZE SCHEDULE FOR ALL FIXTURE ROUGHING SIZE REQUIREMENTS.
J. THIS CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL REQUIREMENTS FOR THE INSTALLATION, CONNECTION, EXTENSION OR MODIFICATION TO ALL UTILITY SERVICES WITH RESPECTIVE PROVIDERS INCLUDING PAYMENT OF ALL ASSOCIATED FEES.	E. VERIFY ALL INDICATED CONDITIONS BEFORE STARTING WORK AND REPORT ANY DISCREPANCIES. THE DRAWINGS REFLECT CONDITIONS WHICH CAN BE REASONABLY INTERPRETED FROM THE EXISTING VISIBLE CONDITIONS OR FROM DRAWINGS AND INFORMATION FURNISHED BY THE OWNER.
K. THE CONTRACTOR IS RESPONSIBLE FOR ALL PAINTING ASSOCIATED WITH CUTTING AND PATCHING. ALL PAINTING IN AREAS WITH COMPLETE FINISH RENOVATIONS SHALL BE PROVIDED BY THE GENERAL CONTRACTOR.	F. LOCATE ALL FIXTURES AND EQUIPMENT AS PER THE FINAL ARCHITECTURAL DRAWINGS.
L. COLOR AND FINISH SELECTIONS FOR ALL MATERIALS, INCLUDING PAINTING OF PIPING, SHALL BE AS DIRECTED AND/OR APPROVED BY THE ARCHITECT.	1.07 PRODUCTS
M. SUBMITTALS	A. SANITARY AND VENT PIPING:
N. FLOOR DRAIN	1. ABOVE GRADE AND UNDERGROUND PIPING SHALL BE POLYVINYL CHLORIDE (PVC) PIPE AS PER ASTM D2665, ASTM F891, ASTM F1488, CSA B18.1.2 AS PER 2022 PLUMBING CODE 7TH EDITION, TABLE 702.1 AND TABLE 702.2. OR PIPING SHALL BE HUBLESS CAST IRON PIPE WITH STAINLESS STEEL COUPLINGS AND ELASTOMERIC GASKETS WITH A MINIMUM 4 BANDS PER COUPLING.
O. BACK FLOW PREVENTER	2. SLOPE OF DRAINAGE SYSTEM SHALL BE 1/8" PER FOOT OF RUN FOR PIPE OVER 3" (I.D.) AND 1/4" PER FOOT OF RUN FOR PIPE 3" AND SMALLER (I.D.). VENT PIPING SHALL BE PITCHED TO DRAIN.
P. WATER HEATER	3. ALL CAST IRON SOIL PIPE AND FITTINGS SHALL BE MARKED WITH THE COLLECTIVE TRADEMARK OF THE CAST IRON SOIL PIPE INSTITUTE (CISI) AND BE LISTED BY NSF INTERNATIONAL.
Q. NOT IN SCOPE	B. DOMESTIC WATER PIPING:
R. EXPANSION TANK	1. ABOVE GRADE WATER PIPING SHALL BE TYPE 'L' HARD-DRAWN COPPER TUBE. PEX PIPING IS AN ACCEPTABLE SUBSTITUTE AS PER ASTM F876 AWWA C904 AND CSA B137.5
S. CIRCULATION PUMP	2. FITTINGS IN DOMESTIC WATER PIPING SHALL BE WROUGHT COPPER OR CAST BRASS.
T. VENT	3. JOINTS SHALL BE MADE WITH LEAD-FREE SOLDER.
U. VENT STACK	4. THE ENTIRE DOMESTIC WATER DISTRIBUTION SYSTEM SHALL BE INSULATED INCLUDING ALL VALVES, FITTINGS, ETC.
V. VENT DRAINS	5. COMPLY WITH NSF 61 FOR MATERIALS FOR WATER-SERVICE PIPING AND SPECIFICATIONS FOR DOMESTIC WATER.
W. VENT DRAINS	6. ALL DOMESTIC WATER PIPING ABOVE GRADE SHALL BE INSULATED WITH FIRE-RETARDANT, FACTORY-APPLIED JACKET. PROVIDE COLD WATER PIPING WITH FACTORY-APPLIED VAPOR BARRIER. INSULATION REQUIREMENT SHOULD COMPLY WITH FLORIDA ENERGY CONSERVATION CODE 2023, 8TH EDITION. REFER BELOW TABLE C403.2.10 FOR MINIMUM PIPE INSULATION THICKNESS.
X. VENT DRAINS	7. WATER DISTRIBUTION SYSTEM AS PER FLORIDA ENERGY CONSERVATION CODE 2023, 8TH EDITION C404.7. HAVING ONE OR MORE RECIRCULATION PUMPS THAT PUMP WATER FROM A HEATED WATER SUPPLY PIPE BACK TO THE HEATED-WATER SOURCE THROUGH A COLD-WATER SUPPLY PIPE SHALL BE A DEMAND RECIRCULATION WATER SYSTEM. PUMPS SHALL HAVE CONTROLS THAT COMPLY WITH BOTH OF THE FOLLOWING:
Y. VENT DRAINS	A. THE CONTROL SHALL START THE PUMP UPON RECEIVING A SIGNAL FROM THE ACTION OF A USER OF A FIXTURE OR APPLIANCE, SENSING THE PRESENCE OF A USER OF A FIXTURE OR SENSING THE FLOW OF HOT OR TEMPERED WATER TO A FIXTURE FITTING OR APPLIANCE.
Z. VENT DRAINS	B. THE CONTROL SHALL LIMIT THE TEMPERATURE OF THE WATER ENTERING THE COLD-WATER PIPING TO 104°F (40°C).
AA. VENT DRAINS	8. AS PER FLORIDA ENERGY CONSERVATION CODE 2023 C404.6.1 HEATED-WATER CIRCULATION SYSTEMS SHALL BE PROVIDED WITH A CIRCULATION PUMP. THE SYSTEM RETURN PIPE SHALL BE A DEDICATED RETURN PIPE OR A COLD WATER SUPPLY PIPE. CONTROLS FOR CIRCULATING HOT WATER SYSTEM PUMPS SHALL START THE PUMP BASED ON THE IDENTIFICATION OF A DEMAND FOR HOT WATER WITHIN THE OCCUPANCY. THE CONTROLS SHALL AUTOMATICALLY TURN OFF THE PUMP WHEN THE WATER IN THE CIRCULATION LOOP IS AT THE DESIRED TEMPERATURE AND WHEN THERE IS NO DEMAND FOR HOT WATER.
BB. VENT DRAINS	9. THE CONTRACTOR ASSUMES ALL RESPONSIBILITY FOR COORDINATING THE WORK OF OTHER TRADES WHICH MAY BE AFFECTED BY SUBSTITUTIONS, INCLUDING ALL RELATED COSTS.
CC. VENT DRAINS	10. INSPECTION AND TESTING OF PLUMBING SYSTEMS SHALL BE IN ACCORDANCE WITH SECTION PC 107.


PLUMBING DRAWING LIST	
P0.1	PLUMBING SPECIFICATIONS, ABBREVIATIONS, SYMBOLS & NOTES
P1.0	PLUMBING SANITARY PIPING PLAN
P1.1	PLUMBING WATER PIPING PLAN
P5.0	PLUMBING DETAILS
P6.0	PLUMBING RISERS & SCHEDULES

BUILDING DEPARTMENT PLUMBING NOTES	
1. ALL PLUMBING SYSTEMS (SANITARY, WASTE, VENT, WATER) AND ASSOCIATED EQUIPMENT SHALL BE INSTALLED, OPERATED AND MAINTAINED IN ACCORDANCE WITH THE REQUIREMENTS OF 2023 FLORIDA PLUMBING CODE 8TH EDITION.	
2. INSTALLATION OF UNDERGROUND PIPING SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION PC 702.2	
3. PROTECTION OF PIPING AND PLUMBING SYSTEM COMPONENTS AS PER SECTION PC 305.	
4. TRENCHING, EXCAVATION AND BACKFILL AS PER SECTION PC 306.	
5. RODENT PROOFING AS PER PC 304.	
6. MATERIALS USED IN PLUMBING SYSTEMS SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION PC 303, PC 605, PC 702, PC 902, PC 1102.	
7. EQUIPMENT CONNECTIONS AND JOINING OF PIPING SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTERS 4, 5, 6, 7 AND 9.	
8. DEEP SEAL TRAPS FOR FLOOR DRAINS SHALL BE PROVIDED AS PER PC 1002, AND CLEAN-OUTS SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION PC 708.	
9. DRAINAGE PIPE CLEANOUTS AS PER SECTION PC 708.	
10. VERTICAL AND HORIZONTAL PIPING SHALL BE SUPPORTED IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION PC 308.	
11. WATER SUPPLY SYSTEMS SHALL BE INSTALLED AND MAINTAINED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 6 SECTION PC 601-603, 604, 606, 607, 608, 610.	
12. THE SANITARY DRAINAGE SYSTEM SHALL BE SIZED AND INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 7 SECTION PC 701, 704, 705, 706, 707, 708, 711.	
13. VENT PIPING FOR THE SANITARY DRAINAGE SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 9 SECTION PC 901 THROUGH PC 912 THROUGH PC 917.	
14. INSPECTION AND TESTING OF PLUMBING SYSTEMS SHALL BE IN ACCORDANCE WITH SECTION PC 107.	

PLUMBING SPECIFICATIONS:	
1. BASIC PLUMBING REQUIREMENTS, MATERIALS AND METHODS	1.01 SCOPES
A. PROVIDE ALL MATERIAL, TOOLS, SUPERVISION AND LABOR INCLUDING ALL MISCELLANEOUS AND INCIDENTAL ITEMS REQUIRED FOR COMPLETE AND OPERABLE PLUMBING INSTALLATIONS AS SHOWN OR DESCRIBED ON THE DRAWINGS AND IN THESE SPECIFICATIONS.	A. FURNISH: TO PURCHASE, PROCUER, ACQUIRE AND DELIVER, COMPLETE WITH RELATED ACCESSORIES.
B. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL EXISTING AND NEW CONDITIONS AND MATERIALS WITHIN THE CONSTRUCTION AREA. ANY DAMAGE CAUSED BY THE CONTRACTOR SHALL BE REPAIRED TO THE OWNER'S SATISFACTION.	B. INSTALL: TO ERECT, MOUNT AND CONNECT, COMPLETE WITH RELATED ACCESSORIES.
C. OBTAIN ALL PERMITS, PAY ALL PERMIT FEES AND SCHEDULE ALL REQUIRED INSPECTIONS. COPIES OF ALL PERMITS AND INSPECTION CERTIFICATES SHALL BE FORWARDED TO THE OWNER FOR RECORD.	C. PROVIDE: TO FURNISH AND INSTALL.
D. THE GENERAL CONDITIONS OF THE CONTRACT AND ALL DIVISION 1 REQUIREMENTS APPLY TO THE WORK OF THIS SECTION.	D. PLUMBING CONTRACTOR, THE CONTRACTOR, THIS CONTRACTOR: THE CONTRACTOR FOR PLUMBING WORK WHICH IS SPECIFIED HEREIN AND SHOWN ON THESE DRAWINGS.
E. THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO SUBMITTING BID TO DETERMINE CONDITIONS AND THE EXTENT OF THE WORK. BY COMMENCING WORK, THE CONTRACTOR ACKNOWLEDGES HIS CONFIRMATION OF ALL CONDITIONS AS ACCEPTABLE WITH REFERENCE TO HIS CONTRACT, SCOPE OF WORK AND BID PRICE SUCH THAT NO ADDITIONAL COMPENSATION SHALL BE FORTHCOMING FOR UNFORESEEN EXISTING CONDITIONS.	1.06 DRAWINGS
F. IN ALL AREAS SUBJECT TO FREEZING CONDITIONS, THE CONTRACTOR SHALL PROVIDE FREEZE PROTECTION FOR ALL DOMESTIC WATER PIPING INSTALLED UNDER HIS CONTRACT.	A. THE DRAWINGS ARE DIAGRAMMATIC AND ARE INTENDED TO ILLUSTRATE THE GENERAL ARRANGEMENT AND ROUTING OF PIPING AND GENERAL LOCATIONS OF EQUIPMENT. PRECISE LOCATIONS OF EQUIPMENT, RISERS AND STACKS, AND ROUTING AND ELEVATION OF ALL PIPING SYSTEMS SHALL BE COORDINATED IN THE FIELD WITH THE ARCHITECT, ARCHITECTURAL DRAWINGS, THE WORK OF OTHER TRADES, EXISTING AND NEW BUILDING CONDITIONS AND/OR THE PREFERENCES OF THE OWNER/TENANT AS CONSTRUCTION PROCEEDS. ALL PIPING SHALL BE INSTALLED CONCEALED IN FINISHED SPACES, UNLESS NOTED OTHERWISE.
G. ALL ELECTRICAL REQUIREMENTS SHALL BE COORDINATED WITH THE CONTRACTOR FOR ELECTRICAL WORK. THIS CONTRACTOR IS RESPONSIBLE FOR ALL LOW VOLTAGE WIRING FOR EQUIPMENT INSTALLED UNDER HIS CONTRACT. THE CONTRACTOR FOR ELECTRICAL WORK IS RESPONSIBLE FOR LINE VOLTAGE POWER WIRING ONLY.	B. PROVIDE ALL NECESSARY INCIDENTAL MATERIALS AND ACCESSORIES REQUIRED TO MAKE THE WORK COMPLETE IN ALL RESPECTS, EVEN IF NOT PARTICULARLY SHOWN OR SPECIFIED.
H. COLOR AND FINISH SELECTIONS FOR ALL MATERIALS, INCLUDING PAINTING OF PIPING, SHALL BE AS DIRECTED AND/OR APPROVED BY THE ARCHITECT.	C. REFER TO PLUMBING EQUIPMENT/FIXTURE SCHEDULE ON THE DRAWINGS FOR ALL FIXTURE AND EQUIPMENT SPECIFICATIONS.
I. MINOR DETAILS NOT SHOWN OR SPECIFIED, BUT NECESSARY FOR THE PROPER AND ACCEPTABLE CONSTRUCTION, INSTALLATION OR OPERATION OF ANY PART OF THE WORK AS DETERMINED BY THE ENGINEER SHALL BE INCLUDED AS IF SPECIFIED OR INDICATED ON THE DRAWINGS.	D. REFER TO FIXTURE CONNECTION SIZE SCHEDULE FOR ALL FIXTURE ROUGHING SIZE REQUIREMENTS.
J. THIS CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL REQUIREMENTS FOR THE INSTALLATION, CONNECTION, EXTENSION OR MODIFICATION TO ALL UTILITY SERVICES WITH RESPECTIVE PROVIDERS INCLUDING PAYMENT OF ALL ASSOCIATED FEES.	E. VERIFY ALL INDICATED CONDITIONS BEFORE STARTING WORK AND REPORT ANY DISCREPANCIES. THE DRAWINGS REFLECT CONDITIONS WHICH CAN BE REASONABLY INTERPRETED FROM THE EXISTING VISIBLE CONDITIONS OR FROM DRAWINGS AND INFORMATION FURNISHED BY THE OWNER.
K. THE CONTRACTOR IS RESPONSIBLE FOR ALL PAINTING ASSOCIATED WITH CUTTING AND PATCHING. ALL PAINTING IN AREAS WITH COMPLETE FINISH RENOVATIONS SHALL BE PROVIDED BY THE GENERAL CONTRACTOR.	F. LOCATE ALL FIXTURES AND EQUIPMENT AS PER THE FINAL ARCHITECTURAL DRAWINGS.
L. COLOR AND FINISH SELECTIONS FOR ALL MATERIALS, INCLUDING PAINTING OF PIPING, SHALL BE AS DIRECTED AND/OR APPROVED BY THE ARCHITECT.	1.07 PRODUCTS
M. SUBMITTALS	A. SANITARY AND VENT PIPING:
N. FLOOR DRAIN	1. ABOVE GRADE AND UNDERGROUND PIPING SHALL BE POLYVINYL CHLORIDE (PVC) PIPE AS PER ASTM D2665, ASTM F891, ASTM F1488, CSA B18.1.2 AS PER 2022 PLUMBING CODE 7TH EDITION, TABLE 702.1 AND TABLE 702.2. OR PIPING SHALL BE HUBLESS CAST IRON PIPE WITH STAINLESS STEEL COUPLINGS AND ELASTOMERIC GASKETS WITH A MINIMUM 4 BANDS PER COUPLING.
Q. NOT IN SCOPE	2. SLOPE OF DRAINAGE SYSTEM SHALL BE 1/8" PER FOOT OF RUN FOR PIPE OVER 3" (I.D.) AND 1/4" PER FOOT OF RUN FOR PIPE 3" AND SMALLER (I.D.). VENT PIPING SHALL BE PITCHED TO DRAIN.
R. EXPANSION TANK	3. ALL CAST IRON SOIL PIPE AND FITTINGS SHALL BE MARKED WITH THE COLLECTIVE TRADEMARK OF THE CAST IRON SOIL PIPE INSTITUTE (CISI) AND BE LISTED BY NSF INTERNATIONAL.
S. CIRCULATION PUMP	B. DOMESTIC WATER PIPING:
T. VENT	1. ABOVE GRADE WATER PIPING SHALL BE TYPE 'L' HARD-DRAWN COPPER TUBE. PEX PIPING IS AN ACCEPTABLE SUBSTITUTE AS PER ASTM F876 AWWA C904 AND CSA B137.5
U. VENT STACK	2. FITTINGS IN DOMESTIC WATER PIPING SHALL BE WROUGHT COPPER OR CAST BRASS.
V. VENT DRAINS	3. JOINTS SHALL BE MADE WITH LEAD-FREE SOLDER.
W. VENT DRAINS	4. THE ENTIRE DOMESTIC WATER DISTRIBUTION SYSTEM SHALL BE INSULATED INCLUDING ALL VALVES, FITTINGS, ETC.
X. VENT DRAINS	5. COMPLY WITH NSF 61 FOR MATERIALS FOR WATER-SERVICE PIPING AND SPECIFICATIONS FOR DOMESTIC WATER.
Y. VENT DRAINS	6. ALL DOMESTIC WATER PIPING ABOVE GRADE SHALL BE INSULATED WITH FIRE-RETARDANT, FACTORY-APPLIED JACKET. PROVIDE COLD WATER PIPING WITH FACTORY-APPLIED VAPOR BARRIER. INSULATION REQUIREMENT SHOULD COMPLY WITH FLORIDA ENERGY CONSERVATION CODE 2023, 8TH EDITION. REFER BELOW TABLE C403.2.10 FOR MINIMUM PIPE INSULATION THICKNESS.
Z. VENT DRAINS	7. WATER DISTRIBUTION SYSTEM AS PER FLORIDA ENERGY CONSERVATION CODE 2023, 8TH EDITION C404.7. HAVING ONE OR MORE RECIRCULATION PUMPS THAT PUMP WATER FROM A HEATED WATER SUPPLY PIPE BACK TO THE HEATED-WATER SOURCE THROUGH A COLD-WATER SUPPLY PIPE SHALL BE A DEMAND RECIRCULATION WATER SYSTEM. PUMPS SHALL HAVE CONTROLS THAT COMPLY WITH BOTH OF THE FOLLOWING:
AA. VENT DRAINS	A. THE CONTROL SHALL START THE PUMP UPON RECEIVING A SIGNAL FROM THE ACTION OF A USER OF A FIXTURE OR APPLIANCE, SENSING THE PRESENCE OF A USER OF A FIXTURE OR SENSING THE FLOW OF HOT OR TEMPERED WATER TO A FIXTURE FITTING OR APPLIANCE.
BB. VENT DRAINS	B. THE CONTROL SHALL LIMIT THE TEMPERATURE OF THE WATER ENTERING THE COLD-WATER PIPING TO 104°F (40°C).
CC. VENT DRAINS	8. AS PER FLORIDA ENERGY CONSERVATION CODE 2023 C404.6.1 HEATED-WATER CIRCULATION SYSTEMS SHALL BE PROVIDED WITH A CIRCULATION PUMP. THE SYSTEM RETURN PIPE SHALL BE A DEDICATED RETURN PIPE OR A COLD WATER SUPPLY PIPE. CONTROLS FOR CIRCULATING HOT WATER SYSTEM PUMPS SHALL START THE PUMP BASED ON THE IDENTIFICATION OF A DEMAND FOR HOT WATER WITHIN THE OCCUPANCY. THE CONTROLS SHALL AUTOMATICALLY TURN OFF THE PUMP WHEN THE WATER IN THE CIRCULATION LOOP IS AT THE DESIRED TEMPERATURE AND WHEN THERE IS NO DEMAND FOR HOT WATER.
DD. VENT DRAINS	9. THE CONTRACTOR ASSUMES ALL RESPONSIBILITY FOR COORDINATING THE WORK OF OTHER TRADES WHICH MAY BE AFFECTED BY SUBSTITUTIONS, INCLUDING ALL RELATED COSTS.
EE. VENT DRAINS	10. INSPECTION AND TESTING OF PLUMBING SYSTEMS SHALL BE IN ACCORDANCE WITH SECTION PC 107.

1.05 DEFINITIONS	9. HW SYSTEM PIPING IS DESIGNED AS PER MAXIMUM ALLOWED PIPE LENGTH METHOD AS PER FLORIDA ENERGY CONSERVATION CODE 2023 C404.5.1. THE HW PIPE LENGTH FROM THE NEAREST SOURCE OF HEATED WATER TO THE TERMINATION OF THE FIXTURE SUPPLY PIPE SHALL BE AS PER FOLLOWING TABLE.

<tbl_r cells="2



1 PLUMBING SANITARY PIPING PLAN
P1.0 SCALE: 1/4" = 1'-0"

GENERAL NOTES:

1. CONTRACTOR TO FIELD VERIFY FEASIBILITY OF SLAB PENETRATION AS PER STRUCTURAL REQUIREMENT.
2. PROVIDE ACCESS PANELS FOR WATER HAMMER ARRESTOR, CLEANOUTS & SHUT-OFF VALVES AS REQUIRED.
3. REFER RISER DIAGRAMS FOR ALL PIPE SIZES.
4. CONTRACTOR TO FIELD VERIFY EXISTING GREASE, VENT PIPE SIZE, CONDITION AND INVERT. AND REROUTE THE NEW PIPES AS REQUIRED.
5. ANY UNUSED EXISTING FLOOR SINK/DRAIN AND PIPING MUST BE COMPLETELY REMOVED OR CAPPED. DO NOT ABANDON IN PLACE.

SANITARY PLAN NOTES:

- 1 EXISTING LAVATORY WITH EXISTING SANITARY, VENT WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING CONDITION OF EXISTING PIPING AND FIXTURE REPLACED IF REQUIRED.
- 2 EXISTING WATER CLOSET WITH EXISTING SANITARY, VENT WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING CONDITION OF EXISTING PIPING AND FIXTURE REPLACED IF REQUIRED.
- 3 EXISTING MOP SINK WITH EXISTING SANITARY, VENT WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING CONDITION OF EXISTING PIPING AND FIXTURE REPLACED IF REQUIRED.
- 4 INDIRECT WASTE FROM 3 COMPARTMENT SINK AND DISHWASHER TO FLOOR SINK WITH APPROVED AIR GAP.
- 5 INDIRECT WASTE FROM 1 COMPARTMENT SINK AND ICE BIN / ICE MAKER TO FLOOR SINK WITH APPROVED AIR GAP.
- 6 INDIRECT WASTE FROM ICE MAKER AND DISPENSER TO FLOOR SINK WITH APPROVED AIR GAP.
- 7 CONNECT NEW 3" GREASE SANITARY WASTE PIPING TO EXISTING GREASE SANITARY LINE IN SPACE. CONTRACTOR TO FIELD VERIFY SIZE, ROUTING AND INVERT.
- 8 CONNECT NEW 3" VENT LINE TO EXISTING VENT LINE. CONTRACTOR VERIFY EXISTING VENT LINE LOCATION AND SIZE.
- 9 EXISTING GREASE SANITARY PIPES ARE SHOWN ON PLAN FOR REFERENCED ONLY. CONTRACTOR TO FIELD VERIFY EXISTING GREASE SANITARY LOCATION, SIZE AND CONDITION. REROUTE NEW PIPING AS REQUIRED. BASE BID ACCORDINGLY.
- 10 CONNECT NEW 2" GREASE SANITARY WASTE PIPING TO EXISTING GREASE SANITARY LINE IN SPACE. CONTRACTOR TO FIELD VERIFY SIZE, ROUTING AND INVERT.
- 11 EXISTING FLOOR DRAIN TO REMAIN WITH EXISTING PIPING AND FITTING. CONTRACTOR TO FIELD VERIFY EXISTING FLOOR DRAIN PIPING CONDITION AND LOCATION. REPLACE AND MOVE AS REQUIRED. EXISTING FLOOR DRAINS SHOWN ON PLAN FOR REFERENCE ONLY. BASE BID ACCORDINGLY.
- 12 EXISTING FCO ONLY FOR REFERENCE.
- 13 EXISTING GREASE INTERCEPTOR TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING GREASE INTERCEPTOR LOCATION, SIZE AND CAPACITY. THE EXISTING GREASE INTERCEPTOR MINIMUM CAPACITY SHOULD BE EQUAL TO 750 GALLON. UPGRADE IF REQUIRED (GB-500). BASE BID ACCORDINGLY.
- 14 EXISTING HAND SINK WITH EXISTING SANITARY, VENT WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING CONDITION OF EXISTING PIPING AND FIXTURE REPLACED IF REQUIRED.
- 15 EXISTING FLOOR SINK WITH EXISTING SANITARY, VENT WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING CONDITION OF EXISTING PIPING AND FIXTURE REPLACED IF REQUIRED.
- 16 CONNECT NEW 2" VENT TO EXISTING VENT. CONTRACTOR TO FIELD VERIFY LOCATION AND CONDITION. BASE BID ACCORDINGLY.
- 17 EXISTING VENT TO REMAIN. EXISTING VENT SHOWN ON PLAN FOR REFERENCE ONLY. CONTRACTOR TO FIELD VERIFY EXISTING VENT LOCATION AND CONDITION. REPLACE IF REQUIRED. BASE BID ACCORDINGLY.

SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:


APPROVED BY:

PROJECT NUMBER:

PLUMBING SANITARY
PIPING PLAN


P1.0

GRAPHIC SCALE: 1/4" = 1'-0"
0 4' 8' 12' 16'



1 PLUMBING WATER PIPING PLAN
P1.1
SCALE: 1/4" = 1'-0"

GRAPHIC SCALE: 1/4" = 1'-0"
0 4' 8' 12' 16'



P1.1

GENERAL NOTES:

1. CW/HW PIPING TO BE PROVIDED WITH INSULATION AS PER FLORIDA ENERGY CONSERVATION CODE 2023, 8 EDITION (REFER SHEET P0.1)
2. PROVIDE BRANCH PRV IF PRESSURE EXCEEDS 80 PSI.
3. CONTRACTOR TO FIELD VERIFY FEASIBILITY OF SLAB PENETRATION AS PER STRUCTURAL REQUIREMENT.
4. PROVIDE ACCESS PANELS FOR WATER HAMMER ARRESTOR, CLEANOUTS & SHUT-OFF VALVES AS REQUIRED.
5. REFER RISER DIAGRAMS FOR ALL PIPE SIZES.
6. PROVIDE TRAP PRIMER FOR FLOOR DRAIN AS PER LOCAL JURISDICTION.

DOMESTIC WATER PLAN NOTES:

1. ROUTE NEW 1" CW AND 1" HW PIPING WITH SHUT OFF VALVE AND TIE-INTO THE EXISTING WATER LINE. CONTRACTOR TO FIELD VERIFY EXISTING WATER TIE-IN LOCATION AND SIZE AND UPGRADE IF REQUIRED. BASE BID ACCORDINGLY.
2. PROVIDE A TEMPERING VALVE FOR LAVATORIES AND HAND SINK. POWER HYDROGUARD SERIES LFLM495, ASSE 1070 OR EQUAL. SET TEMPERATURE TO A MAXIMUM OF 110° F.
3. CONTRACTOR TO FIELD VERIFY THE AVAILABILITY OF WATER METER AND BFP FOR THE SPACE AND PROVIDE NEW IF NOT EXISTING. BASE BID ACCORDINGLY.
4. EXISTING PLUMBING FIXTURE WITH EXISTING CW/HW PIPING WITH ASSOCIATED ACCESSORIES AND FITTINGS TO REMAIN. CONTRACTOR TO FIELD VERIFY THE CONDITION OF EXISTING PIPING AND REPLACE IF REQUIRED.
5. EXISTING WATER HEATER WITH ASSOCIATED PIPING AND EQUIPMENT TO BE REMAIN. CONTRACTOR TO FIELD VERIFY EXISTING WATER HEATER AND ASSOCIATED EQUIPMENT'S CONDITION. REPLACE IF REQUIRED.
6. PROVIDE ASSE 1022 APPROVED WATTS SD-3, OR APPROVED EQUAL DUAL CHECK VALVE FOR BEVERAGE DISPENSING EQUIPMENT AND ICE MACHINE.

SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL


DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:

PLUMBING WATER PIPING
PLAN





DISCHARGE INTO RECEPTOR WITH AIR GAP SUFFICIENT TO REMOVE GRATE AND STRAINER. MAKE AIR GAP TWICE PIPE DIAMETER OR MINIMUM OF 2".

PROVIDE CLEANOUTS IN TURNS/ENDS OF PIPE, USE DW FITTINGS IF SIZE IS LARGER THAN 1".

SLOPE PIPE AS MUCH AS POSSIBLE TOWARD DISCHARGE.

MAKE CONNECTION TO EQUIPMENT AS REQUIRED.

VERIFY WITH LOCAL CODES IF/WHEN TRAP AND/OR VENT ARE REQUIRED FOR THE LENGTH OF DRAIN PIPE INSTALLED



PDI SIZE	PIPE SIZE	FIXTURE UNIT	FIXTURE UNIT TABULATION		
			LOAD	COLD	HOT
A	1/2"	1-11	VALVE WATER CLOSET	---	0
B	3/4"	12-32	TANK WATER CLOSET	5	---
C	1"	33-60	URINAL	5	---
D	1-1/4"	61-11	BLAVATORY/SINK	1.5	1.5
E	1-1/2"	14-15	ANITOR'S SINK	3	3
F	2"	154-33	SHOWER/BATHTUB	2	2

TO PROVIDE WATER HAMMER ARRESTERS BY SIOUX CITY, PRECISION PLUMBING PRODUCTS, WATTS OR APPROVED EQUIVALENT WITH PISTON AND O-RING CONSTRUCTION, HAVING PDI #WH-201, ASSE #1010 AND ANSI #A112.26.1M CERTIFICATION. INSTALL IN HORIZONTAL OR VERTICAL POSITION, BUT NEVER UPSIDE DOWN. INSTALL IN LINE WITH WATER FLOW DIRECTION IF POSSIBLE. SIZE THE UNITS AS SHOWN ON THE DRAWINGS AND/OR PER THE TABLES SHOWN ABOVE.

SHEET HISTORY SCHEDULE

ISSUE DATE:

FAZOLI'S, KISSIMMEE, FL

DRAWN BY:

QAQC:

APPROVED BY:

PROJECT NUMBER:



PLUMBING DETAILS

P5.0

PLUMBING FIXTURE SCHEDULE											
Fixture	Qty.	Equipment Category	Manufacturer	Model	Trap	Soil/Waste	Vent	CW	HW	Thermostatic Mixing Valve	Remarks
EX.WC	2	WATER CLOSET	EXISTING	EXISTING	-	E	-	E	-	-	-
EX.LAV	2	LAVATORY	EXISTING	EXISTING	E	E	-	E	E	-	-
EX.MS	1	MOP SINK	EXISTING	EXISTING	E	E	-	E	E	-	-
EX.HS	1	HAND SINK	EXISTING	EXISTING	E	E	-	E	E	-	-
E0.1	2	ICE/BVF. DISP.	COKE	-	-	1/2"	-	1/2"	-	-	INDIRECT DRAIN TO FLOOR SINK
E1.1	2	ICE MAKER	MANITOWOC	IYT-0620A	-	-	1/2"	-	1/2"	-	INDIRECT DRAIN TO FLOOR SINK, FILTER WATER FROM 1.3
E1.3	1	WATER FILTER	OPTIPURE	FXTS-12	-	-	-	1/2"	-	-	-
E27	1	DISPENSER, BEVERAGE/ NON CARBONATED	BUNN	ULTRA-2-0522	-	-	-	1/2"	-	-	-
E29	2	ICED TEA DISPENSER	-	-	-	-	-	1/2"	-	-	-
E37	1	6 WELL STEAM TABLE	DELFIELD	FZ000A03	-	-	-	1/2"	-	-	INDIRECT DRAIN TO FLOOR SINK
E39	1	PASTA COOKER ELECTRIC	PITCO	SSPE14	-	-	-	1/2"	-	-	INDIRECT DRAIN TO FLOOR SINK
E51.2	1	FLOOR THROUGH FOR KETTLES	JOHN BOOS	-	-	3"	-	-	-	-	3" INDIRECT DRAIN TO FLOOR THROUGH
E52	1	SWIVEL POT FILLER	T & S BRASS	B-0610	-	-	-	1/2"	1/2"	-	-
E60	1	S/S SOILED DISHABLE AND 3-COMP SINK	BEST	-	-	2"	-	-	-	-	INDIRECT DRAIN TO FLOOR SINK
E60.1	1	PRE-RINSE ASSEMBLY AND ADD ON FAUCET	T & S BRASS	B-0133	-	-	-	1/2"	1/2"	-	-
E61	1	S/S WORKTABLE W/ 1-COMP SINK	BEST	-	-	2"	-	-	-	-	INDIRECT DRAIN TO FLOOR SINK
E61.1	1	FAUCET AT PREP SINK	T & S BRASS	B-0230	-	-	-	1/2"	1/2"	-	-
E63	1	DISHMACHINE	-	-	-	-	-	1/2"	-	-	INDIRECT DRAIN TO FLOOR SINK
E66	1	ICE MAKER W/BIN	MANITOWOC	IYT1500A-261/D-970	-	-	1/2"	-	1/2"	-	INDIRECT DRAIN TO FLOOR SINK
E66.2	1	WATER FILTER	CHILTEC	SYSTEM4	-	-	-	1/2"	-	-	-
E69	1	BAG IN BOX RACK W/CARBONATOR	-	-	-	-	-	3/4"	-	-	-
E71	1	WATER FILTER	OPTIPURE	FX-22PC	-	-	-	3/4"	-	-	-
E82	2	SINK, HAND, WALL MOUNT W/FAUCET	JOHN BOOS	PBHS-W-1410-P-SSLR	PROVIDE	1-1/2"	-	1-1/2"	1/2"	1/2"	PROVIDE

PLUMBING PUMPS SCHEDULE									
Tag	Manufacturer Model No.	Type / Configuration	Service	Flow GPM	Total Head FT./PSI	Motor HP/Amps	Pump RPM	Electrical	Accessories / Remarks
RCP-1	BELL & GOSSETT #NBF-33	CENTRIFUGAL / IN-LINE	HOT WATER CIRCULATION	10.0	5	125W	2950	120/1/60	ALL BRONZE CONSTRUCTION

GREASE INTERCEPTOR SCHEDULE					
Item	Service	Flow Capacity (GPM)	Grease Capacity (LBS)	Liquid Capacity (Gallon)	Manufacturer and Model
GREASE INTERCEPTOR GI-1	KITCHEN WASTE	100	3048	510	SCHIER MODEL GB-500
NOTE: CONTRACTOR TO PROVIDE ALL REQUIRED ACCESSORIES FOR SATISFACTORY WORKING OF GREASE INTERCEPTOR AS PER SITE CONDITIONS.					



SHEET HISTORY SCHEDULE

ISSUE DATE: FAZOLI'S, KISSIMMEE, FL

DRAWN BY: QAQC: APPROVED BY: PROJECT NUMBER: PLUMBING RISERS AND SCHEDULES

P6.0