


GENERAL NOTES:

- 1. ALL SPRINKLER WORK SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF N.F.P.A.-13, N.F.P.A.-855 AND ALL LOCAL AUTHORITIES.
2. ALL SPRINKLER WORK SHALL COMPLY WITH FIRE PROTECTION STANDARDS AND REQUIREMENTS.
3. DRAWING INDICATES SPRINKLER SYSTEM DESIGN ONLY. CONTRACTOR RESPONSIBLE FOR OFFSETS, DROPS AND RISES FOR COORDINATION WITH OTHER TRADES.
...
17. COMPOSITE DRAWINGS

CONTRACTOR SHALL BE GIVEN A SEPIA TRANSPARENCIES TO IMPOSE THEIR WORK FOR A COORDINATED ALLOCATION OF SPACE. PROCEDURE SHALL INCLUDE PIPING, ELECTRICAL, STRUCTURAL AND ARCHITECTURAL DETAILS. SEPIAS SHALL BE GIVEN TO ALL TRADES WHO WILL DRAW HIS WORK ON DRAWINGS. G.C. SHALL HOLD A COORDINATION MEETING WITH ALL CONTRACTORS TO ELIMINATE INTERFERENCE OR CONFLICTS IN INSTALLING WORK. IF UNABLE TO EACH AGREEMENT ISSUE, G.C. SHALL MAKE BINDING DECISION.

SPRINKLER LEGEND



SPRINKLER DRAWING LIST

- SP-001.00 SPRINKLER GENERAL NOTE, SYMBOLS, ABBREVIATIONS AND SPECIFICATIONS.
SP-101.00 SPRINKLER OVERALL PLAN, DETAILED SPRINKLER PLAN & SPRINKLER RISER DIAGRAM.

DESIGN CRITERIA SUMMARY

HYDRAULIC CALCULATIONS BASED ON THE FOLLOWING:
OCCUPANCY: EXTRA HAZARD 1
MINIMUM DESIGN DENSITY: 0.30 GPM/SQ. FT.

SPACING BETWEEN SPRINKLER HEADS

EXTRA HAZARD 1: 10' MAX. COVERAGE PER SPRINKLER HEAD
NOTE: MAXIMUM DISTANCE BETWEEN SPRINKLER HEADS & WALLS IS 1/2 THE DISTANCE BETWEEN HEADS.

SPRINKLER SCHEDULE

Table with 11 columns: SYMBOL, NAME, COVERAGE, METAL, TEMPERATURE (°F), RESPONSE, K-FACTOR, NPT, MFG, MODEL#, APPROVALS. Row 1: ●, PENDENT, STANDARD, BRASS, 155, STANDARD, 5.6, 1/2", TYCO, TY325, cULus

SPRINKLER NOTES

- 1. THE COMPONENTS INSTALLATION, SIZING, SPACING, CLEARANCES, POSITION AND TYPE OF SYSTEMS SHALL CONFORM TO THE MASSACHUSETTS BUILDING CODE 2015 CHAPTER 9, MASSACHUSETTS FIRE CODE 2015 CHAPTER 9, MASSACHUSETTS FIRE SPRINKLER CODE 2013 / NFPA 13, 2013 AND NFPA 855.
2. ONLY APPROVED MATERIALS SHALL BE USED AS PER NFPA 13 CHAPTER 6 & CHAPTER 10.
...
24. THIS APPLICATION IS MADE ONLY FOR WORK INDICATED ON THE SPECIFICATION SHEET. ALL OTHER MATTERS SHOWN ARE NOT TO BE RELIED UPON OR TO BE CONSIDERED AS EITHER BEING APPROVED OR IN ACCORDANCE WITH APPLICABLE CODES.

SPECIAL INSPECTION SPRINKLER NOTE:

- 1. SPECIAL INSPECTION OF SPRINKLER SYSTEM TO BE PERFORMED IN ACCORDANCE WITH MASSACHUSETTS BUILDING CODE SECTION BC 1704.2 & 1704.3
2. FINAL INSPECTION IN ACCORDANCE WITH MASSACHUSETTS BUILDING CODE 2015 BC 110.3.10 AND AUTHORITY HAVING JURISDICTION.

HYDRAULIC CALCULATION SUMMARY

HYDRAULIC CALCULATIONS FOR COMMERCIAL AREA BASED ON NFPA 13-2013 SECTION 11.2.3 FOLLOWING:
OCCUPANCY: EXTRA HAZARD 1
MINIMUM DESIGN DENSITY: 0.30 GPM/SQ. FT. AS PER NFPA 13
DESIGN AREA OF APPLICATION: (161 SQ.FT. AREA)
HYDRAULICALLY REMOTEST AREA: 6
NUMBER OF HEADS CALCULATED: 5.6
K-FACTOR: 5.6

PROTECTION AREA OF SPRINKLER HEADS

EXTRA HAZARD 1 : 100 SQ. FT. MAX PER SPRINKLER HEAD

SPRINKLER SPECIFICATIONS


- PART 1 - GENERAL
1.01 REQUIREMENTS
A. THE SPRINKLER CONTRACTOR SHALL BE A LICENSED, AUTHORIZED INSTALLER OF SPRINKLER SYSTEMS AND SHALL HAVE HAD A MINIMUM OF FIVE YEARS EXPERIENCE IN THE INSTALLATION OF SPRINKLER SYSTEMS IN THE STATE OF MASSACHUSETTS.
...
2.06 ALTERNATES/SUBSTITUTIONS
CONTRACTOR SHALL STATE IN THEIR PROPOSAL ANY CONTRACTOR PROPOSED SUBSTITUTIONS OF THE MATERIALS OR METHODS OF INSTALLATION FROM THAT SPECIFIED. THESE ALTERATIONS SHALL BE LISTED ON THE PROPOSAL AS CONTRACTOR ALTERNATIVE.
2.07 LEAK DAMAGE
THE SPRINKLER CONTRACTOR SHALL BE RESPONSIBLE DURING THE INSTALLATION AND TESTING PERIODS OF THE SPRINKLER SYSTEM FOR ANY LOSS OR DAMAGE TO THE WORK OF OTHERS, TO THE PROPERTY, ITS CONTENTS ETC. CAUSED BY LEAKS IN THE EQUIPMENT, BY UNPLUGGED OR DISCONNECTED PIPES, FITTINGS ETC. OR BY OVERFLOW, AND SHALL PAY FOR THE NECESSARY REPLACEMENTS OR REPAIRS TO THE WORK OF OTHERS, DAMAGED BY SUCH LEAKAGE.

- 2.08 INSERTS, HANGERS, ETC.
F. ALL SPRINKLER PIPING SHALL BE SUBSTANTIALLY SUPPORTED AND SHALL COMPLY WITH THE STANDARDS FOR THE NATIONAL FIRE PROTECTION ASSOCIATION FOR THE INSTALLATION OF SPRINKLER SYSTEMS AND AS REQUIRED BY THE MASSACHUSETTS BUILDING CODE.
...
2.11 SPRINKLER HEADS
A. SPRINKLERS SHALL BE RATED FOR ORDINARY TEMPERATURES (155 DEG. F) EXCEPT AS REQUIRED NEAR HEATERS OR LOCATIONS WHERE ELEVATED TEMPERATURES MAY NORMALLY BE EXPECTED OR AS OTHERWISE INDICATED ON THE CONTRACT DRAWINGS.

- PART 3 - EXECUTION
3.01 GUARANTEE
A. GUARANTEE FOR A PERIOD OF ONE (1) YEAR FROM THE DATE OF ACCEPTANCE BY THE OWNER, ALL MATERIALS, APPARATUS AND WORKMANSHIP WHETHER FURNISHED BY HIMSELF OR BY HIS SUBCONTRACTORS AND HE SHALL REPLACE OR REPAIR IN A MANNER APPROVED BY THE PROPERTY MANAGEMENT, WITHOUT COST TO THE OWNER, ANY PART OR PARTS OF THE WORK WHICH MAY PROVE DEFECTIVE OR UNSATISFACTORY WITH IN THE PERIOD OF THE GUARANTEE.
3.02 INSTALLATION
A. PIPING
1. INSTALL PIPING AS SHOWN ON THE CONTRACT DRAWINGS AND STRAIGHT AND DIRECT AS POSSIBLE, FORMING RIGHT ANGLES OR PARALLEL LINES WITH WALLS, NEATLY SPACED, WITH RISERS PLUMB AND TRUE.
...
B. PIPE JOINTS
1. THREADED JOINTS SHALL BE MADE UP OF TIGHT USING PIPE JOINT TEFLON COMPOUND OR TAPE, APPLIED ON THE MALE THREADS ONLY.

FIRE NARRATIVE

DURING A FIRE EVENT, CONNECT THE WATER HOSE TO AN EXTERNAL FIRE DEPARTMENT CONNECTION PROVIDED BY THE END USER. WATER WILL IMMEDIATELY FLOW INTO THE ENTIRE DRY PIPE SYSTEM. ONLY OVERHEATED CABINET NOZZLE WITH TEMPERATURE BULB SHALL BE ACTIVATED AND SPRAYING WATER TO EXTINGUISH FIRE; (THE OUTDOOR WATER PIPE, SOURCE AND CONTROL SYSTEM SHOULD BE DONE BY OTHERS). WATER WILL CONTINUE TO FLOW THROUGH THE OPEN NOZZLE HEAD UNTIL THE ENTIRE CABINET IS FLOODED.



FIRE DETECTION AND EXTINGUISH GENERAL FLOW DIAGRAM

NY ENGINEERS
NEARBY ENGINEERS
382 NE 191ST STREET SUITE
49674, MIAMI, FL 33179
PH-914.257.3455
WWW.NY-ENGINEERS.COM


PROJECT NAME

PHYSICAL LOCATION


DRAWING TITLE
SPRINKLER GENERAL NOTES, SYMBOLS, ABBREVIATIONS AND SPECIFICATIONS

GRAPHIC SCALE


Table with project details: SEAL, PROJECT NO., SCALE (AS NOTED), DRAWN BY (NYE), CHECKED BY (NYE), DATE (01/19/2024), SHEET NUMBER (SP-001.00)




1 SPRINKLER OVERALL PLAN
SCALE: 1/16" = 1'-0"



3 CONCRETE RING PIT CROSS SECTION DETAILS
SCALE: NTS




4 FIRE DEPARTMENT CONNECTION DETAIL
SCALE: NTS



5 SPRINKLER RISER DIAGRAM
SCALE: NTS

DESIGN AS PER NFPA 13 FOR EXTRA HAZARD-1 OCCUPANCY. DESIGN BASED ON DRY PIPE SPRINKLER CONSISTING OF MOST REMOTE SIX (6) HYDRAULICALLY MOST DEMANDING STANDARD RESPONSE SPRINKLERS.
DESIGN DENSITY = 0.3 GPM/SQ.FT.



2 DETAILED SPRINKLER PLAN
SCALE: 1/2" = 1'-0"

- SPRINKLER LEGEND:**
- ① FIRE DEPARTMENT SPRINKLER CONNECTION 2½"x2½"x4", 36" AFF. (PROVIDE SOLID BRONZE MATERIAL FOR FIRE DEPARTMENT CONNECTION). REFER KEY PLAN ON SHEET SP-001 FOR EXACT LOCATION.
 - ② NEW 2" DRY SPRINKLER PIPE RUNNING UNDERGROUND. COORDINATE PIPING LAYOUT W/ SOLAR CONSULTANT.
 - ③ COORDINATE SPRINKLER LOCATION & PIPING W/ EQUIPMENT CONTRACTOR.
 - ④ COORDINATE WITH CABINET MANUFACTURER AND GC FOR SPRINKLER PIPING SUPPORT FROM THE CABINET. PROVIDE ADD ALTERNATE FOR ANY ADDITIONAL PIPING SUPPORTS IF REQUIRED.
 - ⑤ SPRINKLER PIPING AND SPRINKLER HEAD BY CABINET MANUFACTURER. COORDINATE PIPING CONNECTION WITH CABINET MANUFACTURER.
 - ⑥ 1" DRAIN PIPE W/ MANUAL DRAIN CONTROL VALVE. INSTALL VERTICALLY. REFER DETAIL #3.

HAZARD CLASSIFICATION AND DESIGN DENSITY:
AREA : BATTERY CABINET

OCCUPANCY: EXTRA HAZARDS I
MINIMUM DESIGN DENSITY: 0.30 GPM/SQ. FT.

NO.	DATE	ISSUE DESCRIPTION

NY ENGINEERS
NEARBY ENGINEERS
382 NE 191ST STREET SUITE
49674, MIAMI, FL 33179
PH-914.257.3455
WWW.NY-ENGINEERS.COM

PROJECT NAME

PHYSICAL LOCATION

DRAWING TITLE

**SPRINKLER OVERALL PLAN ,
DETAILED SPRINKLER PLAN &
SPRINKLER RISER DIAGRAM**

GRAPHIC SCALE

SEAL

PROJECT NO.	-
SCALE	AS NOTED
DRAWN BY	NYE
CHECKED BY	NYE
DATE	01/19/2024
SHEET NUMBER	SP-101.00

Fire Sprinkler Reports

Prepared By:

NY ENGINEERS

12/06/2023

12/06/2023

General Project Data Report

General Data

Project Title:	Project File Name:
Designed By:	Date:
Code Reference:	Approving Agency:
Client Name:	Phone:
Address:	City, State Zip Code:
Company Name:	Representative:
Company Address:	City And State:
Phone:	
Building Name:	Building Owner:
Contact at Building:	Phone at Building:
Address Of Building:	City, State Zip Code:

Project Data

Description Of Hazard:	Ex. Haz. Gp. 1	Sprinkler System Type:	Dry
Design Area Of Water Application:	161 ft ²	Maximum Area Per Sprinkler:	50 ft ²
Default Sprinkler K-Factor:	5.60 K	Default Pipe Material:	SCHED 40 WET STEEL
Inside Hose Stream Allowance:	0.00 gpm	Outside Hose Stream Allowance:	0.00 gpm
In Rack Sprinkler Allowance:	0.00 gpm		

Sprinkler Specifications

Make:	TYCO	Model:	TY325
Size:	0.50	Temperature Rating:	155 F

Water Supply Test Data

Source Of Information:		Date Of Test:	
Test Hydrant ID:			
Hydrant Elevation:	0 ft	Static Pressure:	0.00 psi
Test Flow Rate:	0.00 gpm	Test Residual Pressure:	0.00 psi
Calculated System Flow Rate:	93.67 gpm	Calculated Inflow Residual Pressure:	130.91 psi

Calculation Project Data

Calculation Mode:	Demand	Minimum Desired Flow Density:	0.30 gpm/ft ²
HMD Minimum Residual Pressure:	7.00 psi	Number Of Inactive Pipes:	0
Number Of Active Nodes:	23	Number Of Inactive Sprinklers:	0
Number Of Active Pipes:	22		
Number Of Active Sprinklers:	6		

Fire Sprinkler Input Data

Node Input Data

Node No.	Node Description Branch Description	Area Group Branch Dia. (in)	Sprinkler KFactor (K) Branch Len. (ft)	Pressure Estimate (psi) Branch Std Fittings	Node Elev (ft) Branch Non- Std Fittings (ft)	Non-Sprinkler Flow (gpm) Branch Sprk KFactor (K)
1	No Discharge ----	---- 0.000	N/A 0.0	7.20 ----	8.00 0.0	0.00 0.00
2	No Discharge ----	---- 0.000	N/A 0.0	7.24 ----	8.00 0.0	0.00 0.00
3	No Discharge ----	---- 0.000	N/A 0.0	7.40 ----	8.00 0.0	0.00 0.00
4	No Discharge ----	---- 0.000	N/A 0.0	7.73 ----	8.00 0.0	0.00 0.00
5	No Discharge ----	---- 0.000	N/A 0.0	8.31 ----	8.00 0.0	0.00 0.00
6	No Discharge ----	---- 0.000	N/A 0.0	9.20 ----	8.00 0.0	0.00 0.00
7	No Discharge ----	---- 0.000	N/A 0.0	10.70 ----	8.00 0.0	0.00 0.00
8	No Discharge ----	---- 0.000	N/A 0.0	17.19 ----	-2.00 0.0	0.00 0.00
9	No Discharge ----	---- 0.000	N/A 0.0	131.75 ----	-2.00 0.0	0.00 0.00
10	No Discharge ----	---- 0.000	N/A 0.0	130.41 ----	3.00 0.0	0.00 0.00
11	No Discharge ----	---- 0.000	N/A 0.0	130.91 ----	3.00 0.0	0.00 0.00
12	No Discharge ----	---- 0.000	N/A 0.0	9.10 ----	8.00 0.0	0.00 0.00
13	No Discharge ----	---- 0.000	N/A 0.0	8.22 ----	8.00 0.0	0.00 0.00
14	No Discharge ----	---- 0.000	N/A 0.0	7.65 ----	8.00 0.0	0.00 0.00
15	No Discharge ----	---- 0.000	N/A 0.0	7.32 ----	8.00 0.0	0.00 0.00
16	No Discharge ----	---- 0.000	N/A 0.0	7.17 ----	8.00 0.0	0.00 0.00
17	No Discharge ----	---- 0.000	N/A 0.0	7.12 ----	8.00 0.0	0.00 0.00
101	Sprinkler ----	---- 0.000	5.60 0.0	7.17 ----	7.00 0.0	0.00 0.00

Fire Sprinkler Input Data

Node Input Data (cont'd)

Node No.	Node Description Branch Description	Area Group Branch Dia. (in)	Sprinkler KFactor (K) Branch Len. (ft)	Pressure Estimate (psi) Branch Std Fittings	Node Elev (ft) Branch Non- Std Fittings (ft)	Non-Sprinkler Flow (gpm) Branch Sprk KFactor (K)
102	Sprinkler ----	---- 0.000	5.60 0.0	7.22 ----	7.00 0.0	0.00 0.00
103	Sprinkler ----	---- 0.000	5.60 0.0	7.36 ----	7.00 0.0	0.00 0.00
104	Sprinkler ----	---- 0.000	5.60 0.0	7.68 ----	7.00 0.0	0.00 0.00
105	Sprinkler ----	---- 0.000	5.60 0.0	8.22 ----	7.00 0.0	0.00 0.00
106	Sprinkler ----	---- 0.000	5.60 0.0	9.06 ----	7.00 0.0	0.00 0.00

Fire Sprinkler Input Data

Pipe Input Data

Beg. Node	End. Node	Pipe Description	Nominal Diameter (inch)	Type Group	Fitting Data	Nominal Length (feet)	Fitting Length (feet)	Total Length (feet)	CFactor (gpm/inc h-psi)
101	17	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
1	2	SCHED 40 WET STEEL	2.000	0	T	5.40	10.00	15.40	120
102	16	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
2	3	SCHED 40 WET STEEL	2.000	0	T	5.40	10.00	15.40	120
103	15	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
3	4	SCHED 40 WET STEEL	2.000	0	T	5.40	10.00	15.40	120
104	14	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
4	5	SCHED 40 WET STEEL	2.000	0	T	5.40	10.00	15.40	120
105	13	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
5	6	SCHED 40 WET STEEL	2.000	0	T	5.40	10.00	15.40	120
106	12	SCHED 40 WET STEEL	1.000	0	E	3.00	2.00	5.00	120
6	7	SCHED 40 WET STEEL	2.000	0	T	8.00	10.00	18.00	120
7	8	SCHED 40 WET STEEL	2.000	0	EC	10.00	16.00	26.00	120
8	9	SCHED 40 WET STEEL	2.000	0	5E	1350.00	25.00	1375.00	120
9	10	SCHED 40 WET STEEL	2.000	0	E	5.00	5.00	10.00	120
10	11	SCHED 40 WET STEEL	2.000	0	E	1.00	5.00	6.00	120
17	1	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120
16	2	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120
15	3	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120
14	4	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120
13	5	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120
12	6	SCHED 40 WET STEEL	1.000	0		1.00	0.00	1.00	120

Fire Sprinkler Output Data

Overall Node Groupings Output Data

Pipe Segment Beg. Node	End. Node	Pipe Type Group	Pipe Flow Rate (gpm)	Sprinkler Flow At Beg. Node (gpm)	Non-Sprinkler Flow Out (+) (gpm)	In (-) (gpm)	Beg. Node Residual Pressure (psi)	Imbalance Flow At Beg. Node (gpm)
1	2	0	-15.00	0.00	0.00	0.00	7.20	0.00000
1	17	0	15.00					
2	1	0	15.00	0.00	0.00	0.00	7.24	0.00000
2	3	0	-30.04					
2	16	0	15.04					
3	2	0	30.04	0.00	0.00	0.00	7.40	0.00000
3	4	0	-45.24					
3	15	0	15.20					
4	3	0	45.24	0.00	0.00	0.00	7.73	0.00000
4	5	0	-60.76					
4	14	0	15.52					
5	4	0	60.76	0.00	0.00	0.00	8.31	0.00000
5	6	0	-76.81					
5	13	0	16.06					
6	5	0	76.81	0.00	0.00	0.00	9.20	0.00000
6	7	0	-93.67					
6	12	0	16.86					
7	6	0	93.67	0.00	0.00	0.00	10.70	0.00000
7	8	0	-93.67					
8	7	0	93.67	0.00	0.00	0.00	17.19	0.00000
8	9	0	-93.67					
9	8	0	93.67	0.00	0.00	0.00	131.75	0.00000
9	10	0	-93.67					
10	9	0	93.67	0.00	0.00	0.00	130.41	0.00000
10	11	0	-93.67					
11	10	0	93.67	0.00	0.00	-93.67	130.91	
12	6	0	-16.86	0.00	0.00	0.00	9.10	0.00000
12	106	0	16.86					
13	5	0	-16.06	0.00	0.00	0.00	8.22	0.00000
13	105	0	16.06					
14	4	0	-15.52	0.00	0.00	0.00	7.65	0.00000
14	104	0	15.52					
15	3	0	-15.20	0.00	0.00	0.00	7.32	0.00000
15	103	0	15.20					
16	2	0	-15.04	0.00	0.00	0.00	7.17	0.00000
16	102	0	15.04					
17	1	0	-15.00	0.00	0.00	0.00	7.12	0.00000
17	101	0	15.00					

Fire Sprinkler Output Data

Overall Node Groupings Output Data (cont'd)

Pipe Segment Beg. Node	End. Node	Pipe Type Group	Pipe Flow Rate (gpm)	Sprinkler Flow At Beg. Node (gpm)	Non-Sprinkler Flow Out (+) (gpm)	In (-) (gpm)	Beg. Node Residual Pressure (psi)	Imbalance Flow At Beg. Node (gpm)
101	17	0	-15.00	15.00	0.00	0.00	7.17	0.00000
102	16	0	-15.04	15.04	0.00	0.00	7.22	0.00000
103	15	0	-15.20	15.20	0.00	0.00	7.36	0.00000
104	14	0	-15.52	15.52	0.00	0.00	7.68	0.00000
105	13	0	-16.06	16.06	0.00	0.00	8.22	0.00000
106	12	0	-16.86	16.86	0.00	0.00	9.06	0.00000

Fire Sprinkler Output Data

Overall Pipe Output Data

Beg. End. Node	Nodal KFactor (K)	Elevation (feet)	Spk/Hose Discharge (gpm)	Residual Pressure (psi)	Nom. Dia. Inside Dia. C-Value	q (gpm) Q (gpm) Velocity (fps)	F. L./ft (psi/ft) Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (ft)	PF-(psi) PE-(psi) PT-(psi)
17	0.00	8.00	0.00	7.12	1.00	0.00	0.07646	1.00	0.076
1	0.00	8.00	0.00	7.20	1.049	15.00	-----	0.00	0.000
	SCHED 40 WET STEEL				120	5.57	0	1.00	0.076
1	0.00	8.00	0.00	7.20	2.00	0.00	0.00281	5.40	0.043
2	0.00	8.00	0.00	7.24	2.067	15.00	T	10.00	0.000
	SCHED 40 WET STEEL				120	1.43	0	15.40	0.043
16	0.00	8.00	0.00	7.17	1.00	0.00	0.07686	1.00	0.077
2	0.00	8.00	0.00	7.24	1.049	15.04	-----	0.00	0.000
	SCHED 40 WET STEEL				120	5.58	0	1.00	0.077
2	0.00	8.00	0.00	7.24	2.00	0.00	0.01016	5.40	0.156
3	0.00	8.00	0.00	7.40	2.067	30.04	T	10.00	0.000
	SCHED 40 WET STEEL				120	2.87	0	15.40	0.156
15	0.00	8.00	0.00	7.32	1.00	0.00	0.07831	1.00	0.078
3	0.00	8.00	0.00	7.40	1.049	15.20	-----	0.00	0.000
	SCHED 40 WET STEEL				120	5.64	0	1.00	0.078
3	0.00	8.00	0.00	7.40	2.00	0.00	0.02167	5.40	0.334
4	0.00	8.00	0.00	7.73	2.067	45.24	T	10.00	0.000
	SCHED 40 WET STEEL				120	4.33	0	15.40	0.334
14	0.00	8.00	0.00	7.65	1.00	0.00	0.08141	1.00	0.081
4	0.00	8.00	0.00	7.73	1.049	15.52	-----	0.00	0.000
	SCHED 40 WET STEEL				120	5.76	0	1.00	0.081
4	0.00	8.00	0.00	7.73	2.00	0.00	0.03740	5.40	0.576
5	0.00	8.00	0.00	8.31	2.067	60.76	T	10.00	0.000
	SCHED 40 WET STEEL				120	5.81	0	15.40	0.576
13	0.00	8.00	0.00	8.22	1.00	0.00	0.08673	1.00	0.087
5	0.00	8.00	0.00	8.31	1.049	16.06	-----	0.00	0.000
	SCHED 40 WET STEEL				120	5.96	0	1.00	0.087
5	0.00	8.00	0.00	8.31	2.00	0.00	0.05771	5.40	0.889
6	0.00	8.00	0.00	9.20	2.067	76.81	T	10.00	0.000
	SCHED 40 WET STEEL				120	7.34	0	15.40	0.889
12	0.00	8.00	0.00	9.10	1.00	0.00	0.09489	1.00	0.095
6	0.00	8.00	0.00	9.20	1.049	16.86	-----	0.00	0.000
	SCHED 40 WET STEEL				120	6.26	0	1.00	0.095
6	0.00	8.00	0.00	9.20	2.00	0.00	0.08331	8.00	1.500
7	0.00	8.00	0.00	10.70	2.067	93.67	T	10.00	0.000
	SCHED 40 WET STEEL				120	8.96	0	18.00	1.500
7	0.00	8.00	0.00	10.70	2.00	0.00	0.08331	10.00	2.166
8	0.00	-2.00	0.00	17.19	2.067	93.67	EC	16.00	4.330
	SCHED 40 WET STEEL				120	8.96	0	26.00	6.496

Fire Sprinkler Output Data

Overall Pipe Output Data (cont'd)

Beg. End. Node	Nodal KFactor (K)	Elevation (feet)	Spk/Hose Discharge (gpm)	Residual Pressure (psi)	Nom. Dia. Inside Dia. C-Value	q (gpm) Q (gpm) Velocity (fps)	F. L./ft (psi/ft) Fittings Type-Grp	Pipe-Len. Fit-Len. Tot-Len. (ft)	PF-(psi) PE-(psi) PT-(psi)
8	0.00	-2.00	0.00	17.19	2.00	0.00	0.08331	1350.00	114.552
9	0.00	-2.00	0.00	131.75	2.067	93.67	5E	25.00	0.000
	SCHED 40 WET STEEL				120	8.96	0	1375.00	114.552
9	0.00	-2.00	0.00	131.75	2.00	0.00	0.08331	5.00	0.833
10	0.00	3.00	0.00	130.41	2.067	93.67	E	5.00	-2.165
	SCHED 40 WET STEEL				120	8.96	0	10.00	-1.332
10	0.00	3.00	0.00	130.41	2.00	0.00	0.08331	1.00	0.500
11	0.00	3.00	0.00	130.91	2.067	93.67	E	5.00	0.000
	SCHED 40 WET STEEL				120	8.96	0	6.00	0.500
106	5.60	7.00	16.86	9.06	1.00	16.86	0.09489	3.00	0.474
12	0.00	8.00	0.00	9.10	1.049	16.86	E	2.00	-0.433
	SCHED 40 WET STEEL				120	6.26	0	5.00	0.041
105	5.60	7.00	16.06	8.22	1.00	16.06	0.08673	3.00	0.434
13	0.00	8.00	0.00	8.22	1.049	16.06	E	2.00	-0.433
	SCHED 40 WET STEEL				120	5.96	0	5.00	0.001
104	5.60	7.00	15.52	7.68	1.00	15.52	0.08141	3.00	0.407
14	0.00	8.00	0.00	7.65	1.049	15.52	E	2.00	-0.433
	SCHED 40 WET STEEL				120	5.76	0	5.00	-0.026
103	5.60	7.00	15.20	7.36	1.00	15.20	0.07831	3.00	0.392
15	0.00	8.00	0.00	7.32	1.049	15.20	E	2.00	-0.433
	SCHED 40 WET STEEL				120	5.64	0	5.00	-0.041
102	5.60	7.00	15.04	7.22	1.00	15.04	0.07686	3.00	0.384
16	0.00	8.00	0.00	7.17	1.049	15.04	E	2.00	-0.433
	SCHED 40 WET STEEL				120	5.58	0	5.00	-0.049
101	5.60	7.00	15.00	7.17	1.00	15.00	0.07646	3.00	0.382
17	0.00	8.00	0.00	7.12	1.049	15.00	E	2.00	-0.433
	SCHED 40 WET STEEL				120	5.57	0	5.00	-0.051

Fire Sprinkler Output Data

Overall Sprinkler Output Data

Flowing Sprinkler Node No.	Area Group Code	Sprinkler KFactor (K)	Sprinkler Elevation (feet)	Residual Pressure (psi)	Flowing Area (ft ²)	Flowing Density (gpm/ft ²)	Sprinkler Discharge (gpm)
101		5.60	7.00	7.17	50.00	0.300	15.00
Sub Totals For Non-Group					50.00	0.300	15.00
102		5.60	7.00	7.22	50.00	0.301	15.04
Sub Totals For Non-Group					50.00	0.301	15.04
103		5.60	7.00	7.36	50.00	0.304	15.20
Sub Totals For Non-Group					50.00	0.304	15.20
104		5.60	7.00	7.68	50.00	0.310	15.52
Sub Totals For Non-Group					50.00	0.310	15.52
105		5.60	7.00	8.22	50.00	0.321	16.06
Sub Totals For Non-Group					50.00	0.321	16.06
106		5.60	7.00	9.06	50.00	0.337	16.86
Sub Totals For Non-Group					50.00	0.337	16.86
Totals For All Groups					300.00	0.312	93.67

Fire Sprinkler Output Summary

Hydraulically Most Demanding Sprinkler Node

HMD Sprinkler Node Number:	101
HMD Actual Residual Pressure:	7.17 psi
HMD Actual GPM:	15.00 gpm

Sprinkler Summary

Sprinkler System Type:	Dry
Specified Area Of Application:	161.00 ft ²
Adjusted Area Of Application:	209.30 ft ²
Minimum Desired Density:	0.300 gpm/ft ²
Application Average Density:	0.582 gpm/ft ²
Application Adjusted Density (not required by NFPA 13):	0.448 gpm/ft ²
Application Average Area Per Sprinkler:	26.83 ft ²
Adjusted Area Per Sprinkler (not required by NFPA 13):	34.88 ft ²
Sprinkler Flow:	93.67 gpm
Average Sprinkler Flow:	15.61 gpm

Flow Velocity And Imbalance Summary


Maximum Flow Velocity (In Pipe 9 - 10)	8.96 ft/sec
Maximum Velocity Pressure (In Pipe 9 - 10)	0.54 psi
Allowable Maximum Nodal Pressure Imbalance:	0.0100 psi
Actual Maximum Nodal Pressure Imbalance:	0.0000 psi
Actual Average Nodal Pressure Imbalance:	0.0000 psi
Actual Maximum Nodal Flow Imbalance:	0.0000 gpm
Actual Average Nodal Flow Imbalance:	0.0000 gpm

Overall Network Summary

Number Of Unique Pipe Sections:	22
Number Of Flowing Sprinklers:	6
Pipe System Water Volume:	245.30 gal
Sprinkler Flow:	93.67 gpm
Non-Sprinkler Flow:	0.00 gpm
Minimum Required Residual Pressure At System Inflow Node:	130.91 psi
Demand Flow At System Inflow Node:	93.67 gpm

Fire Sprinkler Output Data

Hydraulic Supply/Demand Graph



Demand Curve Data

Calculated Residual Pressure: 130.91 psi

Calculated Flow Rate: 93.67 gpm

Pressure Required For First Sprinkler Downstream From Inflow Node To Flow: 1.73 psi