



FIRE ALARM KEYED WORK NOTES

- ① ALL NEW FIRE ALARM DEVICES SHALL BE CONNECTED TO THE EXISTING FIRE ALARM CONTROL PANEL. CONTRACTOR SHALL COORDINATE WITH BASE BUILDING/OWNER.
- ② FIRE ALARM ANNUNCIATOR PANEL (FAAP) SHOULD BE COMPATIBLE WITH BASE BUILDING FAAP AND SHALL BE INTEGRATED WITH CITIZEN'S BMS.

