



Property of NYE Engineers

GREASE INTERCEPTOR SCHEDULE

ITEM	LOCATION	SERVICE	FLOW IN GPM	GREASE CAPACITY IN LBS	REMARKS
GREASE INTERCEPTOR GI-1	GROUND FLOOR	SECTION-3/ SECTION-6	70	175.6	-SCHIER, MODEL GB-3 INTERCEPTOR. SIZE-37"X28"X21"

- NOTES:
 1. CONCRETE AROUND EXISTING GREASE TRAP SHALL BE CUT AS NECESSARY TO CONNECT PIPING TO NEW GREASE TRAP.
 2. PROVIDE THIRD OUTLET FOR CLEAN OUT AT SIDE OF GREASE TRAP FROM MANUFACTURER. PROVIDE CLEAN OUT FLUSH WITH FLOOR NEXT TO PIT.

AIR COMPRESSOR SCHEDULE

ITEM	LOCATION	CAPACITY	MHP	RATED AIR DELIVERY	MODEL	REMARKS
AIR COMPRESSOR	GROUND FLOOR	80 GALLONS	7.5	27.5 CFM @ 115PSI	INGERSOLL RAND R5.5i-TAS	DIMENSIONS: 68.5"LX30"WX67.2"H

- NOTES:
 1. CONNECT CONDENSATE DRAIN PIPE TO NEAREST SINK WITH FUNNEL DRAIN.